

## Condition 30

# Appendix 5C1

Burnaby Terminal - Power System Study with Short Circuit Analysis, Arc Flash, and Protection Coordination Study





01-13283-TB-BB02-TTF-RPT-0001 **Trans Mountain Expansion Project** 

Burnaby Terminal – Power System Study with Short Circuit Analysis, Arc Flash, and Protection Coordination Study

Contractor Revision Date:	2017-02-10
Contractor Revision No.:	В
Page	1 of 356



## **Trans Mountain Expansion Project**

# Burnaby Terminal – Power System Study with Short Circuit Analysis, Arc Flash, and Protection Coordination Study

KMC Document # 01-13283-TB-BB02-TTF-RPT-0001



Rev No.	Prepared by/ Date	Reviewed by/ Date	Approved by/ Date	TMEP Acceptance/ Date	Pages Revised	Issued Type
А	L. Fotoohi 2017-01-31	D. Dapcevic 2017-01-31	K. Savage 2017-01-31			Issued for Review
В	L. Fotoohi 2017-02-10	D. Dapcevic 2017-02-10	K. Savage 2017-02-10			Issued for Information



## **Burnaby Terminal**

# Power System Study with Short Circuit Analysis, Arc Flash, and Protection Coordination Study

#### Prepared by:



Project No. 719-216239.00

Document No. 01-13283-TB-BB02-TTF-RPT-0001, Rev. B

#### **PRESENTED TO**

Kinder Morgan Canada Inc. Suite 2700, 300 – 5<sup>th</sup> Avenue SW Calgary, AB T2P 5J2

#### **Revision Table**

Rev	Status	Issue Date	Originator	Checker	Approver
В	Issued for Information	February 10, 2017	L. Fotoohi	D. Dapcevic	K. Savage
Α	Issued for Review	January 31, 2017	L. Fotoohi	D. Dapcevic	K. Savage

#### **Third Party Disclaimer**

The content of this document is not intended to be of use nor relied upon by any person, firm or corporation, other than the addressee. Tetra Tech denies any liability whatsoever to other parties for damages or injuries incurred by the use of this document without prior express written approval of Tetra Tech and the addressee. This document is subject to further restrictions imposed by the contract between the addressee and Tetra Tech.

### **TABLE OF CONTENTS**

1.0	INTR	ODUCTION	1
	1.1	Short Circuit Study – Objectives and Standards	1
	1.2	Arc Flash and Protection Coordination Study – Objectives and Standards	2
	1.3	Facility Power System Description	2
2.0	Sно	RT CIRCUIT STUDY	6
	2.1	Purpose	6
	2.2	The A_Fault Program	6
	2.3	Fault Contributions	7
	2.4	Cable Impedances	8
	2.5	Transformer Data	8
	2.6	Low Voltage Fault Duties	8
	2.7	Medium Voltage Momentary Duties	9
	2.8	Results	9
3.0	ARC	FLASH AND PROTECTION COORDINATION STUDY	12
	3.1	Purpose	12
	3.2	Arc Flash Overview	12
	3.3	SKM PTW Arc Flash Software Configurations	13
	3.4	Arc Flash Evaluation Report	13
	3.5	Arc Flash Evaluation Interpretation	14
	3.6	Basis for Modeling	15
	3.7	Criteria for Protective Device Coordination	15
	3.8	Results	15
4.0	ALTI	ERNATE SCENARIO – EMERGENCY GENERATOR	53
	4.1	Introduction	53
	4.2	Short Circuit Results Summary	53
	4.3	Arc Flash Results	53
5.0	REC	OMMENDATIONS AND RELAY SETTINGS	54
	5.1	Substation 1 Relays	55
	5.2	Substation 2 Relays	58
6.0	Con	ICLUSION	62
LIS	то	F TABLES	
Tabl	e 1: B	olted Short Circuit Calculation Standards	1
		rc Flash and Protection Coordination Study Calculation Standards	
		rc Flash SKM Report Definitions	
		•	

#### **LIST OF APPENDICES**

Appendix 1 Short Circuit Analysis

Appendix 2 Arc Flash Results and Protective Device Coordination

Appendix 3 Alternate Scenario – Emergency Generator

Appendix 4 Reference Drawings

#### **Abbreviations**

Abbreviation	Definition
ATS	Automatic Transfer Switch
СТІ	Coordination Time Interval
CSA	Canadian Standards Association
FCT	Fault Clearing Time
IEEE	Institute of Electrical and Electronics Engineers
LSIG	Long-time Short-time Instantaneous Ground
MCC	Motor Control Center
NGR	Neutral Grounding Resistor
PPE	Personal Protective Equipment
TCC	Time Current Curve
TMEP	Trans Mountain Expansion Project
VFD	Variable Frequency Drive

#### 1.0 INTRODUCTION

This Power System Study applies to the Trans Mountain Expansion Project (TMEP) Burnaby Terminal power distribution system. The future terminal equipment has been evaluated for short circuit currents and for arc flash incident energy and protective device coordination.

Power comes to the terminal via two 12.47 kV feeders from BC Hydro. These utility feeders are known as the Shellmont feeder and the Aubrey feeder. The voltage levels covered in this study are 12470 V, 4160 V, 600 V, and 480 V; this includes transformers, switchgear, all Motor Control Centers (MCCs), and any other major connecting points.

The information sources for this study are from Burnaby Terminal preliminary design single line diagrams and a software model of the existing part of the system developed for the 2008 Arc Flash Study. The data required to perform the analysis consists of fault contribution; equipment ratings; feeder data; transformer data; and protection device make, model, and their associated settings. Since part of the system has not yet been built, most values are based on preliminary design information.

The Power System Study was prepared using PowerTools for Windows, Version 7.0, developed by SKM System Analysis Inc.

#### 1.1 Short Circuit Study – Objectives and Standards

The objectives of the Short Circuit Analysis are as follows:

- Calculate fault levels for buses 480 V and above.
- Evaluate equipment ratings versus available fault levels.
- Identify equipment at which fault levels are a concern and provide recommendations where relevant.

Bolted short circuit calculations used in this study comply with the standards in Table 1.

**Table 1: Bolted Short Circuit Calculation Standards** 

Standard	Title
ANSI C37.010	IEEE Application Guide for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis
ANSI C37.5	Guide for Calculation of Fault Currents for Application of AC High-Voltage Circuit Breakers Rated on a Total Current Basis
ANSI C37.13	Low-Voltage AC Power Circuit Breakers Used in Enclosures
IEEE 141-1993	IEEE Recommended Practice for Electric Power Distribution for Industrial Plants  – Red Book

#### 1.2 Arc Flash and Protection Coordination Study – Objectives and Standards

The objectives of the Arc Flash and Protection Coordination Study are as follows:

- Complete a combined Arc Flash and Protection Coordination Study.
- Prepare Time Current Curves (TCCs) to clearly demonstrate the coordination method and settings, and summarize the findings in a report including Protective Device Coordination Time Interval (CTI).
- Complete Arc Flash Study for all buses 480 V and above to meet the requirements of Canadian Standards Association (CSA) Z462.
- Prepare an Arc Flash Evaluation Report to summarize the data used in calculations, the arc flash levels, and recommendations.
- Review results of the study and recommended Personal Protective Equipment (PPE) requirements.
- Recommend possible improvements to decrease arc flash levels and improve coordination.

The standards in Table 2 were used to evaluate protective device coordination and arc flash incident energy levels, and to determine PPE.

StandardTitleIEEE 242-2001IEEE Recommended Practice for Protection and Coordination of Industrial and<br/>Commercial Power Systems (IEEE Buff Book)CSA Z462-15Workplace Electrical SafetyIEEE 1584-2002IEEE Guide for Performing Arc-Flash Hazard Calculations

Table 2: Arc Flash and Protection Coordination Study Calculation Standards

The purpose of coordination is to isolate faults selectively in the shortest time with minimum system shutdown. All protective devices between the motor and the source of power must be set and sized to coordinate with each other to ensure that only the faulted area is disconnected from the circuit.

#### 1.3 Facility Power System Description

The Burnaby Terminal is fed from BC Hydro, Shellmont, and Aubrey substations via two 12.47 kV feeders to the incoming disconnect switches at each of the Trans Mountain owned 12.47 kV indoor Substations BB-SUB1 and BB-SUB2. The power from the Shellmont feeder is further distributed from the 12.47 kV circuit breaker to Substation 1 Transformer SUB1-TXR. The power from the Aubrey feeder is further distributed from the 12.47 kV circuit breaker to Substation 2 Transformer SUB2-TXR. A 15 A, 10 second rated Neutral Grounding Resistor (NGR) is located at the secondary winding of each substation transformer and will limit any ground faults to 15 A, preventing any ground fault related arc flash event.

#### 1.3.1 New Substation 1 (BB-SUB1) Equipment

Refer to single line drawings in Appendix 4.

From 12.47 kV Substation BB-SUB1, power is distributed through the main incoming breaker SUB1 Breaker and Power Transformer SUB1-TXR to 12.47 kV Substation 1 Power Distribution Center SUB1-PDC. The Transformer SUB1-TXR is dual rated primary (12.47 kV and 25 kV) due to the BC Hydro upgrade program to convert 12.47 kV circuits to 25 kV circuits for future expansion of the utility system. BC Hydro is paying the incremental cost difference for the 12.47/25 kV primary of the transformer. In this study, the voltage level of 12.47 kV is considered. SUB1-PDC houses circuit breakers for existing Power Distribution Center SUB1-PDC1A and new Power Transformers BB-ESB1-TXR1 and BB-ESB2-TXR1 that distribute power further to the low voltage Motor Control Centers (MCCs) BB-ESB1-MCC and BB-ESB2-MCC.

Details of Substation Transformer SUB1-TXR are provided below:

Voltage	12.47 kV to 12.47 kV
Power	5 MVA KNAN
Percent Impedance	8.00 %
Winding Connection	Delta-Wye Connected (15A High Resistance Grounded)
Primary Winding Tap Setting	0 %

Ground fault protection at the 12.47 kV level downstream of SUB1-TXR is performed by a ground fault relay and a 15 A, 10 second NGR located at the secondary of the substation transformer. Ground fault current in the system is limited to 15 A and is quickly interrupted by the ground fault relay and upstream SUB1 Breaker before it reaches the NGR design limit of 10 seconds. A 15 A NGR prevents arc flash events due to ground fault currents.

Power Transformers BB-ESB1-TXR1 and BB-ESB2-TXR1 further distribute power to low voltage MCCs BB-ESB1-MCC and BB-ESB2-MCC and have following details:

Voltage	12.47 kV to 600 V
Power	2 MVA KNAN
Percent Impedance	6.00 %
Winding Connection	Delta-Wye Connected (Solidly Grounded)
Primary Winding Tap Setting	0 %

Each of the 600 V MCCs (BB-ESB1-MCC and BB-ESB2-MCC) has the capability to be fed from an emergency generator via an Automatic Transfer Switch (ATS). During outages on the utility line, a limited amount of essential loads are powered by the emergency generators. Therefore, an alternate scenario was considered for this study.

Each low voltage 600 V MCC is fed from a solidly grounded transformer. Ground faults are cleared by breakers on instantaneous trip. As a worst case scenario, tripping of the breakers is tested against the arcing current, which is substantially lower than the bolted fault current. This approach ensures that any arcing currents that may develop in the 600 V system are quickly cleared by the instantaneous trip of the breakers.

The study evaluated two operation scenarios for the Substation 1 for two existing 500 HP jet fuel pumps fed from a 5 kV switchgear. As one of these motors is the complete backup for the other motor, one motor is considered to be running in the first scenario. Therefore, the following scenarios were considered:

- Only one (1) jet fuel pump is running.
- None of jet fuel pumps are running.

#### 1.3.2 New Substation 2 (BB-SUB2) Equipment

Refer to single line drawings in Appendix 4.

From 12.47 kV Substation BB-SUB2, power is distributed through the main incoming breaker SUB2 Breaker and Power Transformer SUB2-TXR to the 4.16 kV Substation 2, Power Distribution Center SUB2-PDC1. The Transformer SUB2-TXR is dual rated primary (12.47 kV and 25 kV) due to the BC Hydro upgrade program to convert 12.47 kV circuits to 25 kV circuits for future expansion of the utility system. BC Hydro is paying the incremental cost difference for the 12.47/25 kV primary of the transformer. In this study, the voltage level of 12.47 kV is considered. SUB2-PDC1 houses circuit breakers for existing Distribution Transformers LC3-TXR1 and LC4-TXR1 to existing MCCs LC3-MCC and LC4-MCC and new Power Transformers BB-ESB3-TXR1, BB-ESB4-TXR1, and BB-ESB5-TXR1 that distribute power further to low voltage MCCs BB-ESB3-MCC, BB-ESB4-MCC, and BB-ESB5-MCC.

Details of Substation Transformer SUB2-TXR are provided below:

Voltage	12.47 kV to 4160 V
Power	1.5 MVA KNAN
Percent Impedance	8.00 %
Winding Connection	Delta-Wye Connected (15A High Resistance Grounded)
Primary Winding Tap Setting	0 %

Ground fault protection at the 4.16 kV level is performed by a ground fault relay and a 15 A, 10 second NGR located at the secondary of the substation transformer. Ground fault current in the system is limited to 15 A and is quickly interrupted by the ground fault relay and upstream SUB2 Breaker before it reaches the NGR design limit of 10 seconds. A 15 A NGR prevents arc flash events due to ground fault currents.

Power Transformers BB-ESB3-TXR1 and BB-ESB5-TXR2 further distribute power to low voltage MCCs BB-ESB3-MCC and BB-ESB5-MCC and have following details:

Voltage	4160 V to 600 V
Power	500 kVA KNAN
Percent Impedance	5.00 %
Winding Connection	Delta-Wye Connected (Solidly Grounded)
Primary Winding Tap Setting	0 %

Power Transformer BB-ESB4-TXR2 further distributes power to low voltage MCC BB-ESB4-MCC and has following details:

Voltage	4160 V to 600 V
Power	100 kVA KNAN
Percent Impedance	5.00 %
Winding Connection	Delta-Wye Connected (Solidly Grounded)
Primary Winding Tap Setting	0 %

Each 600 V MCCs (BB-ESB3-MCC, BB-ESB4-MCC, and BB-ESB5-MCC) have the capability to be fed from an emergency generator via an ATS. During outages on the utility line, a limited amount of essential loads are powered by the emergency generators. Therefore, an alternate scenario was considered for this study.

Each low voltage 600 V MCC is fed from a solidly grounded transformer. Ground faults are cleared by breakers on instantaneous trip. As a worst case scenario, tripping of the breakers is tested against arcing current, which is substantially lower than the bolted fault current. This approach ensures that any arcing currents that may develop in the 600 V system are quickly cleared by the instantaneous trip of the breakers.

#### 2.0 SHORT CIRCUIT STUDY

#### 2.1 Purpose

The purpose of the Short Circuit Analysis is to evaluate the short circuit current available from potential bolted faults at power equipment with a rated voltage of 480 V and above (three-phase systems). Each bus and circuit-interrupting device is evaluated versus the fault current present in the event of an electrical fault. The results were analyzed and any hardware not operating within its rated tolerances were identified. Within SKM, the A\_Fault module handles all calculations related to short circuit calculations.

SKM calculates the short circuit level using the Institute of Electrical and Electronics Engineers (IEEE) Std. 141-1993 method. The main overall purpose of this study is to calculate the short circuit to determine the ratings of the load buses, fuses, isolation switches, and circuit breakers on-site.

#### 2.2 The A\_Fault Program

Fault levels are determined based on the method defined in the IEEE Red Book (IEEE Std. 141-1993).

The circuit data entered into the software model includes fault contributions, cable impedances, and transformer data. Based on this information, the following data is calculated:

- The ANSI Asymmetrical Momentary RMS duty for all high and medium voltage buses
- The ANSI Symmetrical RMS duty for all buses

Two fault levels are calculated using the IEEE Std. 141-1993 method. The momentary fault level is determined from the first cycle of the fault and the interrupting duty is determined at the point in time when the fault clearing device opens during the fault.

#### 2.3 Fault Contributions

There are three types of fault contributions: local utility, local generators, and induction / synchronous motors.

#### 2.3.1 Utility Fault Contributions

BC Hydro provided the fault level at the Shellmont and Aubrey lines 12.47 kV utility connections as follows:

#### **Shellmont**

Thevenin impedance (100 MVA base @ 12.47 kV)

- Z1 (pu) = 0.3367 + 1.5658j
- Z0 (pu) = 0.9498 + 3.2272j

#### **Aubrey**

Thevenin impedance (100 MVA base @ 12.47 kV)

- Z1 (pu) = 0.7723 + 1.7921j
- Z0 (pu) = 2.4920 + 3.7547j

#### 2.3.2 Induction Motors

For medium voltage studies, A\_Fault ignores contributions from motors rated at less than 50 HP. The multiplication factors required to determine motor fault current contribution are calculated by A\_Fault when the software is run. Fault calculations are made on the basis of motor size and RPM data per Table 4-1 of IEEE Standard 141-1993, which determines the multiplication factors based on the following motor groupings:

- Motors larger than 250 HP at 3600 RPM and motors larger than 1000 HP at slower speeds
- All other motors 50 HP and larger
- All motors less than 50 HP

The Short Circuit Study for Substation 1 (BB-SUB1) has been performed with two configurations for motors connections to identify the worst case fault duties:

- None of jet fuel pumps are running.
- Only one (1) jet fuel pump is running.

The second configuration results in the highest fault duty at all buses.

The Short Circuit Study for Substation 2 (BB-SUB2) has been performed with only one (1) configuration for motor connections to identify the worst case fault duties.

#### 2.4 Cable Impedances

Cable impedance is determined by the conductor length, size, type (copper or aluminum), and raceway type (magnetic or non-magnetic). SKM has a cable library that covers a number of the most common feeder types.

Cable characteristics were determined from the Burnaby Terminal preliminary design information.

#### 2.5 Transformer Data

The Transformer data for transformers in Substation 1 and 2 is from the preliminary design information. The primary winding tap settings are as shown in section 1.3.

#### 2.5.1 Transformer X/R Ratio

The transformer impedance is expressed as a complex quantity for the SKM Fault Study. Typical X/R ratios are based on Figure 4A-1 of the IEEE Red Book (IEEE Std. 141-1993).

#### 2.6 Low Voltage Fault Duties

The three-phase symmetrical fault duty on each low voltage bus is used to determine the bus bracing for the low voltage switchgear and MCCs. The MCCs and switchgear must be rated at a value greater than the calculated fault currents to withstand the forces on the equipment without permanent damage.

When determining the required interrupting rating for low voltage circuit breakers, IEEE Standard C37.13-2008 (Table 3) recommends that a multiplication factor be applied to determine the required minimum device rating. This multiplying factor is based on the system X/R ratio and is determined by SKM A\_Fault calculations when the software is run.

#### 2.7 Medium Voltage Momentary Duties

Momentary duties occur during the first cycle of a short circuit. This fault level is used to determine the bus bracing requirements of the medium voltage switchgear and the interrupting capacity of fuses.

One method to estimate the Asymmetrical Momentary fault level is to apply a worst case multiplication factor of 1.6 to the calculated symmetrical fault level. This 1.6 factor is used to account for the direct current component of the first cycle fault, which itself is a function of the system X/R ratio.

A\_Fault determines the correct asymmetric multiplication factor based on the calculated X/R ratio according to Section 4.5.4.1 of the IEEE Std. 141-1993. The asymmetric component of the fault decays with time as the contributions from motors, for example, reduces to zero at anywhere from 5 to 30 cycles, whereas the utility contribution remains constant. As breakers require a certain amount of time (some up to 8 cycles) to open their contacts, the fault current that is present at the point when the breaker contacts part, will be lower than the first cycle fault current; this value of the fault current is the interrupting duty.

Medium voltage equipment ratings are governed by ANSI/IEEE Standards C37.010-1999 and C37.5.

#### 2.8 Results

The results of the Fault Study are reproduced on the single line diagrams attached in Appendix 1 for the Substation 1 and Substation 2 equipment, respectively. The highest faults are summarized in the appendices tables and in the sub-sections below. The medium voltage buses have three fault duties recorded on each bus, the Asymmetrical Momentary duty, Symmetrical RMS, and Symmetrical Interrupting duty. Low voltage buses have a single fault duty recorded on each bus (the Symmetrical RMS duty) known as the fault duty.

#### 2.8.1 Substation 1 Medium Voltage Equipment

The 12.47 kV main disconnect switch at SUB1 Breaker is 40 kA rated; therefore, it is properly rated for the fault duty of 4.1 kA.

The fault level at SUB1 Breaker is 2.6 kA Momentary and 3.1 kA Interrupting. The Breaker has a Momentary rating of 26 kA and an Interrupting rating of 16 kA; therefore, the Breaker is properly rated.

The SUB1-PDC1 Bus fault current is 2.6 kA Asymmetrical Momentary. The bus bracing rating is 25 kA; therefore, SUB1-PDC1 is properly selected for this fault current.

The fault level at SUB1-PDC1A Breaker is 2.6 kA momentary and 1.7 kA interrupting. The SUB1-PDC1A breaker has a Momentary rating of 37 kA and an Interrupting rating of 18 kA; therefore, the SUB1-PDC1A breaker is properly rated.

The fault level at Main Service Switchgear is 2.6 kA Asymmetrical Momentary. The bus bracing rating is 25 kA; therefore, the switchgear is properly rated for this fault current.

The Main Service Switchgear utilizes fusing for feeder protection. Feeder fuses SW-A, SW-B, SW-E and SW-F have an Asymmetrical Momentary rating of 22.4 kA with a Momentary fault duty of 2.6 kA and a Symmetrical Interrupting rating of 14 kA with a Symmetrical Interrupting duty of 2 kA; therefore, the fuses are properly rated.

The fault level at the 5 kV switchgear is 3.5 kA Asymmetrical Momentary. The bus bracing rating is 25 kA; therefore, the switchgear is properly rated for this fault current.

The Jet Fuel Pump 1 feeder utilizes fusing for protection. The Jet Fuel Pump 1 feeder fuse has an Asymmetrical Momentary rating of 80 kA with a Momentary fault duty of 3.9 kA and a Symmetrical Interrupting rating of 50 kA with a Symmetrical Interrupting duty of 2.9 kA; therefore, the fuse is properly rated.

The Jet Fuel Pump 2 feeder utilizes fusing for protection. The Jet Fuel Pump 1 feeder fuse has an Asymmetrical Momentary rating of 80 kA with a Momentary fault duty of 3.9 kA and a Symmetrical Interrupting rating of 50 kA with a Symmetrical Interrupting duty of 2.9 kA; therefore, the fuse is properly rated.

The fault level at BB-ESB1-MCC Line Breaker is 2.6 kA Momentary and 1.7 kA Interrupting. The BB-ESB1-MCC Line Breaker has a Momentary rating of 58 kA and an Interrupting rating of 28 kA; therefore, the BB-ESB1-MCC Line Breaker is properly rated.

The fault level at BB-ESB2-MCC Line Breaker is 2.6 kA Momentary and 1.7 kA Interrupting. The BB-ESB2-MCC Line Breaker has a Momentary rating of 58 kA and an Interrupting rating of 28 kA; therefore, the BB-ESB2-MCC Line Breaker is properly rated.

#### 2.8.2 Substation 2 Medium Voltage Equipment

The 12.47 kV main disconnect switch is 40 kA rated; therefore, it is properly rated for the fault duty of 2.5 kA.

The fault level at the SUB2 Breaker is 2.5 kA Momentary and 2.4 kA Interrupting. The Breaker has a Momentary rating of 26 kA and an Interrupting rating of 16 kA; therefore, the Breaker is properly rated.

The SUB2-PDC2 Bus fault current is 2.3 kA Asymmetrical Momentary. The bus bracing rating is 25 kA; therefore, SUB1-PDC1 is properly selected for this fault current.

The fault level at LC3-MCC LINE Breaker is 2.3 kA Momentary and 1.9 kA Interrupting. The LC3-MCC Line Breaker has a Momentary rating of 78 kA and an Interrupting rating of 41 kA; therefore, the LC3-MCC LINE Breaker is properly rated.

The fault level at LC4-MCC Line Breaker is 2.3 kA Momentary and 1.9 kA Interrupting. The LC4-MCC Line Breaker has a Momentary rating of 78 kA and an Interrupting rating of 41 kA; therefore, the LC4-MCC Line Breaker is properly rated.

The fault level at BB-ESB3-MCC Line Breaker is 2.3 kA Momentary and 1.9 kA Interrupting. The BB-ESB3-MCC Line Breaker has a Momentary rating of 78 kA and an Interrupting rating of 41 kA; therefore, THE BB-ESB3-MCC Line Breaker is properly rated.

The fault level at BB-ESB4-MCC Line Breaker is 2.3 kA Momentary and 1.9 kA Interrupting. The BB-ESB4-MCC Line Breaker has a Momentary rating of 78 kA and an Interrupting rating of 41 kA; therefore, the BB-ESB4-MCC Line Breaker is properly rated.

The fault level at BB-ESB5-MCC Line Breaker is 2.3 kA Momentary and 1.9 kA Interrupting. The BB-ESB5-MCC Line Breaker has a Momentary rating of 78 kA and an Interrupting rating of 41 kA; therefore, the BB-ESB5-MCC Line Breaker is properly rated.

#### 2.8.3 Substation 1 Low Voltage Equipment

The 600 V MCCs and 480 V MCCs have a bracing of 42 kA. The maximum fault duty at the low voltage MCC is 23.5 kA. The lowest rated breaker is at 14 kA; however, the fault currents at the 14 kA rated breakers is 9.4 kA. Therefore, the low voltage MCCs and all low voltage breakers at the Burnaby Terminal Substation 1 are properly rated.

There are three (3) ATSs located at the Substation 1 supplied electrical system, all rated for 30 kA. The highest fault current at these ATSs is 23.5 kA and therefore all three ATSs are adequately rated for the fault currents.

#### 2.8.4 Substation 2 Low Voltage Equipment

The 600 V MCCs and 480 V MCCs have a bracing of 42 kA. The maximum fault duty at the low voltage MCC is 7.9 kA. The lowest rated breaker is at 14 kA; however, the fault current at the 14 kA rated breakers is 9.4 kA. Therefore, the low voltage MCCs and all low voltage breakers at the Burnaby Terminal Substation 2 are properly rated.

There are five (5) ATSs at the Substation 2 supplied electrical system, all rated for 30 kA. The highest fault current at these ATSs is 7.9 kA and therefore all five ATSs are adequately rated for the fault currents.

#### 3.0 ARC FLASH AND PROTECTION COORDINATION STUDY

#### 3.1 Purpose

The purpose of the Arc Flash and Protection Coordination Study is to determine the incident energy during an arcing fault at power equipment with a rated voltage of 480 V and above (three-phase systems).

#### 3.2 Arc Flash Overview

At each bus, the arc flash energy is calculated per the CSA Z462 standard. Recommendations of arc flash hazard reduction are presented where appropriate. The arc flash results are valid for a worker who is exposed to live electrical parts and when a worker is operating live electrical components, even if the doors are closed.

An arcing fault occurs when a fault current passes through the air between conductors in equipment. Arc flash incidents can result in serious injury and/or death due to the intense effects of the arcing. Use of appropriate PPE can help to reduce the severity of injury to a worker exposed to an arc flash.

The following steps were taken in this Arc Flash Study:

- Identified all three-phase buses of 480 V and higher.
- Collected equipment data including relay settings, breaker settings, fuse types, and sizes.
- Entered data into the SKM software.
- Performed an ANSI Short Circuit Analysis to calculate bolted three-phase current for each bus including branch contributions.
- Calculated the arc current for each bus using IEEE 1584 calculations.
- Analyzed the Arc Flash Evaluation Report generated by SKM.
- Provided recommendations to reduce arc flash hazard (if applicable).

The IEEE 1584 standard provides a detailed procedure to determine the energy to which a worker may be exposed.

#### 3.3 SKM PTW Arc Flash Software Configurations

The following SKM PTW software configurations were made when conducting the Arc Flash and Protection Coordination Study:

- From the faulted bus outwards, the SKM software searches for connected protective devices, excluding ground fault devices. The study options are set to check upstream devices for miscoordination to replicate the true system configuration as accurately as possible. The fault is then cleared in sequence based on the protective device TCC trip curve. This process repeats until all branches contributing to the fault are cleared in correct sequence, as required.
- The protective device that clears the fault in the shortest time period of time is used in the arc
  flash calculation.
- The working distance remains constant.
- Induction motors contribute to the arcing current until removed after five cycles.
- The current-limiting range is assumed to start when the fuse clearing curve drops below 0.01 seconds when the current-limiting fuses are utilized.
- The interrupting device is rated for the available short circuit current. This assumption is confirmed by the Short Circuit Analysis.
- Motor overload devices are not included.
- The worst case incident energy is reported in the results table and single line diagrams.
- The maximum Fault Clearing Time (FCT) was set to 2 seconds. This applies where a
  protective device is not able or not available to clear the arcing fault at a bus, in accordance
  with IEEE 1584 recommendations.

#### 3.4 Arc Flash Evaluation Report

The results of the study are summarized in Appendix 2 and 3. Terms used in the Arc Flash Evaluation Report are defined in Table 3.

**Table 3: Arc Flash SKM Report Definitions** 

Terms	Definitions
Bus Name	Location of fault in the power system.
Protective Device Name	ID of protective device that clears the arcing fault current.
Bus Voltage (kV)	Bus voltage in kilovolts at the source of the fault.
Bus Bolted Fault (kA)	The available current in kiloamperes that can flow between two connected points with no impedance between them.
Protective Device Bolted Fault (kA)	The bolted fault current in kiloamperes that flows through the protective device clearing the fault.
Protective Device Arcing Fault (kA)	The available arcing current in kiloamperes that flows through the protective device clearing the arc fault.

Terms	Definitions
Trip / Delay Time	Total time delay required for a protective device to clear the fault current.
Breaker Opening Time	The amount of time for breakers to fully open upon initiation of an opening sequence. This time is normally measured in cycles to open.
Equipment Type	The IEEE 1584 standard defines different types of equipment when setting up an arc flash analysis. This is important because it sets the default physical characteristics of the equipment such as bus gaps and working distance.
Gap (mm)	The space between bus bars or conductors in equipment.
Ground (Y/N)	Defines the system grounding configuration. Where high resistance grounded systems are used, they are considered ungrounded.
Arc Flash Boundary	The minimum distance from exposed live parts within which a worker could receive a second degree burn during an arc flash event.
Working Distance	The distance between the arc source and the worker's face or chest. Typical working distances are specified per the IEEE 1584 standard.

#### 3.5 Arc Flash Evaluation Interpretation

The PPE required to prevent an incurable burn at the working distance during an arcing fault is to be selected based on calculated incident energy in accordance with CSA Z462-15.

Incident energy levels above 12 cal/cm² require the use of a full arc rated suit. An arc flash suit is restrictive, hot, bulky, and difficult to work in, which increases the chance that a tool will be dropped or accidental contact will be made with live conductors, which may trigger an arc flash event. Recommendations to reduce incident energy levels are provided where the incident energy is greater than 12 cal/cm²; however, it is not always possible to achieve the desired incident energy levels due to equipment limitations and coordination requirements.

Incident energy levels above 40 cal/cm<sup>2</sup> represent a significant hazard and no PPE is available that can provide protection from such high incident energy levels. Greater emphasis should be put on ensuring that the equipment is de-energized and in an electrically safe condition prior to performing any work on this equipment.

This study has been conducted based on the current utility fault level and system configuration. Any change (increase or decrease) of the utility fault level or a change to the system configuration, protective device settings, or rating may increase the arc flash incident energy for each bus.

Arc flash studies typically evaluate the use of a maintenance mode switch as an efficient way to reduce high arc flash levels. Most of the time, the maintenance mode selector switch is in the "In Service" position. In this mode, the switch sends a signal to the relays to use one group of settings, which provides selective relay coordination where the downstream breakers would trip first and only a small part of the facility would lose power under the fault condition. The "Maintenance" position of the selector switch activates another group of the relay settings, which would trip the breaker in the shortest possible time to reduce the amount of the released arc flash energy. "Maintenance Mode" is active only for a short period of time while the energized equipment is accessed by maintenance personnel. While the relays are in "Maintenance Mode", good relay coordination is compromised for safety of the maintenance personnel.

#### 3.6 Basis for Modeling

The plant's power system is modeled based on the following:

- The station is in its normal operating configuration.
- The loads are configured to replicate approximate typical loading at the site.
- The worker remains stationary during the arc flash incident and the working distance remains constant.
- When no protective device is found, the FCT will be set at 2 seconds.

#### 3.7 Criteria for Protective Device Coordination

The purpose of coordination is to isolate faults selectively in the shortest time with minimal system shutdown. All protective devices between the load and the source of power must be set and sized to coordinate with each other to ensure that only the faulted area is disconnected from the circuit. Due to limitations of the protective devices, miscoordination can occur; however, miscoordination must be minimized without compromising equipment protection. The minimum CTI used for the protective device coordination analysis is based on IEEE Std. 242 Table 15-3.

This section of the study is to be interpreted in conjunction with the arc flash analysis. When possible, device coordination will be adjusted to reduce hazardous arc flash levels.

#### 3.8 Results

Refer to Appendix 2 for protection coordination curves, relay, breakers, and fuse settings. Recommendations for improvement are included where appropriate in the appendices.

For the purpose of the Protection Coordination Study, Substation 1 and Substation 2 equipment is divided into branches. These branches were chosen to provide a view of the device coordination directly from the main distribution bus down to the end of the line loads. These branches effectively cover the entire scope of the plant, excluding ground fault protection at the low voltage equipment.

#### 3.8.1 Substation 1 Study Results

The arc flash results for all scenarios are summarized in Appendix 2. The GE Multilin 850 Feeder Protection Relays on the BB-ESB1-MCC, BB-ESB2-MCC, and SUB1-PDC1A utilize dual settings groups. Group 1 settings are used for "Maintenance Mode" and Group 2 settings are used for "In Service Mode". The highest arc flash incident energy at any specific MCC and bus is summarized in Appendix 2 and outlined in the sub-sections below.

#### 3.8.1.1 Branch #1 – BB-SUB1 to BB-ESB1-MCC Bus (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at the utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the BB-ESB1 Transformer are elevated.

Arc Flash Incident Energy	32 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.36 m

Arc flash levels at the BB-ESB1-MCC Line Side are elevated.

Arc Flash Incident Energy	35 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.55 m

Arc flash levels at the BB-ESB1-MCC are elevated.

Arc Flash Incident Energy	35 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.55 m

#### **Arc Flash and Coordination Analysis**

Refer to Branch #1- BB-ESB1-MCC IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service" mode relay settings at BB-ESB1-MCC Line Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second.

Arc flash levels are elevated at the BB-ESB1-MCC and BB-ESB1 Transformer. Work can be performed on the switchgear and transformer when "Maintenance Mode" settings are used at the BB-ESB1-MCC Line Feeder Relay.

The barrier between the BB-ESB1-MCC Main Breaker Line Side and the rest of the MCC is incomplete. In the case of an arc flash in the BB-ESB1-MCC Main Breaker enclosure, the same arc flash incident energy can propagate to the rest of the cells. Therefore, the maximum incident energy that can occur is reported.

Faults at the BB-ESB1-MCC loads, such as BB-ESB1-VFD11 at approximately 21.3 kA, are high enough to result in the BB-ESB1-MCC Main Breaker tripping due to miscoordination. The BB-ESB1-MCC Main Breaker is properly coordinated with the upstream BB-ESB1-MCC Line Feeder Relay.

The discrimination time at approximately 15.8 kA arcing fault is ~0.4 seconds between the BB-ESB1-MCC Main Breaker and the BB-ESB1-MCC Line Feeder Relay. BB-ESB1-MCC Line Feeder Relay and the SUB1 Feeder Relay are coordinated. The discrimination time at approximately 1.8 kA arcing fault at SUB1-PDC1 is ~0.2 seconds between the BB-ESB1-MCC Line Feeder Relay and the SUB1 Feeder Relay.

#### 3.8.1.2 Branch #2 – BB-SUB1 to BB-ESB2-MCC (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the BB-ESB2 Transformer are elevated.

Arc Flash Incident Energy	32 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.4 m

Arc flash levels at the BB-ESB2-MCC Line Side are elevated.

Arc Flash Incident Energy	35 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.59 m

Arc flash levels at the BB-ESB2-MCC are elevated.

Arc Flash Incident Energy	35 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.59 m

#### **Arc Flash and Coordination Analysis**

Refer to Branch #2 – BB-ESB2-MCC IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service Mode" relay settings at BB-ESB2-MCC Line Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second.

Arc flash levels are elevated at the BB-ESB2-MCC and BB-ESB2 Transformer. Work can be performed on these switchgear and transformer when "Maintenance Mode" settings are used at the BB-ESB2-MCC Line Feeder Relay.

The barrier between the BB-ESB2-MCC Main Breaker Line Side and the rest of the MCC is incomplete. In the case of an arc flash in the BB-ESB2-MCC Main Breaker enclosure, the same arc flash incident energy can propagate to the rest of the cells. Therefore, the maximum incident energy that can occur is reported.

Faults at the BB-ESB2-MCC loads such as BB-ESB2-VFD12 at approximately 22.3 kA are high enough to result in the BB-ESB2-MCC Main Breaker tripping due to miscoordination. The BB-ESB2-MCC Main Breaker is properly coordinated with the upstream BB-ESB2-MCC Line Feeder Relay. The discrimination time at approximately 16.4 kA arcing fault is ~.036 seconds between the BB-ESB2-MCC Main Breaker and the BB-ESB2-MCC Line Feeder Relay. BB-ESB2-MCC Line Feeder Relay and the SUB1 Feeder Relay are coordinated. The discrimination time at approximately 1.8 kA arcing fault is ~0.2 seconds between the BB-ESB2-MCC Line Feeder Relay and the SUB1 Feeder Relay.

#### 3.8.1.3 Branch #3 – BB-SUB1 to MCC-AX Bus (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the Main Service Switchgear are within a workable range.

Arc Flash Incident Energy	0.53 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.40 m

Arc flash levels at the TX-A Transformer are elevated.

Arc Flash Incident Energy	35.96 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.62 m

Arc flash levels at the MCC- A Main Breaker Line Side are elevated.

Arc Flash Incident Energy	39 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.82 m

#### Arc flash levels at MCC-A are elevated.

Arc Flash Incident Energy	39 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.82 m

Arc flash levels at MCC- AX are within a workable range.

Arc Flash Incident Energy	0.39 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.23 m

Arc flash levels at the CDP Panel BX are within a workable range.

Arc Flash Incident Energy	0.32 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.20 m

#### **Arc Flash and Coordination Analysis**

Refer to Branch #3-MCC-AX IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service" mode relay settings at SUB1-PDC1A Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second.

Arc flash levels are within workable range at the Main Service Switchgear, MCC AX, and CDP Panel BX. However, the arc flash level at the MCC-A and TX-A Transformer is elevated. Work can be performed on the switchgear and transformer when "Maintenance Mode" settings are used at the SUB1-PDC1A Feeder Relay.

The barrier between the MCC-A Main Breaker Line Side and the rest of the MCC is incomplete. In the case of an arc flash in the MCC-A Main Breaker enclosure, the same arc flash incident energy can propagate to the rest of the cells. Therefore, the maximum incident energy that can occur is reported.

Faults at the CDP Panel BX loads such as Panel PDP#1 at approximately 6.7 kA are high enough to result in the existing CDP BX breaker tripping due to miscoordination. Also, faults at existing MCC-AX at approximately 11 kA are high enough to result in the existing ATS feeder breaker tripping due to miscoordination. The SW-A disconnect fuse is also miscoordinated with the MCC-A Main Breaker due the high fault currents at approximately 12.6 kA. The SUB1-PDC1A relay is properly coordinated with the SUB1 Feeder Relay. The discrimination time at approximately 1.8 kA arcing fault is ~0.4 seconds between the SUB1-PDC1A relay and the SUB1 Feeder Relay.

3.8.1.4 Branch #4 – BB-SUB1 to MCC-B Bus (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the Main Service Switchgear are within a workable range.

Arc Flash Incident Energy	0.53 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.40 m

Arc flash levels at the TX-B Transformer are elevated.

Arc Flash Incident Energy	35.79 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.61 m

Arc flash levels at the MCC- B Main Breaker Line Side are elevated.

Arc Flash Incident Energy	39 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.8 m

Arc flash levels at MCC-B are elevated.

Arc Flash Incident Energy	39 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	3.8 m

#### **Arc Flash and Coordination Analysis**

Refer to Branch #4 – MCC – B IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service Mode" relay settings at the SUB1-PDC1A Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second.

Arc flash levels are within workable range at the Main Service Switchgear. The arc flash level at MCC-B and Transformer TX-B is elevated. Work can be performed on the switchgear and transformer when "Maintenance Mode" settings are used at the SUB1-PDC1A Feeder Relay.

The barrier between the MCC-B Main Breaker Line Side and the rest of the MCC is incomplete. In the case of an arc flash in the MCC-B Main Breaker enclosure, the same arc flash incident energy can propagate to the rest of the cells. Therefore, the maximum incident energy that can occur is reported.

Faults at the MCC-B loads such as Panel Pump #4 at approximately 12.5 kA are high enough to result in the existing MCC-B Main Breaker tripping due to miscoordination. The existing SW-B disconnect fuse is coordinated with MCC-B Main Breaker and the discrimination time is about 0.2 seconds. The SUB1-PDC1A relay is properly coordinated with the SUB1 Feeder Relay. The discrimination time at approximately 1.8 kA arcing fault is ~0.4 seconds between the SUB1-PDC1A relay and the SUB1 Feeder Relay.

#### 3.8.1.5 Branch #5 – BB-SUB1 to MCC-E (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within workable range.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the Main Service Switchgear are within a workable range.

Arc Flash Incident Energy	0.53 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.40 m

Arc flash levels at the TX-E Transformer are elevated.

Arc Flash Incident Energy	16.71 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	2.27 m

Arc flash levels at the MCC- E Main Breaker Line Side are elevated.

Arc Flash Incident Energy	18 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	2.36 m

Arc flash levels at MCC- E are elevated.

Arc Flash Incident Energy	18 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	2.36 m

Arc flash levels at the PLM Shop MCC are within workable range.

Arc Flash Incident Energy	0.3 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.20 m

#### **Arc Flash and Coordination Analysis**

Refer to Branch #5 – MCC-E IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service Mode" relay settings at the SUB1-PDC1A Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. Also, arc flash levels are within workable range at the Main Service Switchgear and PLM Shop MCC. However, the arc flash level at the MCC-E and TX-E Transformer is elevated. Work can be performed on the switchgear and transformer when "Maintenance Mode" settings are used at the SUB1-PDC1A Feeder Relay.

The barrier between the MCC-E Main Breaker Line Side and the rest of the MCC is incomplete. In the case of an arc flash in the MCC-E Main Breaker enclosure, the same arc flash incident energy can propagate to the rest of the cells. Therefore, the maximum incident energy that can occur is reported.

Faults at the PLM Shop MCC loads such as the Air Compressor at approximately 7.7 kA are high enough to result in the existing PLM Shop Breaker and MCC-E Main Breaker tripping due to miscoordination. The existing MCC-E Main Breaker and upstream Fuse Disconnect SW-E are coordinated and the discrimination time is ~0.2 seconds. The SUB1-PDC1A relay is properly coordinated with the SUB1 Feeder Relay. SUB1-PDC1A relay and the SUB1 Feeder Relay are miscoordinated. The discrimination time at approximately 1.8 kA arcing fault is ~0.4 seconds between the SUB1-PDC1A relay and the SUB1 Feeder Relay.

3.8.1.6 Branch #6 – SUB1 to 5 kV Switchgear (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the Main Service Switchgear are within a workable range.

Arc Flash Incident Energy	0.53 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.40 m

Arc flash levels at the TX-F Transformer are within a workable range.

Arc Flash Incident Energy	0.67 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.5 m

Arc flash levels at the 5 kV Switchgear are within a workable range.

Arc Flash Incident Energy	0.67 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.5 m

#### **Arc Flash and Coordination Analysis**

Refer to Branch #6-5 kV SWGR IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service Mode" relay settings at the SUB1-PDC1A Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at the Main Service Switchgear, TX-F Transformer, and 5 kV Switchgear.

The JFBP#1 fuse is properly coordinated with the upstream SW-F fuse. The time discrimination time at approximately 2.1 kA arcing fault is ~0.2 seconds between the JFBP#1 fuse and the SW-F fuse. The SW-F Fuse and upstream Relay SUB1-PDC1A are miscoordinated.

The SUB1-PDC1A relay is properly coordinated with the SUB1 Feeder Relay. The discrimination time at approximately 1.8 kA arcing fault is ~0.4 seconds between the SUB1-PDC1A relay and the SUB1 Feeder Relay.

#### 3.8.1.7 Branch #7 – BB-SUB1 to BB-ESB1-MCC Bus (Group 1 Maintenance Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.96 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the BB-ESB1 Transformer are within a workable range.

Arc Flash Incident Energy	5.3 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.13 m

Arc flash levels at the BB-ESB1-MCC Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	4.9 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.08 m

Arc flash levels at BB-ESB1-MCC are within a workable range.

Arc Flash Incident Energy	4.9 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.08 m

#### **Arc Flash and Coordination Analysis**

Refer to Branch #7 – BB-ESB1-MCC MAINT TCC Curve in Appendix 2. This TCC shows protective device coordination when using "Maintenance Mode" relay settings at the BB-ESB1-MCC Line Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also arc flash levels are within a workable range at the BB-ESB1-MCC Main Breaker Line Side and BB-ESB1 Transformer.

Since it is desirable that the faults be cleared as soon as possible in Maintenance Mode and to keep the arc flash levels low at the main buses, the instantaneous settings of BB-ESB1-MCC Line Feeder Protection Relay is enabled. The use of the Maintenance Mode Switch leads to miscoordination of protective devices, which is present only at times when Maintenance Mode is activated.

#### 3.8.1.8 Branch #8 – BB-SUB1 to BB-ESB2-MCC Bus (Group 1 Maintenance Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.96 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the BB-ESB2 Transformer are within a workable range.

Arc Flash Incident Energy	5.5 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.16 m

Arc flash levels at the BB-ESB2-MCC Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	5.1 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.11 m

Arc flash levels at BB-ESB2-MCC are within a workable range.

Arc Flash Incident Energy	5.1 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.11 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #8 – BB-ESB2-MCC MAINT TCC Curve in Appendix 2. This TCC shows protective device coordination when using "Maintenance Mode" relay settings at BB-ESB2-MCC Line Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at the BB-ESB2-MCC Main Breaker Line Side and BB-ESB2 Transformer.

Since it is desirable that the faults be cleared as soon as possible in Maintenance Mode and to keep the arc flash levels low at the main buses, the instantaneous settings of BB-ESB2-MCC Line Feeder Protection Relay is enabled. The use of Maintenance Mode Switch leads to miscoordination of protective devices, which is present only at times when Maintenance Mode is activated.

3.8.1.9 Branch #9 – BB-SUB1 to MCC-AX Bus (Group 1 Maintenance Mode Settings)

### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.96 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the Main Service Switchgear are within a workable range.

Arc Flash Incident Energy	0.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.22 m

Arc flash levels at the TX-A Transformer are within a workable range.

Arc Flash Incident Energy	3.56 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.89 m

Arc flash levels at the MCC-A Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	3.4 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.85 m

Arc flash levels at MCC-A are within a workable range.

Arc Flash Incident Energy	3.4 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.85 m

Arc flash levels at MCC- AX are within a workable range.

Arc Flash Incident Energy	0.40 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.23 m

Arc flash levels at CDP Panel BX are within a workable range.

Arc Flash Incident Energy	0.32 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.20 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #9 – MCC-AX MAINT TCC Curve in Appendix 2. This TCC shows protective device coordination when using "Maintenance Mode" relay settings at SUB1-PDC1A Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at the Main Service Switchgear, MCC AX, CDP Panel BX, and MCC-A Main Breaker Line Side.

Since it is desirable that the faults be cleared as soon as possible in Maintenance Mode and to keep the arc flash levels low at the main buses, the instantaneous settings of SUB1-PDC1A Line Feeder Protection Relay is enabled. The use of the Maintenance Mode Switch leads to miscoordination of protective devices, which is present only at times when Maintenance Mode is activated.

## 3.8.1.10 Branch #10 – BB-SUB1 to MCC-B Bus (Group 1 Maintenance Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.96 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the TX-B Transformer are within a workable range.

Arc Flash Incident Energy	3.38 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.86 m

Arc flash levels at the Main Service Switchgear are within a workable range.

Arc Flash Incident Energy	0.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.22 m

Arc flash levels at the MCC-B Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	3.2 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.83 m

Arc flash levels at MCC-B are within a workable range.

Arc Flash Incident Energy	3.2 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.83 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #10 – MCC-B MAINT TCC Curve in Appendix 2. This TCC shows protective device coordination when using "Maintenance Mode" relay settings at SUB1-PDC1A Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at the Main Service Switchgear, MCC-B Main Breaker Line Side, and at MCC-B.

Since it is desirable that the faults be cleared as soon as possible in Maintenance Mode and to keep the arc flash levels low at the main buses, the instantaneous settings of SUB1-PDC1A Line Feeder Protection Relay is enabled. The use of Maintenance Mode Switch leads to miscoordination of protective devices, which is present only at times when Maintenance Mode is activated.

## 3.8.1.11 Branch #11 – BB-SUB1 to MCC-E (Group 1 Maintenance Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.96 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the Main Service Switchgear are within a workable range.

Arc Flash Incident Energy	0.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.22 m

Arc flash levels at the TX-E Transformer are within a workable range.

Arc Flash Incident Energy	2.05 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.63 m

Arc flash levels at the MCC-E Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	1.9 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.61 m

Arc flash levels at MCC-E are within a workable range.

Arc Flash Incident Energy	1.9 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.61 m

Arc flash levels at PLM Shop MCC are within workable range.

Arc Flash Incident Energy	0.3 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.19 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #11-MCC-E MAINT TCC Curve in Appendix 2. This TCC shows protective device coordination when using "Maintenance Mode" relay settings at SUB1-PDC1A Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at the Main Service Switchgear, PLM Shop MCC, MCC-E Main Breaker Line Side, and at MCC-E.

Since it is desirable that the faults be cleared as soon as possible in Maintenance Mode and to keep the arc flash levels low at the main buses, the instantaneous settings of SUB1-PDC1A Line Feeder Protection Relay is enabled. The use of Maintenance Mode Switch leads to miscoordination of protective devices, which is present only at times when Maintenance Mode is activated.

## 3.8.1.12 Branch #12 – BB-SUB1 to 5 kV Switchgear (Group 1 Maintenance Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB1 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	6.6 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	5.26 m

Arc flash levels at the SUB1 Transformer are within workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.96 m

Arc flash levels at the SUB1-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	2.5 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.98 m

Arc flash levels at the Main Service Switchgear are within a workable range.

Arc Flash Incident Energy	0.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.22 m

Arc flash levels at the TX-F Transformer are within a workable range.

Arc Flash Incident Energy	0.25 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.18 m

Arc flash levels at the 5 kV Switchgear Bus are within a workable range.

Arc Flash Incident Energy	0.25 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	0.18 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #12-5 kV SWGR MAINT TCC Curve in Appendix 2. This TCC shows protective device coordination when using "Maintenance Mode" relay settings at SUB1-PDC1A Feeder Relay.

Arc flash levels are within a workable range at the SUB1 12.5 kV Switch and SUB1-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at the Main Service Switchgear and 5 kV Switchgear.

Since it is desirable that the faults be cleared as soon as possible in Maintenance Mode and to keep the arc flash levels low at other main buses, the instantaneous settings of SUB1-PDC1A Line Feeder Protection Relay is enabled. The use of Maintenance Mode Switch leads to miscoordination of protective devices, which is present only at times when Maintenance Mode is activated.

## 3.8.1.13 Other Buses not included in Branches 1-6 (Group 2 In Service Mode Settings)

All other buses not included in above mentioned Branches 1 to 6, have the arc flash levels within workable range. Refer to the arc flash tables in Appendix 2.

### 3.8.1.14 Branch # 13 SUB1-PDC1 Ground Fault Results

There is no arc flash analysis related to the ground fault relay branch as the three phase calculations provide worst case arc flash values.

### 3.8.1.15 Branch # 14 BB-ESB1-MCC Ground Fault Results

There is no arc flash analysis related to the ground fault relay branch, as the three phase calculations provide worst case arc flash values.

### 3.8.1.16 Branch # 15 BB-ESB2-MCC Ground Fault Results

There is no arc flash analysis related to the ground fault relay branch, as the three phase calculations provide worst case arc flash values.

## 3.8.2 Substation 2 Study Results

The arc flash results for all scenarios are summarized in Appendix 2. The GE Multilin 850 Feeder Protection Relays on Lines BB-ESB3-MCC, BB-ESB4-MCC, BB-ESB5-MCC, MCC LC-3, and MCC LC-4 utilize dual settings groups. Group 1 settings are used for "Maintenance Mode" and Group 2 settings are used for "In Service Mode". The highest arc flash incident energy at any specific MCC and bus is summarized in Appendix 2 and outlined in the sub-sections below.

## 3.8.2.1 Branch #1 – BB-SUB 2 to BB-ESB3A-MCC Bus (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB2 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	5.4 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	4.27 m

Arc flash levels at the SUB2 Transformer are within workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.02 m

Arc flash levels at the SUB2-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.03 m

Arc flash levels at the BB-ESB3-MCC Main Breaker Line Side are elevated.

Arc Flash Incident Energy	13 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.98 m

Arc flash levels at the BB-ESB3-MCC are elevated.

Arc Flash Incident Energy	13 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.98 m

Arc flash levels at the BB-ESB3A-MCC Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	0.3 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.2 m

Arc flash levels at the BB-ESB3A-MCC are within a workable range.

Arc Flash Incident Energy	0.3 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.2 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #1 – BB-ESB3A-MCC IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service Mode" relay settings at BB-ESB3-MCC Line Feeder Relay.

Arc flash levels are within a workable range at the SUB2 12.5 kV Switch and SUB2-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at BB-ESB3-MCC and BB-ESB3A-MCC.

Faults at the BB-ESB3A-MCC loads such as BB-ESB3A-VFD2 at approximately 6.19 kA are high enough to result in the BB-ESB3A-MCC Main Breaker, BB-ESB3A-MCC Line Breaker and ESB3-MCC Main Breaker tripping due to miscoordination. The BB-ESB3-MCC Line Relay is properly coordinated with the SUB2 Feeder Relay but it is miscoordinated with the SUB2 Xmer Primary Relay. The discrimination time at approximately 1.9 kA arcing fault is ~3.1 seconds between the BB-ESB3-MCC Line Relay and the SUB2 Feeder Relay.

3.8.2.2 Branch #2 – SUB 2 to BB-ESB4-MCC Bus (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Refer to Appendix 2 for the arc flash results.

Arc flash levels at the SUB2 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	5.4 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	4.27 m

Arc flash levels at the SUB2 Transformer are within workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.02 m

Arc flash levels at the SUB2-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.03 m

Arc flash levels at the BB-ESB4-MCC Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	5.5 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.15 m

Arc flash levels at the BB-ESB4-MCC are within a workable range.

Arc Flash Incident Energy	5.5 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.15 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #2 – BB-ESB4-MCC IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service Mode" relay settings at BB-ESB4-MCC Line Feeder Relay.

Arc flash levels are within a workable range at the SUB2 12.5 kV Switch and SUB2-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at the BB-ESB4-MCC.

The BB-ESB4-MCC Main Breaker is properly coordinated with the BB-ESB4-MCC Line Relay. The discrimination time at approximately 1.4 kA arcing fault is ~1 seconds between the BB-ESB4-MCC Main Breaker and the BB-ESB4-MCC Line Relay.

The BB-ESB4-MCC Line Relay is properly coordinated with the SUB2 Feeder. The discrimination time at approximately 1.9 kA arcing fault is ~4 seconds between the BB-ESB4-MCC Line Relay and the SUB2 Feeder Relay.

## 3.8.2.3 Branch #3 – BB-SUB 2 to BB-ESB5C-MCC (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB2 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	5.4 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	4.27 m

Arc flash levels at the SUB2 Transformer are within a workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.02 m

Arc flash levels at the SUB2-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.03 m

Arc flash levels at the BB-ESB5-MCC Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	7.8 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.43 m

Arc flash levels at BB-ESB5-MCC are within a workable range.

Arc Flash Incident Energy	7.8 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.43 m

Arc flash levels at the BB-ESB5C-MCC Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	0.18 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.14 m

Arc flash levels at BB-ESB5C-MCC are within a workable range.

Arc Flash Incident Energy	0.18 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.14 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #3 – BB-ESB5C-MCC IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service Mode" relay settings at BB-ESB5-MCC Line Feeder Relay.

Arc flash levels are within a workable range at the SUB2 12.5 kV Switch and SUB2-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at the BB-ESB5C-MCC and BB-ESB5-MCC.

Faults at the BB-ESB5C-MCC loads such as BB-ESB5A-VFD1 at approximately 5.5 kA are high enough to result in the BB-ESB5C-MCC Main Breaker, ESB5C-MCC Line Breaker and ESB5-MCC Main Breaker tripping due to miscoordination. The BB-ESB5-MCC Line Relay is properly coordinated with the SUB2 Feeder Relay. The discrimination time at approximately 1.9 kA arcing fault is ~2.7 seconds between the BB-ESB5-MCC Line Relay and the SUB2 Feeder Relay

## 3.8.2.4 Branch #4 – BB-SUB 2 to BB-LC3A-MCC Bus (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB2 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	5.4 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	4.27 m

Arc flash levels at the SUB2 Transformer are within a workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.02 m

Arc flash levels at the SUB2-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.03 m

Arc flash levels at the T-3 Transformer are within a workable range.

Arc Flash Incident Energy	8.9 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.54 m

Arc flash levels at the MCC LC3 Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	8.9 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.54 m

Arc flash levels at MCC LC-3 are within a workable range.

Arc Flash Incident Energy	8.9 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.55 m

Arc flash levels at the BB-LC3A-MCC Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	0.2 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.15 m

Arc flash levels at BB-LC3A-MCC are within a workable range.

Arc Flash Incident Energy	0.2 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.15 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #4 – BB-LC3A-MCC IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service Mode" relay settings at LC3-MCC Line Feeder Relay.

Arc flash levels are within a workable range at the SUB2 12.5 kV Switch and SUB2-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at BB-LC3A-MCC. The arc flash level at the MCC LC-3 Main Breaker Line Side and T-3 Transformer are within workable range.

Faults at the BB-LC3A-MCC loads such as BB-LC3A-VFD1 at approximately 6.8 kA are high enough to result in the LC3A-MCC Main Breaker tripping due to miscoordination. The upstream MCC-LC-3 Main Breaker and LC3-MCC Line Breaker are also miscoordinated with LC3A-MCC Main Breaker due to the high fault currents at approximately 7.8 kA. The LC3-MCC Line Relay is properly coordinated with the SUB2 Feeder Relay. The discrimination time at approximately 1.9 kA arcing fault is ~3.7 seconds between the LC3-MCC Line Relay and the SUB2 Feeder Relay.

### 3.8.2.5 Branch #5 – SUB 2 to BB-LC4A-MCC Bus (Group 2 In Service Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB2 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	5.4 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	4.27 m

Arc flash levels at the SUB2 Transformer are within a workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.02 m

Arc flash levels at the SUB2-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.03 m

Arc flash levels at the T-4 Transformer are within a workable range.

Arc Flash Incident Energy	9.1 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.57 m

Arc flash levels at the MCC LC4 Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	9.2 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.58 m

Arc flash levels at MCC LC-4 are within a workable range.

Arc Flash Incident Energy	9.2 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	1.58 m

Arc flash levels at the BB-LC4A-MCC Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	0.2 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.15 m

Arc flash levels at BB-LC4A-MCC are within a workable range.

Arc Flash Incident Energy	0.2 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.15 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #5 –BB-LC4A-MCC IN-SVC TCC Curve in Appendix 2. This TCC shows protective device coordination when using "In Service Mode" relay settings at LC4-MCC Line Feeder Relay.

Arc flash levels are within a workable range at the SUB2 12.5 kV Switch and SUB2-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at the BB-LC4A-MCC. The arc flash level at MCC LC-4 Main Breaker Line Side and T-4 Transformer are within workable range.

Faults at the BB-LC4A-MCC loads, such as BB-LC4A-VFD1 at approximately 5.8 kA, are high enough to result in the LC4A-MCC Main Breaker tripping due to miscoordination. The upstream MCC-LC-4 Main Breaker and LC4-MCC Line Breaker are also miscoordinated with the LC4A-MCC Main Breaker due the high fault currents at approximately 7.6 kA. The LC4-MCC Line Relay is properly coordinated with the SUB2 Feeder Relay, but it is miscoordinated with the SUB2 Xmer Primary Relay. The discrimination time at approximately 1.9 kA arcing fault is ~3.7 seconds between the LC4-MCC Line Relay and the SUB2 Feeder Relay.

3.8.2.6 Branch #6 – BB-SUB 2 to BB-ESB3A-MCC Bus (Group 1 Maintenance Mode Settings)

#### **Arc Flash Results**

Arc flash levels at the SUB2 12.5 kV Switch are within a workable range. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV Switch. The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown and not controlled by Trans Mountain, the actual trip time may be longer than 2 seconds.

Arc Flash Incident Energy	5.4 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	4.27 m

Arc flash levels at the SUB2 Transformer are within a workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.02 m

Arc flash levels at the SUB2-PDC1 Bus are within a workable range.

Arc Flash Incident Energy	1.3 cal/cm <sup>2</sup>
Working Distance	0.91 m
Flash Protection Boundary	1.03 m

Arc flash levels at the BB-ESB3-MCC Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	1.7 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.56 m

Arc flash levels at BB-ESB3-MCC are within a workable range.

Arc Flash Incident Energy	1.7 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.56 m

Arc flash levels at the BB-ESB3A-MCC Main Breaker Line Side are within a workable range.

Arc Flash Incident Energy	0.28 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.19 m

Arc flash levels at BB-ESB3A-MCC are within a workable range.

Arc Flash Incident Energy	0.28 cal/cm <sup>2</sup>
Working Distance	0.45 m
Flash Protection Boundary	0.19 m

## **Arc Flash and Coordination Analysis**

Refer to Branch #6 – BB-ESB3A-MCC MAINT TCC Curve in Appendix 2. This TCC shows protective device coordination when using "Maintenance Mode" relay settings at BB-ESB3-MCC Line Feeder Relay.

Arc flash levels are within a workable range at the SUB2 12.5 kV Switch and SUB2-PDC1 Bus. There are no upstream Trans Mountain owned protective devices to clear the fault upstream of the 12.5 kV switch. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 second. Also, arc flash levels are within workable range at BB-ESB3-MCC and BB-ESB3A-MCC.

Since it is desirable that the faults be cleared as soon as possible in Maintenance Mode and to keep the arc flash levels low at the main buses, the instantaneous settings of the BB-ESB3-MCC Line Feeder Protection Relay is enabled. The use of Maintenance Mode Switch leads to miscoordination of protective devices, which is present only at times when Maintenance Mode is activated.

3.8.2.7 Other Buses not included in Branches 1-5 (Group 2 In Service Mode Settings)

All other buses not included in the above mentioned Branches 1 to 5 have the arc flash levels within workable Range. Refer to arc flash tables in Appendix 2.

#### 3.8.2.8 Branch # 7 SUB2-PDC1 Ground Fault Results

There is no arc flash analysis related to the ground fault relay branch, as the three phase calculations provide worst case arc flash values.

## 4.0 ALTERNATE SCENARIO – EMERGENCY GENERATOR

## 4.1 Introduction

Results and analysis for the emergency generator scenario have been provided for the system. In the event of a loss of utility power, an emergency generator restores power to a limited number of 600 V and 480 V MCCs, but medium voltage loads such as the jet fuel pumps will not run.

There are five (5) Generators at sites. The largest Generator has a 150 kW rating.

## 4.2 Short Circuit Results Summary

All protective devices, 600 V buses and 480 V buses, are adequately rated for the calculated short circuit currents. The detailed tabulated results are provided in Appendix 3.

### 4.3 Arc Flash Results

Arc flash levels at all of the operating buses are below 7 cal/cm<sup>2</sup>, which is an acceptable level.

## 5.0 RECOMMENDATIONS AND RELAY SETTINGS

During the process of the coordination and arc flash study, design improvements were identified. The following recommended design improvements are different then the provided design shown on the single lines in Appendix 4. The study model single lines in Appendix 2 show the recommended design with improved coordination and reduced arc flash levels. The studies were completed assuming the following recommendations have been followed:

- Replace BC Hydro Shellmont 50-100:5 CTs for feeder breaker relay and transformer relay with 150-300:5 CTs.
- Replace zero sequence CTs on Feeder Lines SUB1-PDC1A, BB-ESB1-MCC, BB-ESB2-MCC, MCC-LC3, MCC-LC4, BB-ESB3-MCC, BB-ESB4-MCC, and BB-ESB5-MCC at Substation 1 and 2 with 50/5 CTs.
- A multifunction generator protection relay similar to Multilin 889 is not required for small emergency generators. Low voltage breaker at the generators is adequate for protection.
- 4160 V/600 V and 12470 V/600 V power distribution transformers are recommended to be solidly grounded and ground faults cleared by breakers. As a worst case scenario, tripping of the breakers is calculated against the arcing current, which is substantially lower than the bolted fault current. This approach ensures that any arcing currents, which may be developed in the low voltage system, are quickly cleared by the breakers.
- It is recommended to add new relays and other equipment to improve the low voltage coordination. Details of the design will require another design study to determine a practical solution.

Directional Overcurrent Relay (ANSI Function 67) is used in this project to block the stored energy of running motors from feeding an electrical fault upstream of the motor protection relays. Directional relays are used with overcurrent relays to operate when the fault current is flowing from each 300 HP motor towards the system. For this application, an element characteristic angle of 30° with polarizing voltage threshold of 0.7 was selected. The instantaneous overcurrent pickup of 110 A was selected for the directional relay.

Directional Power Relay (ANSI Function 32) is used in this project to block the stored energy of running motors from feeding an electrical fault upstream of the motor protection relays. For this application, a minimum operating power of 20 % and a relay characteristic angle of 85° was selected.

# 5.1 Substation 1 Relays

The overcurrent protection settings at the Substation 1 equipment are as follows:

SUB 1 Feeder Relay GE Multilin 850 50/51 Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.61

SUB 1 Feeder Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Ground Time Overcurrent Pickup	0.05
Ground Time Overcurrent Curve Type	Definite Time
Ground Time Overcurrent Multiplier	0.5

SUB 1 Transformer Relay GE Multilin 845 50/51 Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Moderately Inverse
Phase Time Overcurrent Multiplier	1.1

SUB 1 Transformer Relay GE Multilin 845 50G/51G Function (Group 1 and 2)	
Ground Time Overcurrent Pickup	4
Ground Time Overcurrent Curve Type	Definite Time
Ground Time Overcurrent Multiplier	0.42

SUB 1-PDC1A Feeder Relay GE Multilin 850 50/51 Function (Group 1)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.32
Phase Instantaneous Pickup	1
Phase Instantaneous Overcurrent Delay	0

SUB 1-PDC1A Feeder Relay GE Multilin 850 50/51 Function (Group 2)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.32

SUB 1-PDC1A Feeder Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	0.05
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.2

BB-ESB1-MCC Line Feeder Relay GE Multilin 850 50/51 Function (Group 1)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.7
Phase Instantaneous Pickup	4
Phase Instantaneous Overcurrent Delay	0

BB-ESB1-MCC Line Feeder Relay GE Multilin 850 50/51 Function (Group 2)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.7

BB-ESB1-MCC Line Feeder Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	0.05
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.2

ESB1-MCC Main Feeder Relay GE Multilin 850 50/51 Function (Group 1 and 2)	
Phase Long Time Pickup	1
Phase Long Time Delay	60
Phase Short Time Pickup	10
Phase Short Time Delay	0.1
Phase Instantaneous Overcurrent Delay	4
Ground Fault Pickup	250 A
Ground Fault Delay	0.2

BB-ESB2-MCC Line Feeder Relay GE Multilin 850 50/51 Function (Group 1)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.7
Phase Instantaneous Pickup	4
Phase Instantaneous Overcurrent Delay	0

BB-ESB2-MCC Line Feeder Relay GE Multilin 850 50/51 Function (Group 2)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.7

BB-ESB2-MCC Line Feeder Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	0.05
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.2

ESB2-MCC Main Feeder Relay GE Multilin 850 50/51 Function (Group 1 and 2)	
Phase Long Time Pickup	1
Phase Long Time Delay	60
Phase Short Time Pickup	10
Phase Short Time Delay	0.1
Phase Instantaneous Overcurrent Delay	4
Ground Fault Pickup	250 A
Ground Fault Delay	0.2

# 5.2 Substation 2 Relays

The overcurrent protection settings at the Substation 2 are as follows:

SUB 2 Feeder Relay GE Multilin 850 50/51 Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.63

SUB 2 Feeder Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Ground Time Overcurrent Pickup	0.05
Ground Time Overcurrent Curve Type	Definite Time
Ground Time Overcurrent Multiplier	0.5

SUB 2 Transformer Relay GE Multilin 845 50/51 Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Moderately Inverse
Phase Time Overcurrent Multiplier	0.12

SUB 2 Transformer Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Ground Time Overcurrent Pickup	4
Ground Time Overcurrent Curve Type	Definite Time
Ground Time Overcurrent Multiplier	0.4

LC-3 MCC Feeder Relay GE Multilin 850 50/51 Function (Group 1)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.49
Phase Instantaneous Pickup	5
Phase Instantaneous Overcurrent Delay	0

LC-3 MCC Feeder Relay GE Multilin 850 50/51 Function (Group 2)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.49

LC-3 MCC Line Feeder Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	0.05
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.2

LC-4 MCC Feeder Relay GE Multilin 850 50/51 Function (Group 1)	
Phase Time Overcurrent Pickup	1
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.5
Phase Instantaneous Pickup	4
Phase Instantaneous Overcurrent Delay	0

LC-4 MCC Feeder Relay GE Multilin 850 50/51 Function (Group 2)	
Phase Time Overcurrent Pickup 1	
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.5

LC-4 MCC Line Feeder Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Phase Time Overcurrent Pickup 0.05	
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier 0.2	

BB-ESB3-MCC Line Feeder Relay GE Multilin 850 50/51 Function (Group 1)		
Phase Time Overcurrent Pickup 1		
Phase Time Overcurrent Curve Type Extremely Inverse		
Phase Time Overcurrent Multiplier	1.01	
Phase Instantaneous Pickup	5	
Phase Instantaneous Overcurrent Delay	0	

BB-ESB3-MCC Line Feeder Relay GE Multilin 850 50/51 Function (Group 2)	
Phase Time Overcurrent Pickup 1	
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	1.01

BB-ESB3-MCC Line Feeder Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	0.05
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.2

BB-ESB4-MCC Line Feeder Relay GE Multilin 850 50/51 Function (Group 1 and 2)	
Phase Time Overcurrent Pickup 1	
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.16

BB-ESB4-MCC Line Feeder Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	0.05
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.2

BB-ESB5-MCC Line Feeder Relay GE Multilin 850 50/51 Function (Group 1)		
Phase Time Overcurrent Pickup 1		
Phase Time Overcurrent Curve Type Extremely Inverse		
Phase Time Overcurrent Multiplier	0.5	
Phase Instantaneous Pickup	4	
Phase Instantaneous Overcurrent Delay	0	

BB-ESB5-MCC Line Feeder Relay GE Multilin 850 50/51 Function (Group 2)	
Phase Time Overcurrent Pickup 1	
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier 0.5	

BB-ESB5-MCC Line Feeder Relay GE Multilin 850 50G/51G Function (Group 1 and 2)	
Phase Time Overcurrent Pickup	0.05
Phase Time Overcurrent Curve Type	Extremely Inverse
Phase Time Overcurrent Multiplier	0.2

## 6.0 CONCLUSION

This Power System Study evaluated the TMEP Burnaby Terminal power distribution system. The future terminal equipment was evaluated for short circuit currents and for arc flash incident energy and protective device coordination. As not all data was available at the time of this analysis, this study will be re-examined once detailed design is complete and all information is available.

All buses at Burnaby Terminal (switchgears and MCCs) were found to be operating within their rated short circuit withstand capability. Additionally, all protective devices were found to be operating within their rated short circuit interrupting capabilities.

The study results are based on a maximum FCT of 2 seconds in accordance with IEEE 1584 recommendation. Since the upstream protective device at utility is unknown, the actual trip time may be longer than 2 seconds.

Arc flash levels at BB-ESB1-MCC and BB-ESB1-TXR1 transformer are elevated during normal operations. The BB-ESB1-MCC Line Feeder Relay is equipped with a Maintenance Mode Switch that must be used to reduce arc flash levels to an acceptable level during maintenance activities at BB-ESB1-MCC or BB-ESB1-TXR1.

Arc flash levels at BB-ESB2-MCC and BB-ESB2-TXR1 transformer are elevated during normal operations. The BB-ESB2-MCC Line Feeder Relay is equipped with a Maintenance Mode Switch that must be used to reduce arc flash levels to an acceptable level during maintenance activities at BB-ESB2-MCC or BB-ESB2-TXR1.

Arc flash levels at MCC-A Line Side are elevated during normal operations. The SUB1-PDC1A Line Feeder Relay is equipped with a Maintenance Mode Switch that must be used to reduce arc flash levels to an acceptable level during maintenance activities at MCC-A.

Arc flash levels at MCC-B are elevated during normal operations. The SUB1-PDC1A Line Feeder Relay is equipped with a Maintenance Mode Switch that must be used to reduce arc flash levels to an acceptable level during maintenance activities at MCC-B.

Arc flash levels at MCC-E are elevated during normal operations. The SUB1-PDC1A Line Feeder Relay is equipped with a Maintenance Mode Switch that must be used to reduce arc flash levels to an acceptable level during maintenance activities at MCC-E.

Arc flash levels at ESB3-MCC are elevated during normal operations. The BB-ESB3-MCC Line Feeder Relay is equipped with a Maintenance Mode Switch that must be used to reduce arc flash levels to an acceptable level during maintenance activities at BB-ESB3-MCC.

All other equipment at Burnaby Terminal have acceptable arc flash levels.

Appendix 1
Short Circuit Analysis



Burnaby Terminal 216239 Rev B - Issued For Review

Table 1B - High Vo	Itage and Medium	Voltage Disconnect Switch
--------------------	------------------	---------------------------

Disconnect Switches	Momentary Rating (kA)	Momentary Fault Duty (kA)	% Capacity Utilized [%]	
SUB1 12.5 kV Switch	40	4.1	10.25	
SUB2 12.5 kV Switch	40	2.5	6.25	

Table 1C - Medium Voltage Bus Rating

	Lineup Bus Bracing	Momentary Fault Duty	% Capacity Utilized	
Bus	(kA)	(kA)	[%]	
SUB1-PDC1	25	2.6	10	
SUB2-PDC1	25	2.3	9	
02-Main Service SWGR	25	2.6	10	
5kV SWGR	25	3.5	14	

Table 1D	- Medium	Voltage	Fuse &	<b>Breaker Rating</b>	

Breaker	Momentary Rating (kA)	Momentary Fault Duty (kA)	Interrupting Rating (kA)	Sym Interrupting Duty (kA)	% Capacity Utilized [%]	Breaker Cycles
SUB 1 Breaker	26	4.1	16	3.1	19	3
SUB 2 Breaker	26	2.5	16	2.4	15	3
SUB1-PDC1A	37	2.6	18	1.7	9	3
BB-ESB1-MCC LINE Bkr	58	2.6	28	1.7	6	3
BB-ESB2-MCC LINE Bkr	58	2.6	28	1.7	6	3
LC3-MCC LINE Bkr	78	2.3	41	1.9	5	3
LC4-MCC LINE Bkr	78	2.3	41	1.9	5	3
BB-ESB3-MCC LINE Bkr	78	2.3	41	1.9	5	3
BB-ESB4-MCC LINE Bkr	78	2.3	41	1.9	5	3
BB-ESB5-MCC LINE Bkr	78	2.3	41	1.9	5	3
SW-A	22.4	2.6	14	2.0	14	n/a
SW-B	22.4	2.6	14	2.0	14	n/a
SW-E	22.4	2.6	14	2.0	14	n/a
SW-F	22.4	2.6	14	2.0	14	n/a
JFBP#1 FU	80	3.9	50	2.9	6	n/a
JFBP#2 FU	80	3.9	50	2.9	6	n/a



Burnaby Terminal 216239 Rev B - Issued For Review

Table 1E - Low Voltage MCC Bus Ratio				
	Lineup Bus Bracing	Fault Duty	% Capacity Utilized	
Bus	(kA)	(kA)	[%]	Notes
BB-ESB1-MCC	42	22.4	53	
BB-ESB2-MCC	42	23.5	56	1
BB-ESB2A-MCC	42	21.2	50	1
MCC-A	42	14.3	34	1
MCC-F	42	10.1	24	1
CDP PANEL A	42	8.1	19	
CDP PANEL SB-A1	42	4.9	12	
MCC-B	42	13.6	32	
MCC-E	42	10	24	1
PLM SHOP MCC	42	8.4	20	
MECH SHOP PANEL	42	8.4	20	1
MCC-EX	42	1.2	3	1
MCC-AX	42	12.6	30	1
DIV. OFFICE BASMENT	42	1.8	4	1
LEVEE BUILDING	42	0.9	2	1
CDP PANEL AX (CTRL RM BLDG)	42	6.4	15	1
CDP PANEL BX	42	7.5	18	1
PDP#1	42	6.7	16	1
PDP#3	42	6.7	16	
PDP#4	42	7.2	17	1
PDP#5	42	7.2	17	1
PDP#6	42	7.6	18	1
MCC-DX	42	6.8	16	1
MCC LC-3	42	7.9	19	1
BB-LC3A-MCC	42	6.9	16	
TK90/88 MCC	42	4.9	12	
TK82 MCC	42	4.8	11	
TK86 MCC	42	3.7	9	
TK72 MCC	42	2.8	7	1
TK74 MCC	42	2.7	6	1
MCC LC-4	42	7.6	18	
BB-LC4A-MCC	42	6.7	16	
TK71 MCC	42	2.9	7	
TK73 MCC	42	2.8	7	
TK81 MCC	42	2.9	7	
TK83 MCC	42	3.9	9	
TK85 MCC	42	6.4	15	
TK87 MCC	42	2.8	7	
BB-ESB3-MCC	42	6.8	16	
BB-ESB3A-MCC	42	6.5	15	



Burnaby Terminal 216239 Rev B - Issued For Review

Table 1E	- Low Voltag	ge MCC Bus	Rating	(Cont.)	
----------	--------------	------------	--------	---------	--

	Lineup Bus Bracing	Fault Duty	% Capacity Utilized	
Bus	(kA)	(kA)	[%]	Notes
BB-ESB3B-MCC	42	6.5	15	
BB-ESB4-MCC	42	1.9	5	
BB-ESB5-MCC	42	6	14	
BB-ESB5A-MCC	42	5.5	13	
BB-ESB5B-MCC	42	5.5	13	
BB-ESB5C-MCC	42	5.5	13	

Table 1F - Low Voltage Breaker & Fuse Rating

	Interrupting Rating	Low Voltage Fault Duty	% Capacity Utilized
Device	(kA)	(kA)	[%]
ATS FDR BK	35	14.3	41
BB-ESB1-GEN Bkr	25	1.3	5
BB-ESB2-GEN Bkr	25	1.3	5
BB-ESB3-GEN Bkr	25	0.4	2
BB-ESB3A-MCC LINE Bkr	35	6.9	20
BB-ESB3A-MCC Main Bkr	35	6.5	19
BB-ESB3B-MCC LINE Bkr	35	6.9	20
BB-ESB3B-MCC Main Bkr	35	6.5	19
BB-ESB4-GEN Bkr	25	0.4	2
BB-ESB5-GEN Bkr	25	0.4	2
BM-74 Bkr	35	5.5	16
BM-75 Bkr	35	5.5	16
BM-76 Bkr	35	5.5	16
BM-77 Bkr	35	5.5	16
BM-78 Bkr	35	6.0	17
BM-79 Bkr	35	5.5	16
BM-80 Bkr	35	6.9	20
BM-91 Bkr	35	6.9	20
BM-93 Bkr	35	6.9	20
BM-96 Bkr	35	6.5	19
BM-97 Bkr	35	6.5	19
BM-98 Bkr	35	6.5	19
BPM-11 Bkr	35	22.4	64
BPM-12 Bkr	35	23.5	67
BPM-21 Bkr	35	22.4	64
BPM-22 Bkr	35	23.5	67
BPM-31 Bkr	35	22.4	64
BPM-31 Bkr1	35	6.7	19
BPM-32 Bkr	35	23.5	67
CDP A FDR BK	25	14.3	57
CDP SB-A1 FDR BK	25	14.3	57



Burnaby Terminal 216239 Rev B - Issued For Review

	Interrupting Rating	Low Voltage Fault Duty	% Capacity Utilized
Device	(kA)	(kA)	[%]
CDP-AX FDR BK	65	12.6	19
CDP-BX FDR BK	65	12.6	19
DIV OFFICE FDR BK	65	12.6	19
ESB1-AHU Bkr	25	22.4	90
ESB1-LP1 Bkr	25	22.4	90
ESB1-MCC MAIN Bkr	65	22.4	34
ESB2-AHU Bkr	25	23.5	94
ESB2-LP1 Bkr	25	23.5	94
ESB2-MCC MAIN Bkr	65	23.5	36
ESB2A-LP1 Bkr	25	21.2	85
ESB2A-MCC LINE Bkr	25	23.5	94
ESB2A-MCC MAIN Bkr	25	21.2	85
ESB3-LP1 Bkr	25	6.9	28
ESB3-MCC MAIN Bkr	25	6.9	28
ESB3A-LP1 Bkr	25	6.5	26
ESB3B Bkr	35	6.5	19
ESB3B-LP1 Bkr	25	6.5	26
ESB4-LP1 Bkr	25	1.9	8
ESB4-MCC MAIN Bkr	35	1.9	5
ESB5-LP1 Bkr	25	6.0	24
ESB5-MCC MAIN Bkr	25	6.0	24
ESB5A-LP1 Bkr	25	5.5	22
ESB5A-MCC LINE Bkr	35	6.0	17
ESB5A-MCC MAIN Bkr	35	5.5	16
ESB5B-LP1 Bkr	25	5.5	22
ESB5B-MCC LINE Bkr	35	6.0	17
ESB5B-MCC MAIN Bkr	35	5.5	16
ESB5C-LP1 Bkr	25	5.5	22
ESB5C-MCC LINE Bkr	35	6.0	17
ESB5C-MCC MAIN Bkr	35	5.5	16
G-LC-3 BK	14	2.6	19
G-LC-4 BK	14	2.6	19
GEN BK	65	1.5	2
.C 71 FDR BK	14	9.2	66
.C 72 FDR BK	14	9.4	67
LC 73 FDR BK	65	8.5	13
LC 74 FDR BK	35	8.8	25
C 81 FDR BK	14	9.2	66
LC 82 FDR BK	14	9.4	67
I C 83 EDB BK	1/1	9.2	66



Burnaby Terminal 216239 Rev B - Issued For Review


Table 1F	- Low Voltage	Breaker &	Fuse Rating	(Cont.)


Table 11 - LOW VOILage Dieaker	Interrupting Rating	Low Voltage Fault Duty	% Capacity Utilized		
Device	(kA)	(kA)	[%]		
LC 84 FDR BK	14	9.4	67		
LC 85 FDR BK	14	9.2	66		
LC 86 FDR BK	14	9.4	67		
LC 87 FDR BK	14	9.2	66		
LC 90/88 FDR BK	35	8.8	25		
LC3A-LP1 Bkr	25	6.9	28		
LC3A-MCC LINE Bkr	65	8.8	14		
LC3A-MCC MAIN Bkr	65	6.9	11		
LC4A-LP1 Bkr	25	6.7	27		
LC4A-MCC LINE Bkr	65	8.5	13		
LC4A-MCC MAIN Bkr	65	6.7	10		
MCC-A MAIN	30	14.3	48		
MCC-B MAIN	30	13.8	46		
MCC-DX FDR BK	25	7.5	30		
MCC-E MAIN	35	10.3	29		
MCC-EX FDR BK	65	12.6	19		
MCC-EX MAIN	65	1.2	2		
MCC-LC-2 MAIN BK	65	0.0	0		
MCC-LC-3 MAIN BK	30	8.9	30		
MCC-LC-4 MAIN BK	30	8.6	29		
MCCF FDR BK	35	14.3	41		
MECH SHOP BKR	100	10.3	10		
PDP1 FDR BK	25	7.5	30		
PDP3/4 FDR BK	25	7.5	30		
PDP5 FDR BK	25	7.5	30		
PDP6 FDR BK	25	7.5	30		
PFC FD BK	14	9.4	67		
PFC-LC4 FD BK	14	9.2	66		
PLM SHOP BKR	100	10.3	10		
TK71 MAIN BK	14	2.9	21		
TK72 MAIN BK	14	2.8	20		
TK73 MAIN BK	65	2.8	4		
TK74 MAIN BK	14	2.7	19		
TK81 MAIN BK	14	2.9	21		
TK82 MAIN BK	14	3.1	22		
TK83 MAIN BK	14	3.9	28		
TK84 MAIN BK	14	4.8	34		
TK85 MAIN BK	14	6.5	46		
TK86 MAIN BK	14	3.7	26		
TK87 MAIN BK	65	2.8	4		
TK90/88 MAIN BK	65	4.9	8		





Burnaby Terminal 216239 Rev B - Issued For Review


Table 1F - Load Interrupt/	Transfer Switch		
Switch	Interrupt Rating (kA)	Duty (kA)	% Capacity Utilized {Interrupting} [%]
ATS-NORM	30	12.2	41
BB-ESB1-TRS	30	23.2	77
BB-ESB2-TRS	30	24.2	81
ATS-LC3	30	7.9	26
ATS-LC4	30	7.6	25
BB-ESB3-TRS	30	6.9	23
BB-ESB4-TRS	30	2	7
BB-ESB5-TRS	30	6.3	21























Project: Burnaby Terminal Kinder Morgan Burnaby Terminal Power System Study

# ANSI Complete Fault Report One of Jet Fuel Pumps is Running

## A\_FAULT Settings

Fault Type	3 Phase+Unbalanced	LV Duty	Yes	Int Duty	Yes
Faulted Bus	All Buses	LV Report	Complete	Int Report	Complete
Include Tap	No	Mom Duty	Yes	<b>Solution Method</b>	E/Z
Pre-fault Voltage	1.0000	Mom Report	Complete	NACD Option	Interpolated

#### Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Fau	It Duty	X/R	Asym	ı kA	Seq	uence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impeda	nce pu	R	+ <i>j</i> X
02-MAIN	12,470	3 Phase:	2.29	49.4	6.59	3.04	2.68	Z1:	2.02	0.52	3.11
SERVICE SWGR		SLG:	0.01	0.2	0.01	0.01		Z2:	2.02		
		LL:	1.98	24.7				Z0:	926.16		
LLG Gnd Return kA:	0.007	LLG:	1.98	24.7							
5KV SWGR	4,160	3 Phase:	2.75	19.8	7.86	3.79	3.29	Z1:	5.05	0.13	0.86
		SLG:	3.02	12.5	7.28	4.10		Z2:	5.05		
		LL:	2.38	9.9				Z0:	3.71		
LLG Gnd Return kA:	3.340	LLG:	2.92	12.1							
BB-ESB1-MCC	600	3 Phase:	23.08	24.0	4.61	28.38	25.80	Z1:	4.17	0.00	0.01
		SLG:	20.44	12.3	2.16	21.52		Z2:	4.17		
		LL:	19.99	12.0				Z0:	6.23		
LLG Gnd Return kA:	17.769	LLG:	24.69	14.8							
BB-ESB1-TXR1	12,470	3 Phase:	2.29	49.4	6.53	3.04	2.68	Z1:	2.02	0.52	3.11
Prim Side		SLG:	0.01	0.2	0.01	0.01		Z2:	2.02		
		LL:	1.98	24.7				Z0:	926.16		
LLG Gnd Return kA:	0.007	LLG:	1.98	24.7							
BB-ESB1-TXR1	600	3 Phase:	24.90	25.9	6.39	32.91	29.05	Z1:	3.87	0.00	0.01
Sec Side		SLG:	26.91	16.1	6.62	35.84		Z2:	3.87		
		LL:	21.56	12.9				Z0:	3.00		
LLG Gnd Return kA:	29.266	LLG:	25.82	15.5							
BB-ESB1-VFD11	600	3 Phase:	22.67	23.6	4.33	27.47	25.13	Z1:	4.25	0.00	0.01
Line Side		SLG:	19.66	11.8	2.01	20.50		Z2:	4.25		
		LL:	19.63	11.8				Z0:	6.70		
LLG Gnd Return kA:	16.775	LLG:	24.15	14.5							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Seq	uence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impedar	nce pu	R	+ <i>j</i> X
BB-ESB1-VFD21	600	3 Phase:	22.67	23.6	4.33	27.47	25.13	Z1:	4.25	0.00	0.01
Line Side		SLG:	19.66	11.8	2.01	20.50		Z2:	4.25		
		LL:	19.63	11.8				Z0:	6.70		
LLG Gnd Return kA:	16.775	LLG:	24.15	14.5							
BB-ESB1-VFD31	600	3 Phase:	22.67	23.6	4.33	27.47	25.13	Z1:	4.25	0.00	0.01
Line Side		SLG:	19.66	11.8	2.01	20.50		Z2:	4.25		
		LL:	19.63	11.8				Z0:	6.70		
LLG Gnd Return kA:	16.775	LLG:	24.15	14.5							
BB-ESB2A	600	3 Phase:	21.92	22.8	3.29	24.96	23.46	Z1:	4.39	0.01	0.01
		SLG:	17.33	10.4	1.51	17.59		Z2:	4.39		
		LL:	18.98	11.4				Z0:	8.49		
LLG Gnd Return kA:	13.821	LLG:	22.73	13.6							
BB-ESB2-MCC	600	3 Phase:	24.16	25.1	4.76	29.92	27.12	Z1:	3.98	0.00	0.01
		SLG:	20.99	12.6	2.14	22.09		Z2:	3.98		
		LL:	20.92	12.6				Z0:	6.23		
LLG Gnd Return kA:	17.969	LLG:	25.70	15.4							
BB-ESB2-TXR1	12,470	3 Phase:	2.29	49.4	6.54	3.04	2.68	Z1:	2.02	0.52	3.11
Prim Side		SLG:	0.01	0.2	0.01	0.01		Z2:	2.02		
		LL:	1.98	24.7				Z0:	926.16		
LLG Gnd Return kA:	0.007	LLG:	1.98	24.7							
BB-ESB2-TXR1	600	3 Phase:	25.82	26.8	6.32	34.06	30.09	Z1:	3.73	0.00	0.01
Sec Side		SLG:	27.62	16.6	6.57	36.74		Z2:	3.73		
		LL:	22.36	13.4				Z0:	3.00		
LLG Gnd Return kA:	29.684	LLG:	26.58	15.9							
BB-ESB2-VFD12	600	3 Phase:	23.70	24.6	4.45	28.90	26.37	Z1:	4.06	0.00	0.01
Line Side		SLG:	20.17	12.1	1.99	21.01		Z2:	4.06		
		LL:	20.53	12.3				Z0:	6.70		
LLG Gnd Return kA:	16.951	LLG:	25.11	15.1							
BB-ESB2-VFD22	600	3 Phase:	23.70	24.6	4.45	28.90	26.37	Z1:	4.06	0.00	0.01
Line Side		SLG:	20.17	12.1	1.99	21.01		Z2:	4.06		
		LL:	20.53	12.3				Z0:	6.70		
LLG Gnd Return kA:	16.951	LLG:	25.11	15.1							
BB-ESB2-VFD32	600	3 Phase:	23.70	24.6	4.45	28.90	26.37	Z1:	4.06	0.00	0.01
Line Side		SLG:	20.17	12.1	1.99	21.01		Z2:	4.06		
		LL:	20.53	12.3				Z0:	6.70		
LLG Gnd Return kA:	16.951	LLG:	25.11	15.1							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	kA	Sec	quence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impeda	nce pu	R	+ <i>j</i> X
BB-ESB3A-MCC	600	3 Phase:	6.19	6.4	2.78	6.80	6.50	Z1:	15.55	0.02	0.05
		SLG:	5.72	3.4	1.72	5.87		Z2:	15.55		
		LL:	5.36	3.2				Z0:	20.50		
LLG Gnd Return kA:	5.200	LLG:	6.64	4.0							
BB-ESB3A-MCC	600	3 Phase:	6.48	6.7	3.28	7.37	6.93	Z1:	14.85	0.02	0.05
Main Bkr LineSide		SLG:	6.27	3.8	2.10	6.58		Z2:	14.85		
		LL:	5.61	3.4				Z0:	17.15		
LLG Gnd Return kA:	5.965	LLG:	7.02	4.2							
BB-ESB3B-MCC	600	3 Phase:	6.49	6.7	3.34	7.41	6.96	Z1:	14.83	0.02	0.05
		SLG:	6.27	3.8	2.12	6.59		Z2:	14.83		
		LL:	5.62	3.4				Z0:	17.15		
LLG Gnd Return kA:	5.968	LLG:	7.03	4.2							
BB-ESB3B-MCC	600	3 Phase:	6.49	6.7	3.34	7.41	6.96	Z1:	14.83	0.02	0.05
Main Bkr LineSide		SLG:	6.27	3.8	2.12	6.59		Z2:	14.83		
		LL:	5.62	3.4				Z0:	17.15		
LLG Gnd Return kA:	5.968	LLG:	7.03	4.2							
BB-ESB3-MCC	600	3 Phase:	6.78	7.0	4.12	8.12	7.47	Z1:	14.20	0.01	0.05
		SLG:	6.87	4.1	2.80	7.56		Z2:	14.20		
		LL:	5.87	3.5				Z0:	14.06		
LLG Gnd Return kA:	6.890	LLG:	7.37	4.4							
BB-ESB3-TXR1	4,160	3 Phase:	2.33	16.8	4.50	2.85	2.59	Z1:	5.96	0.23	1.01
Prim Side		SLG:	0.01	0.1	0.01	0.01		Z2:	5.96		
		LL:	2.02	8.4				Z0:	2,776.83		
LLG Gnd Return kA:	0.007	LLG:	2.02	8.4							
BB-ESB3-TXR1	600	3 Phase:	7.11	7.4	4.81	8.83	8.00	Z1:	13.53	0.01	0.05
Sec Side		SLG:	7.79	4.7	4.78	9.66		Z2:	13.53		
		LL:	6.16	3.7				Z0:	10.00		
LLG Gnd Return kA:	8.610	LLG:	7.51	4.5							
BB-ESB4-MCC	600	3 Phase:	1.88	2.0	3.43	2.16	2.02	Z1:	51.20	0.07	0.17
		SLG:	1.72	1.0	2.13	1.81		Z2:	51.20		
		LL:	1.63	1.0				Z0:	67.40		
LLG Gnd Return kA:	1.566	LLG:	1.95	1.2							
BB-ESB4-TXR1	4,160	3 Phase:	2.33	16.8	4.48	2.84	2.59	Z1:	5.97	0.23	1.01
Prim Side	, - •	SLG:	0.01	0.1	0.01	0.01		Z2:	5.97		
		LL:	2.01	8.4				Z0:	2,776.83		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Sec	quence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impeda	nce pu	R	+ <i>j</i> X
BB-ESB4-TXR1	600	3 Phase:	2.02	2.1	4.06	2.42	2.22	Z1:	47.57	0.04	0.17
Sec Side		SLG:	1.99	1.2	3.77	2.34		Z2:	47.57		
		LL:	1.75	1.1				Z0:	50.00		
LLG Gnd Return kA:	1.956	LLG:	2.02	1.2							
BB-ESB5A-MCC	600	3 Phase:	5.50	5.7	2.12	5.78	5.64	Z1:	17.50	0.03	0.05
		SLG:	4.42	2.7	1.06	4.43		Z2:	17.50		
		LL:	4.76	2.9				Z0:	32.72		
LLG Gnd Return kA:	3.564	LLG:	5.73	3.4							
BB-ESB5B-MCC	600	3 Phase:	5.54	5.8	2.27	5.87	5.71	Z1:	17.38	0.03	0.05
		SLG:	4.44	2.7	1.09	4.45		Z2:	17.38		
		LL:	4.79	2.9				Z0:	32.72		
LLG Gnd Return kA:	3.572	LLG:	5.77	3.5							
BB-ESB5C-MCC	600	3 Phase:	5.54	5.8	2.27	5.87	5.71	Z1:	17.38	0.03	0.05
		SLG:	4.44	2.7	1.09	4.45		Z2:	17.38		
		LL:	4.79	2.9				Z0:	32.72		
LLG Gnd Return kA:	3.572	LLG:	5.77	3.5							_
BB-ESB5-MCC	600	3 Phase:	6.03	6.3	2.61	6.55	6.29	Z1:	15.96	0.03	0.05
		SLG:	5.22	3.1	1.28	5.26		Z2:	15.96		
		LL:	5.22	3.1				Z0:	25.55		
LLG Gnd Return kA:	4.425	LLG:	6.45	3.9							
BB-ESB5-TXR1	4,160	3 Phase:	2.33	16.8	4.50	2.85	2.59	Z1:	5.96	0.23	1.01
Prim Side		SLG:	0.01	0.1	0.01	0.01		Z2:	5.96		
		LL:	2.02	8.4				Z0:	2,776.83		
LLG Gnd Return kA:	0.007	LLG:	2.02	8.4							
BB-ESB5-TXR1	600	3 Phase:	7.15	7.4	4.52	8.75	7.97	Z1:	13.47	0.01	0.05
Sec Side		SLG:	7.82	4.7	4.56	9.59		Z2:	13.47		
		LL:	6.19	3.7				Z0:	10.00		
LLG Gnd Return kA:	8.626	LLG:	7.51	4.5							
BB-LC3A-MCC	480	3 Phase:	6.86	5.7	2.44	7.36	7.11	Z1:	17.53	0.02	0.04
		SLG:	6.69	3.2	1.66	6.85		Z2:	17.53		
		LL:	5.94	2.9				Z0:	19.89		
LLG Gnd Return kA:	6.409	LLG:	7.50	3.6							
BB-LC4A-MCC	480	3 Phase:	5.84	4.9	1.85	6.04	5.94	Z1:	20.58	0.02	0.04
		SLG:	5.11	2.5	1.20	5.13		Z2:	20.58		
		LL:	5.06	2.4				Z0:	31.14		
LLG Gnd Return kA:	4.432	LLG:	6.14	2.9							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Se	equence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Imped	ance pu	R	+ <i>j</i> X
CDP PANEL A	480	3 Phase:	7.89	6.6	1.26	7.94	7.91	Z1:	15.25	0.02	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	15.25		
		LL:	6.83	3.3				Z0:	180,046.70		
LLG Gnd Return kA:	0.001	LLG:	6.83	3.3							
CDP PANEL AX	480	3 Phase:	6.25	5.2	1.05	6.26	6.25	Z1:	19.26	0.03	0.03
(CTRL RM BLDG)		SLG:	0.00	0.0	0.03	0.00		Z2:	19.26		
		LL:	5.41	2.6				Z0:	180,053.80		
LLG Gnd Return kA:	0.001	LLG:	5.41	2.6							
CDP PANEL BX	480	3 Phase:	7.38	6.1	2.57	7.99	7.69	Z1:	16.31	0.02	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	16.31		
		LL:	6.39	3.1				Z0:	180,052.30		
LLG Gnd Return kA:	0.001	LLG:	6.39	3.1							
CDP PANEL	480	3 Phase:	4.80	4.0	0.57	4.80	4.80	Z1:	25.05	0.05	0.03
SB-A1		SLG:	0.00	0.0	0.03	0.00		Z2:	25.05		
		LL:	4.16	2.0				Z0:	180,066.20		
LLG Gnd Return kA:	0.001	LLG:	4.16	2.0							
DIV. OFFICE	480	3 Phase:	1.80	1.5	0.53	1.80	1.80	Z1:	66.79	0.14	0.07
BASEMENT		SLG:	0.00	0.0	0.03	0.00		Z2:	66.79		
		LL:	1.56	0.7				Z0:	180,128.50		
LLG Gnd Return kA:	0.001	LLG:	1.56	0.7							
ESB2A-MCC	600	3 Phase:	21.92	22.8	3.29	24.96	23.46	Z1:	4.39	0.01	0.01
MAIN Bkr Line		SLG:	17.33	10.4	1.51	17.59		Z2:	4.39		
		LL:	18.98	11.4				Z0:	8.49		
LLG Gnd Return kA:	13.821	LLG:	22.73	13.6							
ESB2-MCC MAIN	600	3 Phase:	24.16	25.1	4.76	29.93	27.13	Z1:	3.98	0.00	0.01
Bkr Line side		SLG:	21.00	12.6	2.15	22.09		Z2:	3.98		
		LL:	20.93	12.6				Z0:	6.23		
LLG Gnd Return kA:	17.976	LLG:	25.70	15.4							
ESB3-MCC MAIN	600	3 Phase:	6.78	7.0	4.12	8.12	7.47	Z1:	14.20	0.01	0.05
Bkr Line Side		SLG:	6.87	4.1	2.80	7.56		Z2:	14.20		
		LL:	5.87	3.5				Z0:	14.06		
LLG Gnd Return kA:	6.890	LLG:	7.37	4.4							
ESB4-MCC MAIN	600	3 Phase:	1.88	2.0	3.43	2.16	2.02	Z1:	51.20	0.07	0.17
Bkr Line Side		SLG:	1.72	1.0	2.13	1.81		Z2:	51.20		
		LL:	1.63	1.0				Z0:	67.36		
LLG Gnd Return kA:	1.566	LLG:	1.95	1.2							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	It Duty	X/R	Asym	ı kA	Sec	uence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impeda	nce pu	R	+ <i>j</i> X
ESB5A-MCC	600	3 Phase:	5.51	5.7	2.12	5.79	5.65	Z1:	17.47	0.03	0.05
MAIN Bkr Line		SLG:	4.43	2.7	1.07	4.44		Z2:	17.47		
		LL:	4.77	2.9				Z0:	32.61		
LLG Gnd Return kA:	3.575	LLG:	5.74	3.4							
ESB5B-MCC	600	3 Phase:	5.54	5.8	2.27	5.88	5.71	Z1:	17.36	0.03	0.05
MAIN Bkr Line		SLG:	4.45	2.7	1.09	4.47		Z2:	17.36		
		LL:	4.80	2.9				Z0:	32.61		
LLG Gnd Return kA:	3.583	LLG:	5.78	3.5							
ESB5C-MCC	600	3 Phase:	5.54	5.8	2.27	5.88	5.71	Z1:	17.36	0.03	0.05
MAIN Bkr Line		SLG:	4.45	2.7	1.09	4.47		Z2:	17.36		
		LL:	4.80	2.9				Z0:	32.61		
LLG Gnd Return kA:	3.583	LLG:	5.78	3.5							
ESB5-MCC MAIN	600	3 Phase:	6.03	6.3	2.61	6.55	6.29	Z1:	15.95	0.03	0.05
Bkr Line Side		SLG:	5.22	3.1	1.28	5.26		Z2:	15.95		
		LL:	5.22	3.1				Z0:	25.53		
LLG Gnd Return kA:	4.427	LLG:	6.45	3.9							
LC3A-MCC MAIN	480	3 Phase:	6.86	5.7	2.44	7.36	7.11	Z1:	17.53	0.02	0.04
Bkr Line Side		SLG:	6.69	3.2	1.66	6.85		Z2:	17.53		
		LL:	5.94	2.9				Z0:	19.89		
LLG Gnd Return kA:	6.409	LLG:	7.50	3.6							
LC4A-MCC MAIN	480	3 Phase:	6.69	5.6	2.48	7.20	6.95	Z1:	17.97	0.02	0.04
Bkr Line Side		SLG:	6.55	3.1	1.73	6.72		Z2:	17.97		
		LL:	5.80	2.8				Z0:	20.06		
LLG Gnd Return kA:	6.308	LLG:	7.28	3.5							
LEVEE BUILDING	480	3 Phase:	0.92	0.8	0.34	0.92	0.92	Z1:	130.57	0.29	0.09
		SLG:	0.00	0.0	0.03	0.00		Z2:	130.57		
		LL:	0.80	0.4				Z0: 1	180,234.30		
LLG Gnd Return kA:	0.001	LLG:	0.80	0.4							
MCC LC-3	480	3 Phase:	7.86	6.5	4.44	9.58	8.74	Z1:	15.30	0.01	0.03
		SLG:	8.77	4.2	4.12	10.51		Z2:	15.30		
		LL:	6.81	3.3				Z0:	10.53		
LLG Gnd Return kA:	9.926	LLG:	8.56	4.1							
MCC LC-4	480	3 Phase:	7.63	6.3	4.41	9.29	8.48	Z1:	15.76	0.01	0.04
		SLG:	8.48	4.1	4.33	10.28		Z2:	15.76		
		LL:	6.61	3.2				Z0:	11.03		
LLG Gnd Return kA:	9.543	LLG:	8.17	3.9							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	kA	Se	equence	Equivalent	
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Imped	ance pu	R	+ <i>j</i> X
MCC-A	480	3 Phase:	13.76	11.4	4.44	16.77	15.30	Z1:	8.74	0.00	0.02
		SLG:	0.00	0.0	0.03	0.00		Z2:	8.74		
		LL:	11.91	5.7				Z0:	180,034.80		
LLG Gnd Return kA:	0.001	LLG:	11.91	5.7							
MCC-A MAIN Line	480	3 Phase:	14.32	11.9	4.82	17.78	16.10	Z1:	8.40	0.00	0.02
Side		SLG:	0.00	0.0	0.03	0.00		Z2:	8.40		
		LL:	12.40	6.0				Z0:	180,034.00		
LLG Gnd Return kA:	0.001	LLG:	12.40	6.0							
MCC-AX	480	3 Phase:	12.14	10.1	2.96	13.52	12.84	Z1:	9.90	0.01	0.02
		SLG:	0.00	0.0	0.03	0.00		Z2:	9.90		
		LL:	10.52	5.0				Z0:	180,037.90		
LLG Gnd Return kA:	0.001	LLG:	10.52	5.0							
МСС-В	480	3 Phase:	13.66	11.4	5.29	17.33	15.55	Z1:	8.81	0.00	0.02
		SLG:	0.00	0.0	0.02	0.00		Z2:	8.81		
		LL:	11.83	5.7				Z0:	182,361.00		
LLG Gnd Return kA:	0.001	LLG:	11.83	5.7							
MCC-B MAIN Line	480	3 Phase:	13.66	11.4	5.29	17.33	15.55	Z1:	8.81	0.00	0.02
Side		SLG:	0.00	0.0	0.02	0.00		Z2:	8.81		
		LL:	11.83	5.7				Z0:	182,361.00		
LLG Gnd Return kA:	0.001	LLG:	11.83	5.7							
MCC-DX	480	3 Phase:	6.66	5.5	2.26	7.06	6.86	Z1:	18.07	0.03	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	18.07		
		LL:	5.76	2.8				Z0:	180,056.40		
LLG Gnd Return kA:	0.001	LLG:	5.77	2.8							
МСС-Е	480	3 Phase:	10.05	8.4	3.99	11.95	11.02	Z1:	11.97	0.01	0.03
		SLG:	10.27	4.9	3.92	12.17		Z2:	11.97		
		LL:	8.70	4.2				Z0:	11.18		
LLG Gnd Return kA:	10.511	LLG:	10.19	4.9							
MCC-E MAIN Line	480	3 Phase:	10.05	8.4	3.99	11.95	11.02	Z1:	11.97	0.01	0.03
Side		SLG:	10.27	4.9	3.92	12.17		Z2:	11.97		
		LL:	8.70	4.2				Z0:	11.18		
LLG Gnd Return kA:	10.511	LLG:	10.19	4.9							
MCC-EX	480	3 Phase:	0.63	0.5	0.40	0.63	0.63	Z1:	192.37	0.41	0.16
		SLG:	0.00	0.0	0.03	0.00		Z2:	192.37		
		LL:	0.54	0.3				Z0:	180,316.90		
LLG Gnd Return kA:	0.001	LLG:	0.54	0.3							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Se	equence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Imped	ance pu	R	+ <i>j</i> X
MCC-EX Line Side	480	3 Phase:	1.21	1.0	0.44	1.21	1.21	Z1:	99.58	0.21	0.09
		SLG:	0.00	0.0	0.03	0.00		Z2:	99.58		
		LL:	1.05	0.5				Z0:	180,177.40		
LLG Gnd Return kA:	0.001	LLG:	1.05	0.5							
MCC-F	480	3 Phase:	9.76	8.1	1.78	10.05	9.91	Z1:	12.32	0.01	0.02
		SLG:	0.00	0.0	0.03	0.00		Z2:	12.32		
		LL:	8.46	4.1				Z0:	180,041.40		
LLG Gnd Return kA:	0.001	LLG:	8.46	4.1							
MCC-LC-3 MAIN	480	3 Phase:	7.94	6.6	4.55	9.73	8.86	Z1:	15.15	0.01	0.03
BK Line Side		SLG:	8.94	4.3	4.26	10.79		Z2:	15.15		
		LL:	6.88	3.3				Z0:	10.09		
LLG Gnd Return kA:	10.215	LLG:	8.69	4.2							
MCC-LC-4 MAIN	480	3 Phase:	7.70	6.4	4.52	9.43	8.59	Z1:	15.61	0.01	0.04
BK Line Side		SLG:	8.63	4.1	4.48	10.54		Z2:	15.61		
		LL:	6.67	3.2				Z0:	10.59		
LLG Gnd Return kA:	9.807	LLG:	8.29	4.0							
MECH SHOP	480	3 Phase:	8.45	7.0	2.31	8.99	8.72	Z1:	14.23	0.01	0.03
PANEL		SLG:	8.09	3.9	2.19	8.53		Z2:	14.23		
		LL:	7.32	3.5				Z0:	16.18		
LLG Gnd Return kA:	7.748	LLG:	8.40	4.0							
PDP #1	480	3 Phase:	6.59	5.5	1.84	6.81	6.70	Z1:	18.24	0.03	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	18.24		
		LL:	5.71	2.7				Z0:	180,056.40		
LLG Gnd Return kA:	0.001	LLG:	5.71	2.7							
PDP #3	480	3 Phase:	7.11	5.9	2.32	7.57	7.34	Z1:	16.91	0.02	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	16.91		
		LL:	6.16	3.0				Z0:	180,053.60		
LLG Gnd Return kA:	0.001	LLG:	6.16	3.0							
PDP #4	480	3 Phase:	7.06	5.9	2.28	7.49	7.28	Z1:	17.04	0.02	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	17.04		
		LL:	6.11	2.9					180,053.90		
LLG Gnd Return kA:	0.001	LLG:	6.11	2.9							
PDP #5	480	3 Phase:	7.11	5.9	2.27	7.54	7.32	Z1:	16.93	0.02	0.03
	.00	SLG:	0.00	0.0	0.03	0.00		Z2:	16.93		
		LL:	6.15	3.0					180,053.60		
		~~.	0.15	5.0				۷٠.	100,000.00		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	It Duty	X/R	Asym	ı kA	Se	equence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Imped	ance pu	R	+ <i>j</i> X
PDP #6	480	3 Phase:	7.29	6.1	2.46	7.84	7.57	Z1:	16.49	0.02	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	16.49		
		LL:	6.32	3.0				Z0:	180,052.70		
LLG Gnd Return kA:	0.001	LLG:	6.32	3.0							
PLM SHOP MCC	480	3 Phase:	8.48	7.0	2.38	9.06	8.77	Z1:	14.19	0.01	0.03
		SLG:	8.10	3.9	2.23	8.57		Z2:	14.19		
		LL:	7.34	3.5				Z0:	16.18		
LLG Gnd Return kA:	7.755	LLG:	8.43	4.0							
SUB1 12.5 kV Line	12,470	3 Phase:	3.49	75.5	5.21	4.42	3.97	Z1:	1.32	0.41	2.02
Side	,	SLG:	2.31	28.9	4.01	2.75		Z2:	1.32		
		LL:	3.03	37.7				Z0:	3.36		
LLG Gnd Return kA:	1.728	LLG:	3.21	40.0							
SUB1 Xmer Prim	12,470	3 Phase:	3.49	75.5	5.21	4.42	3.97	Z1:	1.32	0.41	2.02
Side	12,	SLG:	2.31	28.9	4.01	2.75		Z2:	1.32		
		LL:	3.03	37.7				Z0:	3.36		
LLG Gnd Return kA:	1.728	LLG:	3.21	40.0				20.	3.30		
SUB1 Xmer Sec	12,470	3 Phase:	2.29	49.5	6.79	3.07	2.70	Z1:	2.02	0.50	3.10
Side	12,	SLG:	0.01	0.2	0.01	0.01		Z2:	2.02		
		LL:	1.98	24.7				Z0:	926.11		
LLG Gnd Return kA:	0.007	LLG:	1.99	24.8				20.	,20.11		
SUB1-PDC1	12,470	3 Phase:	2.29	49.5	6.77	3.07	2.69	Z1:	2.02	0.50	3.10
SCB1 1DC1	12,170	SLG:	0.01	0.2	0.01	0.01		Z2:	2.02		
		LL:	1.98	24.7				Z0:	926.13		
LLG Gnd Return kA:	0.007	LLG:	1.99	24.8				20.	720.13		
SUB2 12.5 kV Line	12,470	3 Phase:	2.47	53.4	2.59	2.68	2.58	Z1:	1.87	1.08	2.70
Side Side	12,470	SLG:	1.68	20.9	1.88	1.74	2.36	Z2:	1.87	1.00	2.70
		LL:	2.14	26.7	1.00	1./4		Z0:	4.58		
LLG Gnd Return kA:	1.263	LLG:	2.34	29.1				20.	4.36		
SUB2 Xmer Prim	12,470	3 Phase:	2.47	53.4	2.59	2.68	2.58	Z1:	1.87	1.08	2.70
Side Side	12,470	SLG:	1.68	20.9	1.88	1.74	2.36	Z1. Z2:	1.87	1.06	2.70
		LL:	2.14	26.7	1.00	1.74		Z0:	4.58		
LLG Gnd Return kA:	1.263	LLG:	2.14	29.1				ZU:	4.30		
CUR2 Vmar Caa	A 160	3 Dhosar	2 24	16.0	471	2.00	2.62	71.	5.02	0.22	1.00
SUB2 Xmer Sec Side	4,160	3 Phase:	2.34	16.9	4.71	2.90	2.63	Z1:	5.92 5.92	0.22	1.00
~- <del></del>		SLG:	0.01	0.1	0.01	0.01		Z2:	5.92		
II C Cnd Datum le 4	0.007	LL:	2.03	8.4				Z0:	2,776.53		
LLG Gnd Return kA:	0.007	LLG:	2.03	8.5							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Sec	quence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impeda	nce pu	R	+ <i>j</i> X
SUB2-PDC1	4,160	3 Phase:	2.34	16.8	4.63	2.88	2.62	Z1:	5.94	0.22	1.00
		SLG:	0.01	0.1	0.01	0.01		Z2:	5.94		
		LL:	2.02	8.4				Z0:	2,776.68		
LLG Gnd Return kA:	0.007	LLG:	2.03	8.4							
T-3 Prim Side	4,160	3 Phase:	2.33	16.8	4.48	2.84	2.59	Z1:	5.97	0.23	1.01
		SLG:	0.01	0.1	0.01	0.01		Z2:	5.97		
		LL:	2.01	8.4				Z0:	2,776.83		
LLG Gnd Return kA:	0.007	LLG:	2.02	8.4							
T-3 Sec Side	480	3 Phase:	8.01	6.7	4.69	9.88	8.97	Z1:	15.02	0.01	0.03
		SLG:	9.10	4.4	4.69	11.24		Z2:	15.02		
		LL:	6.94	3.3				Z0:	9.60		
LLG Gnd Return kA:	10.545	LLG:	8.70	4.2							
T-4 Prim Side	4,160	3 Phase:	2.33	16.8	4.48	2.84	2.59	Z1:	5.97	0.23	1.01
		SLG:	0.01	0.1	0.01	0.01		Z2:	5.97		
		LL:	2.01	8.4				Z0:	2,776.83		
LLG Gnd Return kA:	0.007	LLG:	2.02	8.4					,		
T-4 Sec Side	480	3 Phase:	7.81	6.5	4.68	9.64	8.75	Z1:	15.39	0.01	0.03
		SLG:	8.85	4.2	4.69	10.92		Z2:	15.39		
		LL:	6.77	3.2				Z0:	10.00		
LLG Gnd Return kA:	10.195	LLG:	8.46	4.1							
TK71 MAIN BK	480	3 Phase:	2.91	2.4	1.02	2.92	2.91	Z1:	41.34	0.07	0.07
Line Side		SLG:	2.47	1.2	1.03	2.48		Z2:	41.34		
		LL:	2.52	1.2				Z0:	63.36		
LLG Gnd Return kA:	2.147	LLG:	2.72	1.3							
TK71 MCC	480	3 Phase:	2.91	2.4	1.02	2.92	2.91	Z1:	41.34	0.07	0.07
		SLG:	2.47	1.2	1.03	2.48		Z2:	41.34		
		LL:	2.52	1.2				Z0:	63.36		
LLG Gnd Return kA:	2.147	LLG:	2.72	1.3							
TK72 MAIN BK	480	3 Phase:	2.77	2.3	0.79	2.77	2.77	Z1:	43.39	0.08	0.06
Line Side		SLG:	2.37	1.1	0.76	2.37		Z2:	43.39		
		LL:	2.40	1.2				Z0:	65.50		
LLG Gnd Return kA:	2.069	LLG:	2.63	1.3							
TK72 MCC	480	3 Phase:	2.77	2.3	0.79	2.77	2.77	Z1:	43.39	0.08	0.06
50	.03	SLG:	2.37	1.1	0.76	2.37		Z2:	43.39		
		LL:	2.40	1.2				Z0:	65.50		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Fau	It Duty	X/R	Asym	ı kA	Seq	uence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impedan	ce pu	R	+ <i>j</i> X
TK73 MAIN BK	480	3 Phase:	2.83	2.4	1.43	2.86	2.85	Z1:	42.53	0.06	0.08
Line Side		SLG:	2.33	1.1	1.51	2.36		Z2:	42.53		
		LL:	2.45	1.2				Z0:	70.07		
LLG Gnd Return kA:	1.976	LLG:	2.59	1.2							
TK73 MCC	480	3 Phase:	2.83	2.4	1.43	2.86	2.85	Z1:	42.53	0.06	0.08
		SLG:	2.33	1.1	1.51	2.36		Z2:	42.53		
		LL:	2.45	1.2				Z0:	70.07		
LLG Gnd Return kA:	1.976	LLG:	2.59	1.2							
TK74 MAIN BK	480	3 Phase:	2.32	1.9	0.88	2.32	2.32	Z1:	51.89	0.09	0.08
Line Side		SLG:	1.92	0.9	0.92	1.93		Z2:	51.89		
		LL:	2.01	1.0				Z0:	83.77		
LLG Gnd Return kA:	1.645	LLG:	2.14	1.0							
TK74 MCC	480	3 Phase:	2.32	1.9	0.88	2.32	2.32	Z1:	51.89	0.09	0.08
		SLG:	1.92	0.9	0.92	1.93		Z2:	51.89		
		LL:	2.01	1.0				Z0:	83.77		
LLG Gnd Return kA:	1.645	LLG:	2.14	1.0							
TK81 MAIN BK	480	3 Phase:	2.91	2.4	0.80	2.92	2.92	Z1:	41.27	0.07	0.06
Line Side		SLG:	2.52	1.2	0.78	2.52		Z2:	41.27		
		LL:	2.52	1.2				Z0:	60.81		
LLG Gnd Return kA:	2.215	LLG:	2.77	1.3							
TK81 MCC	480	3 Phase:	2.91	2.4	0.80	2.92	2.92	Z1:	41.27	0.07	0.06
		SLG:	2.52	1.2	0.78	2.52		Z2:	41.27		
		LL:	2.52	1.2				Z0:	60.81		
LLG Gnd Return kA:	2.215	LLG:	2.77	1.3							
TK82 MAIN BK	480	3 Phase:	3.14	2.6	0.83	3.14	3.14	Z1:	38.26	0.07	0.06
Line Side		SLG:	2.72	1.3	0.79	2.72		Z2:	38.26		
		LL:	2.72	1.3				Z0:	55.98		
LLG Gnd Return kA:	2.402	LLG:	3.01	1.4							
TK82 MCC	480	3 Phase:	3.14	2.6	0.83	3.14	3.14	Z1:	38.26	0.07	0.06
		SLG:	2.72	1.3	0.79	2.72		Z2:	38.26		
		LL:	2.72	1.3				Z0:	55.98		
LLG Gnd Return kA:	2.402	LLG:	3.01	1.4							
TK83 MAIN BK	480	3 Phase:	3.94	3.3	0.82	3.94	3.94	Z1:	30.53	0.05	0.04
Line side		SLG:	3.57	1.7	0.73	3.57		Z2:	30.53		
		LL:	3.41	1.6				Z0:	40.32		
LLG Gnd Return kA:	3.253	LLG:	3.93	1.9							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	kA	Seq	uence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impedan	ice pu	R	+ <i>j</i> X
TK83 MCC	480	3 Phase:	3.94	3.3	0.82	3.94	3.94	Z1:	30.53	0.05	0.04
		SLG:	3.57	1.7	0.73	3.57		Z2:	30.53		
		LL:	3.41	1.6				Z0:	40.32		
LLG Gnd Return kA:	3.253	LLG:	3.93	1.9							
TK84 MAIN BK	480	3 Phase:	4.78	4.0	1.00	4.79	4.78	Z1:	25.16	0.04	0.04
Line Side		SLG:	4.45	2.1	0.86	4.45		Z2:	25.16		
		LL:	4.14	2.0				Z0:	31.15		
LLG Gnd Return kA:	4.142	LLG:	4.88	2.3							
TK84 MCC	480	3 Phase:	4.78	4.0	1.00	4.79	4.78	Z1:	25.16	0.04	0.04
		SLG:	4.45	2.1	0.86	4.45		Z2:	25.16		
		LL:	4.14	2.0				Z0:	31.15		
LLG Gnd Return kA:	4.142	LLG:	4.88	2.3							
TK85 MAIN BK	480	3 Phase:	6.37	5.3	1.81	6.57	6.47	Z1:	18.87	0.02	0.04
Line Side		SLG:	6.52	3.1	1.56	6.63		Z2:	18.87		
		LL:	5.52	2.6				Z0:	17.85		
LLG Gnd Return kA:	6.643	LLG:	6.81	3.3							
TK85 MCC	480	3 Phase:	6.37	5.3	1.81	6.57	6.47	Z1:	18.87	0.02	0.04
		SLG:	6.52	3.1	1.56	6.63		Z2:	18.87		
		LL:	5.52	2.6				Z0:	17.85		
LLG Gnd Return kA:	6.643	LLG:	6.81	3.3							
TK86 MAIN BK	480	3 Phase:	3.70	3.1	0.78	3.71	3.71	Z1:	32.47	0.06	0.04
Line Side		SLG:	3.30	1.6	0.67	3.30		Z2:	32.47		
		LL:	3.21	1.5				Z0:	44.61		
LLG Gnd Return kA:	2.971	LLG:	3.67	1.8							
TK86 MCC	480	3 Phase:	3.70	3.1	0.78	3.71	3.71	Z1:	32.47	0.06	0.04
		SLG:	3.30	1.6	0.67	3.30		Z2:	32.47		
		LL:	3.21	1.5				Z0:	44.61		
LLG Gnd Return kA:	2.971	LLG:	3.67	1.8							
TK87 MAIN BK	480	3 Phase:	2.83	2.4	1.01	2.83	2.83	Z1:	42.52	0.07	0.07
Line Side		SLG:	2.40	1.1	1.02	2.40		Z2:	42.52		
		LL:	2.45	1.2				Z0:	65.63		
LLG Gnd Return kA:	2.077	LLG:	2.64	1.3							
TK87 MCC	480	3 Phase:	2.83	2.4	1.01	2.83	2.83	Z1:	42.52	0.07	0.07
	.00	SLG:	2.40	1.1	1.02	2.40		Z2:	42.52		
		LL:	2.45	1.2				Z0:	65.63		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Se	equence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Imped	ance pu	R	+ <i>j</i> X
TK90/88 MAIN BK	480	3 Phase:	4.93	4.1	1.55	5.01	4.97	Z1:	24.42	0.03	0.05
Line Side		SLG:	4.54	2.2	1.41	4.59		Z2:	24.42		
		LL:	4.27	2.0				Z0:	30.70		
LLG Gnd Return kA:	4.208	LLG:	4.88	2.3							
TK90/88 MCC	480	3 Phase:	4.93	4.1	1.55	5.01	4.97	Z1:	24.42	0.03	0.05
		SLG:	4.54	2.2	1.41	4.59		Z2:	24.42		
		LL:	4.27	2.0				Z0:	30.70		
LLG Gnd Return kA:	4.208	LLG:	4.88	2.3							
TX-A Prim Side	12,470	3 Phase:	2.28	49.3	6.35	3.01	2.66	Z1:	2.03	0.54	3.11
		SLG:	0.01	0.2	0.01	0.01		Z2:	2.03		
		LL:	1.98	24.6				Z0:	926.18		
LLG Gnd Return kA:	0.007	LLG:	1.98	24.7							
TX-A Sec Side	480	3 Phase:	14.93	12.4	5.54	19.14	17.10	Z1:	8.06	0.00	0.02
		SLG:	0.00	0.0	0.03	0.00		Z2:	8.06		
		LL:	12.93	6.2				Z0:	180,033.20		
LLG Gnd Return kA:	0.001	LLG:	12.93	6.2					•		
TX-B Prim Side	12,470	3 Phase:	2.28	49.4	6.52	3.03	2.67	Z1:	2.03	0.52	3.11
	,	SLG:	0.01	0.2	0.01	0.01		Z2:	2.03		
		LL:	1.98	24.7				Z0:	926.17		
LLG Gnd Return kA:	0.007	LLG:	1.98	24.7							
TX-B Sec Side	480	3 Phase:	14.28	11.9	5.89	18.56	16.50	Z1:	8.42	0.00	0.02
		SLG:	0.00	0.0	0.02	0.00		Z2:	8.42		
		LL:	12.37	5.9				Z0:	182,360.20		
LLG Gnd Return kA:	0.001	LLG:	12.37	5.9							
TX-E Prim Side	12,470	3 Phase:	2.22	47.8	4.44	2.70	2.46	Z1:	2.09	0.76	3.16
		SLG:	0.01	0.2	0.01	0.01		Z2:	2.09		
		LL:	1.92	23.9				Z0:	926.41		
LLG Gnd Return kA:	0.007	LLG:	1.92	24.0							
TX-E Sec Side	480	3 Phase:	10.75	8.9	4.69	13.27	12.04	Z1:	11.19	0.01	0.03
		SLG:	11.43	5.5	4.69	14.11		Z2:	11.19		
		LL:	9.31	4.5				Z0:	9.20		
LLG Gnd Return kA:	12.195	LLG:	11.12	5.3							
TX-F Prim Side	12,470	3 Phase:	2.28	49.2	6.25	3.00	2.65	Z1:	2.03	0.55	3.11
	,	SLG:	0.01	0.2	0.01	0.01		Z2:	2.03		
		LL:	1.97	24.6				Z0:	926.20		
LLG Gnd Return kA:	0.007	LLG:	1.98	24.6							

#### Low Voltage 3 Phase and Unbalanced

Fault Location	Bus			t Duty	X/R	Asym	ı kA	Sequ	ience	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impedan	ce pu	R	+ <i>j</i> X
TX-F Sec Side	4,160	3 Phase:	2.76	19.9	7.97	3.81	3.31	Z1:	5.03	0.13	0.86
		SLG:	3.04	12.6	7.53	4.15		Z2:	5.03		
		LL:	2.39	9.9				Z0:	3.65		
LLG Gnd Return kA:	3.375	LLG:	2.93	12.2							

#### **Momentary 3 Phase**

		S	ym Fault D	uty	Mor	n kA	Cres	st kA		
Fault Location Bus Name	Bus Voltage	kA	MVA	X/R	Sym*1.6	Based on X/R	Sym*2.7	Based on X/R	Equi R	valent +jX
02-MAIN SERVICE SWGR	12,470	1.990	42.98	6.67	3.184	2.650	5.373	4.570	0.58	3.57
5KV SWGR	4,160	2.567	18.50	7.69	4.107	3.520	6.931	6.040	0.14	0.92
BB-ESB1-TXR1 Prim Side	12,470	1.990	42.99	6.61	3.184	2.650	5.374	4.560	0.58	3.57
BB-ESB2-TXR1 Prim Side	12,470	1.990	42.99	6.61	3.184	2.650	5.374	4.560	0.58	3.57
BB-ESB3-TXR1 Prim Side	4,160	1.896	13.66	4.36	3.034	2.300	5.119	3.980	0.28	1.23
BB-ESB4-TXR1 Prim Side	4,160	1.896	13.66	4.36	3.034	2.300	5.119	3.980	0.28	1.23
BB-ESB5-TXR1 Prim Side	4,160	1.896	13.66	4.36	3.034	2.300	5.119	3.980	0.28	1.23
SUB1 12.5 kV Line Side	12,470	3.303	71.33	5.07	5.284	4.150	8.917	7.180	0.44	2.13
SUB1 Xmer Prim	12,470	3.302	71.33	5.07	5.284	4.150	8.917	7.180	0.44	2.13
SUB1 Xmer Sec	12,470	1.994	43.08	6.86	3.191	2.680	5.385	4.610	0.56	3.57
SUB1-PDC1	12,470	1.993	43.05	6.83	3.189	2.670	5.382	4.600	0.56	3.57
SUB2 12.5 kV Line Side	12,470	2.352	50.80	2.45	3.763	2.530	6.350	4.250	1.16	2.83
SUB2 Xmer Prim	12,470	2.352	50.80	2.45	3.763	2.530	6.350	4.250	1.16	2.83
SUB2 Xmer Sec	4,160	1.911	13.77	4.57	3.058	2.350	5.160	4.060	0.27	1.23
SUB2-PDC1	4,160	1.904	13.72	4.48	3.046	2.320	5.140	4.030	0.28	1.23
Γ-3 Prim Side	4,160	1.896	13.66	4.36	3.034	2.300	5.119	3.980	0.28	1.23
Γ-4 Prim Side	4,160	1.896	13.66	4.36	3.034	2.300	5.119	3.980	0.28	1.23
ΓX-A Prim Side	12,470	1.986	42.89	6.44	3.177	2.630	5.361	4.530	0.60	3.58
ΓX-B Prim Side	12,470	1.989	42.95	6.60	3.182	2.650	5.369	4.560	0.59	3.57
TX-E Prim Side	12,470	1.936	41.82	4.66	3.098	2.390	5.228	4.130	0.82	3.63
ΓX-F Prim Side	12,470	1.983	42.82	6.35	3.172	2.620	5.353	4.510	0.61	3.58
X-F Sec Side	4,160	2.576	18.56	7.81	4.121	3.550	6.955	6.080	0.14	0.92

#### **Momentary Unbalanced**

Fault Location	Bus		Sym Fa	ult Duty	X/R	Мо	om. Fault Duty		Sequence
Bus Name	Voltage		kA	MVA		kA*1.6	Based on X/R	Imp	edance pu
02-MAIN SERVICE	12,470	3 Phase:	1.990	42.98	6.67	3.184	2.650	Z1:	2.33
SWGR		SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.33
		LL:	1.723	21.49				Z0:	926.16
LLG Gnd Return kA:	0.01	LLG:	1.727	21.53					
5KV SWGR	4,160	3 Phase:	2.567	18.50	7.69	4.107	3.520	Z1:	5.41
		SLG:	2.867	11.93	7.20	4.587	3.880	Z2:	5.41
		LL:	2.223	9.25				Z0:	3.71
LLG Gnd Return kA:	3.25	LLG:	2.761	11.49					
BB-ESB1-TXR1	12,470	3 Phase:	1.990	42.99	6.61	3.184	2.650	Z1:	2.33
Prim Side	,	SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.33
		LL:	1.724	21.49				Z0:	926.16
LLG Gnd Return kA:	0.01	LLG:	1.727	21.54				20.	720.10
BB-ESB2-TXR1	12,470	3 Phase:	1.990	42.99	6.61	3.184	2.650	Z1:	2.33
Prim Side	12,470	SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.33
		LL:	1.724	21.49	0.01	0.024	0.010	Z0:	926.16
LLG Gnd Return kA:	0.01	LLG:	1.724	21.49				20.	920.10
		3 Phase:			1.26	2.024	2 200	Z1:	7 22
BB-ESB3-TXR1 Prim Side	4,160		1.896	13.66	4.36	3.034	2.300		7.32
Timi Side		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.32
LLG Gnd Return kA:	0.01	LL: LLG:	1.642	6.83				Z0:	2,776.83
LLG Glid Return KA:	0.01	LLU:	1.646	6.85					
BB-ESB4-TXR1	4,160	3 Phase:	1.896	13.66	4.36	3.034	2.300	Z1:	7.32
Prim Side		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.32
		LL:	1.642	6.83				Z0:	2,776.83
LLG Gnd Return kA:	0.01	LLG:	1.646	6.85					
BB-ESB5-TXR1	4,160	3 Phase:	1.896	13.66	4.36	3.034	2.300	Z1:	7.32
Prim Side		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.32
		LL:	1.642	6.83				Z0:	2,776.83
LLG Gnd Return kA:	0.01	LLG:	1.646	6.85					
SUB1 12.5 kV Line	12,470	3 Phase:	3.303	71.33	5.07	5.284	4.150	Z1:	1.40
Side		SLG:	2.256	28.13	4.00	3.609	2.680	Z2:	1.40
		LL:	2.860	35.67				Z0:	3.36
LLG Gnd Return kA:	1.71	LLG:	3.040	37.91					
SUB1 Xmer Prim	12,470	3 Phase:	3.302	71.33	5.07	5.284	4.150	Z1:	1.40
Side		SLG:	2.256	28.13	4.00	3.609	2.680	Z2:	1.40
		LL:	2.860	35.66				Z0:	3.36
LLG Gnd Return kA:	1.71	LLG:	3.040	37.91					
SUB1 Xmer Sec Side	12,470	3 Phase:	1.994	43.08	6.86	3.191	2.680	Z1:	2.32
	,	SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.32
		LL:	1.727	21.54				Z0:	926.11
LLG Gnd Return kA:	0.01	LLG:	1.731	21.58					,
SUB1-PDC1	12,470	3 Phase:	1.993	43.05	6.83	3.189	2.670	Z1:	2.32
SODI-I DCI	12,470	SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.32
		SLG: LL:			0.01	0.024	0.010	Z0:	
II C Cnd Datum 1- 4	0.01		1.726	21.53				ZU.	926.13
LLG Gnd Return kA:	0.01	LLG:	1.730	21.57					

#### **Momentary Unbalanced**

Fault Location Bus Name	Bus Voltage		Sym Fa	nult Duty MVA	X/R	Mo kA*1.6	om. Fault Duty Based on X/R	Imp	Sequence edance pu
SUB2 12.5 kV Line	12.470	3 Phase:		50.80	2.45	3.763	2.530	Z1:	1.97
Side Side	12,470	SLG:	2.352 1.639	20.44	1.86	2.622	1.690	Z1. Z2:	1.97
		LL:	2.037	25.40	1.00	2.022	1.090	Z0:	4.58
LLG Gnd Return kA:	1.25	LLG:	2.037	27.76				20.	4.50
SUB2 Xmer Prim Side	12,470	3 Phase:	2.352	50.80	2.45	3.763	2.530	Z1:	1.97
Side		SLG:	1.639	20.44	1.85	2.622	1.690	Z2:	1.97
HCC ID . IA	1.05	LL:	2.037	25.40				Z0:	4.58
LLG Gnd Return kA:	1.25	LLG:	2.226	27.76					
SUB2 Xmer Sec Side	4,160	3 Phase:	1.911	13.77	4.57	3.058	2.350	Z1:	7.26
		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.26
		LL:	1.655	6.89				Z0:	2,776.53
LLG Gnd Return kA:	0.01	LLG:	1.659	6.90					
SUB2-PDC1	4,160	3 Phase:	1.904	13.72	4.48	3.046	2.320	Z1:	7.29
		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.29
		LL:	1.649	6.86				Z0:	2,776.68
LLG Gnd Return kA:	0.01	LLG:	1.652	6.87					
T-3 Prim Side	4,160	3 Phase:	1.896	13.66	4.36	3.034	2.300	Z1:	7.32
1-5 Phili Side	4,100	SLG:	0.015	0.06	0.01	0.024	0.010	Z1. Z2:	7.32
		LL:	1.642	6.83		0.024	0.010	Z0:	2,776.83
LLG Gnd Return kA:	0.01	LLG:	1.646	6.85				20.	2,770.63
LLO Oliu Retulli kA.	0.01	LLO.	1.040	0.83					
T-4 Prim Side	4,160	3 Phase:	1.896	13.66	4.36	3.034	2.300	Z1:	7.32
		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.32
		LL:	1.642	6.83				Z0:	2,776.83
LLG Gnd Return kA:	0.01	LLG:	1.646	6.85					
TX-A Prim Side	12,470	3 Phase:	1.986	42.89	6.44	3.177	2.630	Z1:	2.33
		SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.33
		LL:	1.720	21.44				Z0:	926.18
LLG Gnd Return kA:	0.01	LLG:	1.723	21.49					
TX-B Prim Side	12,470	3 Phase:	1.989	42.95	6.60	3.182	2.650	Z1:	2.33
	,	SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.33
		LL:	1.722	21.48				Z0:	926.17
LLG Gnd Return kA:	0.01	LLG:	1.726	21.52					
TX-E Prim Side	12,470	3 Phase:	1.936	41.82	4.66	3.098	2.390	Z1:	2.39
TA-E I IIII Side	12,470	SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.39
		LL:	1.677	20.91	0.01	0.024	0.010	Z0:	926.41
LLG Gnd Return kA:	0.01	LLG:	1.680	20.91				20.	920.41
TX-F Prim Side	12,470	3 Phase:	1.983	42.82	6.35	3.172	2.620	Z1:	2.34
		SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.34
		LL:	1.717	21.41				Z0:	926.20
LLG Gnd Return kA:	0.01	LLG:	1.721	21.46					
TX-F Sec Side	4,160	3 Phase:	2.576	18.56	7.81	4.121	3.550	Z1:	5.39
		SLG:	2.885	12.00	7.44	4.617	3.930	Z2:	5.39
		LL:	2.231	9.28				Z0:	3.65
LLG Gnd Return kA:	3.28	LLG:	2.771	11.53					

# Interrupting 3 Phase and Unbalanced


Fault Location	Bus	-	Init Sym I	Fault	Equiv	/alent	Seq.		l	nterruptin	g Fault k	Δ
Bus Name	Voltage		kA	X/R	R	+jX	lmp. pu		2 cyc.	3 сус.	5 cyc.	8 сус
02-MAIN	12,470	3 Phase:	1.68	6.68	0.66	4.24	Z1: 2.76	3Ph.Sym:	1.68	1.68	1.68	1.68
SERVICE SWGR		SLG:	0.01	0.01			Z2: 2.76	Tot:	1.85	1.68	1.68	1.68
NACD:	0.85	LL:	1.45				Z0: 926.10	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.45					Tot:	0.01	0.01	0.01	0.01
5KV SWGR	4,160	3 Phase:	2.25	6.90	0.17	1.05	Z1: 6.17	3Ph.Sym:	2.25	2.25	2.25	2.25
		SLG:	2.60	6.69			Z2: 6.17	Tot:	2.50	2.27	2.25	2.25
NACD:	0.83	LL:	1.95				Z0: 3.71	SLG Sym:	2.60	2.60	2.60	2.60
LLG Gnd Return kA:	3.065	LLG:	2.48					Tot:	2.86	2.61	2.60	2.60
BB-ESB1-TXR1	12,470	3 Phase:	1.68	6.65	0.66	4.24	Z1: 2.76	3Ph.Sym:	1.68	1.68	1.68	1.68
Prim Side		SLG:	0.01	0.01			Z2: 2.76	Tot:	1.84	1.68	1.68	1.68
NACD:	0.85	LL:	1.45				Z0: 926.10	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.46					Tot:	0.01	0.01	0.01	0.01
BB-ESB2-TXR1	12,470	3 Phase:	1.68	6.65	0.66	4.24	Z1: 2.76	3Ph.Sym:	1.68	1.68	1.68	1.68
Prim Side		SLG:	0.01	0.01			Z2: 2.76	Tot:	1.84	1.68	1.68	1.68
NACD:	0.85	LL:	1.45				Z0: 926.10	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.46					Tot:	0.01	0.01	0.01	0.01
BB-ESB3-TXR1	4,160	3 Phase:	1.90	4.36	0.28	1.23	Z1: 7.32	3Ph.Sym:	1.90	1.90	1.90	1.90
Prim Side		SLG:	0.01	0.01			Z2: 7.32	Tot:	1.98	1.90	1.90	1.90
NACD:	1.00	LL:	1.64				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01
BB-ESB4-TXR1	4,160	3 Phase:	1.90	4.36	0.28	1.23	Z1: 7.32	3Ph.Sym:	1.90	1.90	1.90	1.90
Prim Side		SLG:	0.01	0.01			Z2: 7.32	Tot:	1.98	1.90	1.90	1.90
NACD:	1.00	LL:	1.64				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01
BB-ESB5-TXR1	4,160	3 Phase:	1.90	4.36	0.28	1.23	Z1: 7.32	3Ph.Sym:	1.90	1.90	1.90	1.90
Prim Side		SLG:	0.01	0.01			Z2: 7.32	Tot:	1.98	1.90	1.90	1.90
NACD:	1.00	LL:	1.64				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01
SUB1 12.5 kV Line	12,470	3 Phase:	3.06	4.88	0.49	2.30	Z1: 1.51	3Ph.Sym:	3.06	3.06	3.06	3.06
Side		SLG:	2.18	3.97			Z2: 1.51	Tot:	3.21	3.06	3.06	3.06
NACD:	0.93	LL:	2.65				Z0: 3.36	SLG Sym:	2.18	2.18	2.18	2.18
LLG Gnd Return kA:	1.688	LLG:	2.83					Tot:	2.26	2.18	2.18	2.18
SUB1 Xmer Prim	12,470	3 Phase:	3.06	4.88	0.49	2.30	Z1: 1.51	3Ph.Sym:	3.06	3.06	3.06	3.06
Side		SLG:	2.18	3.97			Z2: 1.51	Tot:	3.21	3.06	3.06	3.06
NACD:	0.93	LL:	2.65				Z0: 3.36	SLG Sym:	2.18	2.18	2.18	2.18
LLG Gnd Return kA:	1.688	LLG:	2.83					Tot:	2.26	2.18	2.18	2.18
SUB1 Xmer Sec	12,470	3 Phase:	1.68	6.90	0.64	4.24	Z1: 2.76	3Ph.Sym:	1.68	1.68	1.68	1.68
Side		SLG:	0.01	0.01			Z2: 2.76	Tot:	1.86	1.69	1.68	1.68
NACD:	0.85	LL:	1.45				Z0: 926.1	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.46					Tot:	0.01	0.01	0.01	0.01


## Interrupting 3 Phase and Unbalanced

Fault Location	Bus	-	Init Sym I	Fault	Equiv	alent	Seq.		lı	nterruptin	g Fault k	۹
Bus Name	Voltage		kA	X/R	R	+jX	lmp. pu		2 cyc.	3 сус.	5 cyc.	8 сус
SUB1-PDC1	12,470	3 Phase:	1.68	6.85	0.64	4.24	Z1: 2.76	3Ph.Sym:	1.68	1.68	1.68	1.68
	,	SLG:	0.01	0.01			Z2: 2.76	Tot:	1.86	1.69	1.68	1.68
NACD:	0.85	LL:	1.45				Z0: 926.1.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.46					Tot:	0.01	0.01	0.01	0.01
SUB2 12.5 kV Line	12,470	3 Phase:	2.35	2.45	1.16	2.83	Z1: 1.97	3Ph.Sym:	2.35	2.35	2.35	2.35
Side		SLG:	1.64	1.86			Z2: 1.97	Tot:	2.40	2.35	2.35	2.35
NACD:	1.00	LL:	2.04				Z0: 4.58	SLG Sym:	1.64	1.64	1.64	1.64
LLG Gnd Return kA:	1.252	LLG:	2.23					Tot:	1.66	1.64	1.64	1.64
SUB2 Xmer Prim	12,470	3 Phase:	2.35	2.45	1.16	2.83	Z1: 1.97	3Ph.Sym:	2.35	2.35	2.35	2.35
Side		SLG:	1.64	1.85			Z2: 1.97	Tot:	2.40	2.35	2.35	2.35
NACD:	1.00	LL:	2.04				Z0: 4.58	SLG Sym:	1.64	1.64	1.64	1.64
LLG Gnd Return kA:	1.252	LLG:	2.23					Tot:	1.66	1.64	1.64	1.64
SUB2 Xmer Sec	4,160	3 Phase:	1.91	4.57	0.27	1.23	Z1: 7.26	3Ph.Sym:	1.91	1.91	1.91	1.91
Side		SLG:	0.01	0.01			Z2: 7.26	Tot:	2.00	1.91	1.91	1.91
NACD:	1.00	LL:	1.66				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.66					Tot:	0.01	0.01	0.01	0.01
SUB2-PDC1	4,160	3 Phase:	1.90	4.48	0.28	1.23	Z1: 7.29	3Ph.Sym:	1.90	1.90	1.90	1.90
		SLG:	0.01	0.01			Z2: 7.29	Tot:	1.99	1.90	1.90	1.90
NACD:	1.00	LL:	1.65				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01
T-3 Prim Side	4,160	3 Phase:	1.90	4.36	0.28	1.23	Z1: 7.32	3Ph.Sym:	1.90	1.90	1.90	1.90
		SLG:	0.01	0.01			Z2: 7.32	Tot:	1.98	1.90	1.90	1.90
NACD:	1.00	LL:	1.64				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01
T-4 Prim Side	4,160	3 Phase:	1.90	4.36	0.28	1.23	Z1: 7.32	3Ph.Sym:	1.90	1.90	1.90	1.90
		SLG:	0.01	0.01			Z2: 7.32	Tot:	1.98	1.90	1.90	1.90
NACD:	1.00	LL:	1.64				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01
TX-A Prim Side	12,470	3 Phase:	1.67	6.48	0.68	4.25	Z1: 2.77	3Ph.Sym:	1.67	1.67	1.67	1.67
		SLG:	0.01	0.01			Z2: 2.77	Tot:	1.83	1.68	1.67	1.67
NACD:	0.85	LL:	1.45				Z0: 926.18	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.45					Tot:	0.01	0.01	0.01	0.01
TX-B Prim Side	12,470	3 Phase:	1.67	6.62	0.67	4.25	Z1: 2.76	3Ph.Sym:	1.67	1.67	1.67	1.67
		SLG:	0.01	0.01			Z2: 2.76	Tot:	1.84	1.68	1.67	1.67
NACD:	0.85	LL:	1.45				Z0: 926.1'	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.45					Tot:	0.01	0.01	0.01	0.01
TX-E Prim Side	12,470	3 Phase:	1.64	4.90	0.91	4.30	Z1: 2.83	3Ph.Sym:	1.64	1.64	1.64	1.64
		SLG:	0.01	0.01			Z2: 2.83	Tot:	1.71	1.64	1.64	1.64
NACD:	0.85	LL:	1.42				Z0: 926.4		0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.42					Tot:	0.01	0.01	0.01	0.01

## Interrupting 3 Phase and Unbalanced

Fault Location Bus Name	Bus Voltage	Init Sym Fault			Equivalent		Seq.		Interrupting Fault kA			
			kA	X/R	R	+jX	lmp. pu		2 cyc.	3 сус.	5 cyc.	8 cyc.
TX-F Prim Side	12,470	3 Phase:	1.67	6.37	0.70	4.25	Z1: 2.77	3Ph.Sym:	1.67	1.67	1.67	1.67
		SLG:	0.01	0.01			Z2: 2.77	Tot:	1.82	1.67	1.67	1.67
NACD:	0.85	LL:	1.45				Z0: 926.20	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.45					Tot:	0.01	0.01	0.01	0.01
TX-F Sec Side	4,160	3 Phase:	2.26	7.05	0.16	1.05	Z1: 6.14	3Ph.Sym:	2.26	2.26	2.26	2.26
		SLG:	2.61	6.93			Z2: 6.14	Tot:	2.52	2.28	2.26	2.26
NACD:	0.83	LL:	1.96				Z0: 3.65	SLG Sym:	2.61	2.61	2.61	2.61
LLG Gnd Return kA:	3.095	LLG:	2.49					Tot:	2.90	2.64	2.61	2.61





# From Page 1 BB-ESB1-GEN BB-ESB1-TXR1 Nominal kVA 2000 kVA Pri Rated Voltage 12470 V Sec Rated Voltage 600 V Z% 6.00 % BB-ESB1-GEN Bkr P-ESB1-TRS **Burnaby Terminal** P-ESB1-GEN **Substation 1 Equipment - Page 3 of 4 Short Circuit Analysis** BB-ESB1-TRS \*\*\* None of Jet Fuel Pumps is Running \*\*\* P-ESB1-MCC ESB1-MCC MAIN Bkr Line side ANSI Sym 3P LV 22.1 kA ESB1-MCC MAIN Bkr Int Duty 22.1 kA Int Rating 65.0 kA BB-ESB1-MCC ANSI Sym 3P LV 22.1 kA BPM-31 Bkr BPM-11 Bkr BPM-21 Bkr ESB1-AHU Bkr Int Duty 22.1 kA ESB1-LP1 Bkr Int Duty 22.1 kA Int Rating 35.0 kA Int Duty 22.1 kA Int Rating 35.0 kA Int Duty 22.1 kA Int Rating 25.0 kA Int Duty 22.1 kA Int Rating 25.0 kA Int Rating 35.0 kA P-ESB1-VFD11 P-ESB1-VFD21 P-ESB1-VFD31 <sup>▶</sup> P-ESB1-LP1 P-ESB1-AHU BB-ESB1-MCC<50HP BB-ESB1-VFD31 Line Side ANSI Sym 3P LV 19.7 kA BB-ESB1-VFD11 Line Side BB-ESB1-VFD21 Line Side ANSI Sym 3P LV 19.7 kA ANSI Sym 3P LV 19.7 kA BB-ESB1-VFD31 BB-ESB1-VFD11 BB-ESB1-VFD21 ESB1-LP1 ESB1-AHU P-BPM-11 ≥ P-BPM-21 P-BPM-31 → BPM-11 → BPM-21 → BPM-31

Project: Burnaby Terminal Kinder Morgan Burnaby Terminal Power System Study

# ANSI Complete Fault Report None of Jet Fuel Pumps is Running

## A\_FAULT Settings

Fault Type	3 Phase+Unbalanced	LV Duty	Yes	Int Duty	Yes
Faulted Bus	All Buses	LV Report	Complete	Int Report	Complete
Include Tap	No	<b>Mom Duty</b>	Yes	<b>Solution Method</b>	E/Z
Pre-fault Voltage	1.0000	Mom Report	Complete	NACD Option	Interpolated

#### Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Fau	It Duty	X/R	Asym	ı kA	Seq	uence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impeda	nce pu	R	+ <i>j</i> X
02-MAIN	12,470	3 Phase:	2.18	47.0	6.09	2.85	2.52	Z1:	2.13	0.56	3.26
SERVICE SWGR		SLG:	0.01	0.2	0.01	0.01		Z2:	2.13		
		LL:	1.88	23.5				Z0:	926.16		
LLG Gnd Return kA:	0.007	LLG:	1.89	23.5							
5KV SWGR	4,160	3 Phase:	2.39	17.2	6.03	3.12	2.77	Z1:	5.81	0.17	0.99
		SLG:	2.71	11.3	6.04	3.55		Z2:	5.81		
		LL:	2.07	8.6				Z0:	3.71		
LLG Gnd Return kA:	3.147	LLG:	2.60	10.8							
BB-ESB1-MCC	600	3 Phase:	22.74	23.6	4.58	27.92	25.40	Z1:	4.23	0.00	0.01
		SLG:	20.26	12.2	2.17	21.35		Z2:	4.23		
		LL:	19.69	11.8				Z0:	6.23		
LLG Gnd Return kA:	17.705	LLG:	24.38	14.6							
BB-ESB1-TXR1	12,470	3 Phase:	2.18	47.0	6.09	2.85	2.53	Z1:	2.13	0.56	3.26
Prim Side		SLG:	0.01	0.2	0.01	0.01		Z2:	2.13		
		LL:	1.89	23.5				Z0:	926.16		
LLG Gnd Return kA:	0.007	LLG:	1.89	23.6							
BB-ESB1-TXR1	600	3 Phase:	24.46	25.4	6.19	32.12	28.43	Z1:	3.93	0.00	0.01
Sec Side		SLG:	26.56	15.9	6.46	35.20		Z2:	3.93		
		LL:	21.18	12.7				Z0:	3.00		
LLG Gnd Return kA:	29.062	LLG:	25.44	15.3							
BB-ESB1-VFD11	600	3 Phase:	22.33	23.2	4.32	27.05	24.75	Z1:	4.31	0.00	0.02
Line Side		SLG:	19.50	11.7	2.02	20.34		Z2:	4.31		
		LL:	19.34	11.6				Z0:	6.70		
LLG Gnd Return kA:	16.719	LLG:	23.85	14.3							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Seq	uence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impedar	nce pu	R	+ <i>j</i> X
BB-ESB1-VFD21	600	3 Phase:	22.33	23.2	4.32	27.05	24.75	Z1:	4.31	0.00	0.02
Line Side		SLG:	19.50	11.7	2.02	20.34		Z2:	4.31		
		LL:	19.34	11.6				Z0:	6.70		
LLG Gnd Return kA:	16.719	LLG:	23.85	14.3							
BB-ESB1-VFD31	600	3 Phase:	22.33	23.2	4.32	27.05	24.75	Z1:	4.31	0.00	0.02
Line Side		SLG:	19.50	11.7	2.02	20.34		Z2:	4.31		
		LL:	19.34	11.6				Z0:	6.70		
LLG Gnd Return kA:	16.719	LLG:	23.85	14.3							
BB-ESB2A	600	3 Phase:	21.64	22.5	3.31	24.66	23.18	Z1:	4.45	0.01	0.02
		SLG:	17.22	10.3	1.51	17.49		Z2:	4.45		
		LL:	18.74	11.2				Z0:	8.49		
LLG Gnd Return kA:	13.789	LLG:	22.49	13.5							
BB-ESB2-MCC	600	3 Phase:	23.81	24.7	4.74	29.46	26.71	Z1:	4.04	0.00	0.01
		SLG:	20.82	12.5	2.15	21.92		Z2:	4.04		
		LL:	20.62	12.4				Z0:	6.23		
LLG Gnd Return kA:	17.909	LLG:	25.38	15.2							
BB-ESB2-TXR1	12,470	3 Phase:	2.18	47.0	6.10	2.85	2.53	Z1:	2.13	0.56	3.26
Prim Side		SLG:	0.01	0.2	0.01	0.01		Z2:	2.13		
		LL:	1.89	23.5				Z0:	926.16		
LLG Gnd Return kA:	0.007	LLG:	1.89	23.6							
BB-ESB2-TXR1	600	3 Phase:	25.37	26.4	6.13	33.25	29.45	Z1:	3.79	0.00	0.01
Sec Side		SLG:	27.28	16.4	6.42	36.10		Z2:	3.79		
		LL:	21.97	13.2				Z0:	3.00		
LLG Gnd Return kA:	29.484	LLG:	26.19	15.7							
BB-ESB2-VFD12	600	3 Phase:	23.37	24.3	4.44	28.48	25.99	Z1:	4.12	0.00	0.01
Line Side		SLG:	20.01	12.0	2.00	20.86		Z2:	4.12		
		LL:	20.23	12.1				Z0:	6.70		
LLG Gnd Return kA:	16.898	LLG:	24.80	14.9							
BB-ESB2-VFD22	600	3 Phase:	23.37	24.3	4.44	28.48	25.99	Z1:	4.12	0.00	0.01
Line Side		SLG:	20.01	12.0	2.00	20.86		Z2:	4.12		
		LL:	20.23	12.1				Z0:	6.70		
LLG Gnd Return kA:	16.898	LLG:	24.80	14.9							
BB-ESB2-VFD32	600	3 Phase:	23.37	24.3	4.44	28.48	25.99	Z1:	4.12	0.00	0.01
Line Side		SLG:	20.01	12.0	2.00	20.86		Z2:	4.12		
		LL:	20.23	12.1				Z0:	6.70		
LLG Gnd Return kA:	16.898	LLG:	24.80	14.9							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	kA	Sec	quence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impeda	nce pu	R	+ <i>j</i> X
BB-ESB3A-MCC	600	3 Phase:	6.19	6.4	2.78	6.80	6.50	Z1:	15.55	0.02	0.05
		SLG:	5.72	3.4	1.72	5.87		Z2:	15.55		
		LL:	5.36	3.2				Z0:	20.50		
LLG Gnd Return kA:	5.200	LLG:	6.64	4.0							
BB-ESB3A-MCC	600	3 Phase:	6.48	6.7	3.28	7.37	6.93	Z1:	14.85	0.02	0.05
Main Bkr LineSide		SLG:	6.27	3.8	2.10	6.58		Z2:	14.85		
		LL:	5.61	3.4				Z0:	17.15		
LLG Gnd Return kA:	5.965	LLG:	7.02	4.2							
BB-ESB3B-MCC	600	3 Phase:	6.49	6.7	3.34	7.41	6.96	Z1:	14.83	0.02	0.05
		SLG:	6.27	3.8	2.12	6.59		Z2:	14.83		
		LL:	5.62	3.4				Z0:	17.15		
LLG Gnd Return kA:	5.968	LLG:	7.03	4.2							
BB-ESB3B-MCC	600	3 Phase:	6.49	6.7	3.34	7.41	6.96	Z1:	14.83	0.02	0.05
Main Bkr LineSide		SLG:	6.27	3.8	2.12	6.59		Z2:	14.83		
		LL:	5.62	3.4				Z0:	17.15		
LLG Gnd Return kA:	5.968	LLG:	7.03	4.2							
BB-ESB3-MCC	600	3 Phase:	6.78	7.0	4.12	8.12	7.47	Z1:	14.20	0.01	0.05
		SLG:	6.87	4.1	2.80	7.56		Z2:	14.20		
		LL:	5.87	3.5				Z0:	14.06		
LLG Gnd Return kA:	6.890	LLG:	7.37	4.4							
BB-ESB3-TXR1	4,160	3 Phase:	2.33	16.8	4.50	2.85	2.59	Z1:	5.96	0.23	1.01
Prim Side		SLG:	0.01	0.1	0.01	0.01		Z2:	5.96		
		LL:	2.02	8.4				Z0:	2,776.83		
LLG Gnd Return kA:	0.007	LLG:	2.02	8.4							
BB-ESB3-TXR1	600	3 Phase:	7.11	7.4	4.81	8.83	8.00	Z1:	13.53	0.01	0.05
Sec Side		SLG:	7.79	4.7	4.78	9.66		Z2:	13.53		
		LL:	6.16	3.7				Z0:	10.00		
LLG Gnd Return kA:	8.610	LLG:	7.51	4.5							
BB-ESB4-MCC	600	3 Phase:	1.88	2.0	3.43	2.16	2.02	Z1:	51.20	0.07	0.17
		SLG:	1.72	1.0	2.13	1.81		Z2:	51.20		
		LL:	1.63	1.0				Z0:	67.40		
LLG Gnd Return kA:	1.566	LLG:	1.95	1.2							
BB-ESB4-TXR1	4,160	3 Phase:	2.33	16.8	4.48	2.84	2.59	Z1:	5.97	0.23	1.01
Prim Side	, - •	SLG:	0.01	0.1	0.01	0.01		Z2:	5.97		
		LL:	2.01	8.4				Z0:	2,776.83		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Sec	quence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impeda	nce pu	R	+ <i>j</i> X
BB-ESB4-TXR1	600	3 Phase:	2.02	2.1	4.06	2.42	2.22	Z1:	47.57	0.04	0.17
Sec Side		SLG:	1.99	1.2	3.77	2.34		Z2:	47.57		
		LL:	1.75	1.1				Z0:	50.00		
LLG Gnd Return kA:	1.956	LLG:	2.02	1.2							
BB-ESB5A-MCC	600	3 Phase:	5.50	5.7	2.12	5.78	5.64	Z1:	17.50	0.03	0.05
		SLG:	4.42	2.7	1.06	4.43		Z2:	17.50		
		LL:	4.76	2.9				Z0:	32.72		
LLG Gnd Return kA:	3.564	LLG:	5.73	3.4							
BB-ESB5B-MCC	600	3 Phase:	5.54	5.8	2.27	5.87	5.71	Z1:	17.38	0.03	0.05
		SLG:	4.44	2.7	1.09	4.45		Z2:	17.38		
		LL:	4.79	2.9				Z0:	32.72		
LLG Gnd Return kA:	3.572	LLG:	5.77	3.5							
BB-ESB5C-MCC	600	3 Phase:	5.54	5.8	2.27	5.87	5.71	Z1:	17.38	0.03	0.05
		SLG:	4.44	2.7	1.09	4.45		Z2:	17.38		
		LL:	4.79	2.9				Z0:	32.72		
LLG Gnd Return kA:	3.572	LLG:	5.77	3.5							
BB-ESB5-MCC	600	3 Phase:	6.03	6.3	2.61	6.55	6.29	Z1:	15.96	0.03	0.05
		SLG:	5.22	3.1	1.28	5.26		Z2:	15.96		
		LL:	5.22	3.1				Z0:	25.55		
LLG Gnd Return kA:	4.425	LLG:	6.45	3.9							
BB-ESB5-TXR1	4,160	3 Phase:	2.33	16.8	4.50	2.85	2.59	Z1:	5.96	0.23	1.01
Prim Side		SLG:	0.01	0.1	0.01	0.01		Z2:	5.96		
		LL:	2.02	8.4				Z0:	2,776.83		
LLG Gnd Return kA:	0.007	LLG:	2.02	8.4							
BB-ESB5-TXR1	600	3 Phase:	7.15	7.4	4.52	8.75	7.97	Z1:	13.47	0.01	0.05
Sec Side		SLG:	7.82	4.7	4.56	9.59		Z2:	13.47		
		LL:	6.19	3.7				Z0:	10.00		
LLG Gnd Return kA:	8.626	LLG:	7.51	4.5							
BB-LC3A-MCC	480	3 Phase:	6.86	5.7	2.44	7.36	7.11	Z1:	17.53	0.02	0.04
		SLG:	6.69	3.2	1.66	6.85		Z2:	17.53		
		LL:	5.94	2.9				Z0:	19.89		
LLG Gnd Return kA:	6.409	LLG:	7.50	3.6							
BB-LC4A-MCC	480	3 Phase:	5.84	4.9	1.85	6.04	5.94	Z1:	20.58	0.02	0.04
		SLG:	5.11	2.5	1.20	5.13		Z2:	20.58		
		LL:	5.06	2.4				Z0:	31.14		
LLG Gnd Return kA:	4.432	LLG:	6.14	2.9							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	kA	Se	equence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Imped	ance pu	R	+ <i>j</i> X
CDP PANEL A	480	3 Phase:	7.85	6.5	1.27	7.91	7.88	Z1:	15.31	0.02	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	15.31		
		LL:	6.80	3.3				Z0:	180,046.70		
LLG Gnd Return kA:	0.001	LLG:	6.80	3.3							
CDP PANEL AX	480	3 Phase:	6.23	5.2	1.05	6.24	6.24	Z1:	19.31	0.03	0.03
(CTRL RM BLDG)		SLG:	0.00	0.0	0.03	0.00		Z2:	19.31		
		LL:	5.39	2.6				Z0:	180,053.80		
LLG Gnd Return kA:	0.001	LLG:	5.39	2.6							
CDP PANEL BX	480	3 Phase:	7.36	6.1	2.58	7.98	7.67	Z1:	16.35	0.02	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	16.35		
		LL:	6.37	3.1				Z0:	180,052.30		
LLG Gnd Return kA:	0.001	LLG:	6.37	3.1							
CDP PANEL	480	3 Phase:	4.79	4.0	0.57	4.79	4.79	Z1:	25.10	0.05	0.03
SB-A1		SLG:	0.00	0.0	0.03	0.00		Z2:	25.10		
		LL:	4.15	2.0				Z0:	180,066.20		
LLG Gnd Return kA:	0.001	LLG:	4.15	2.0					,		
DIV. OFFICE	480	3 Phase:	1.80	1.5	0.53	1.80	1.80	Z1:	66.82	0.14	0.07
BASEMENT		SLG:	0.00	0.0	0.03	0.00		Z2:	66.82		
		LL:	1.56	0.7					180,128.50		
LLG Gnd Return kA:	0.001	LLG:	1.56	0.7					,		
ESB2A-MCC	600	3 Phase:	21.64	22.5	3.31	24.66	23.18	Z1:	4.45	0.01	0.02
MAIN Bkr Line	000	SLG:	17.22	10.3	1.51	17.49		Z2:	4.45		
		LL:	18.74	11.2				Z0:	8.49		
LLG Gnd Return kA:	13.789	LLG:	22.49	13.5				20.	0		
ESB2-MCC MAIN	600	3 Phase:	23.81	24.7	4.74	29.46	26.72	Z1:	4.04	0.00	0.01
Bkr Line side	000	SLG:	20.82	12.5	2.15	21.92		Z2:	4.04		
		LL:	20.62	12.4				Z0:	6.23		
LLG Gnd Return kA:	17.915	LLG:	25.38	15.2				20.	0.23		
ESB3-MCC MAIN	600	3 Phase:	6.78	7.0	4.12	8.12	7.47	Z1:	14.20	0.01	0.05
Bkr Line Side	000	SLG:	6.87	4.1	2.80	7.56		Z2:	14.20	0.01	
		LL:	5.87	3.5	2.00	7.50		Z0:	14.06		
LLG Gnd Return kA:	6.890	LLG:	7.37	4.4				20.	17.00		
ESB4-MCC MAIN	600	3 Phase:	1.88	2.0	3.43	2.16	2.02	Z1:	51.20	0.07	0.17
Bkr Line Side	000	SLG:	1.72	1.0	2.13	1.81	2.02	Z1: Z2:	51.20	0.07	0.17
		SLG: LL:	1.72	1.0					67.36		
LLG Gnd Return kA:	1 566							Z0:	07.30		
LLO Oliu Ketulli KA:	1.566	LLG:	1.95	1.2							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	It Duty	X/R	Asym	ı kA	Sec	uence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impeda	nce pu	R	+ <i>j</i> X
ESB5A-MCC	600	3 Phase:	5.51	5.7	2.12	5.79	5.65	Z1:	17.47	0.03	0.05
MAIN Bkr Line		SLG:	4.43	2.7	1.07	4.44		Z2:	17.47		
		LL:	4.77	2.9				Z0:	32.61		
LLG Gnd Return kA:	3.575	LLG:	5.74	3.4							
ESB5B-MCC	600	3 Phase:	5.54	5.8	2.27	5.88	5.71	Z1:	17.36	0.03	0.05
MAIN Bkr Line		SLG:	4.45	2.7	1.09	4.47		Z2:	17.36		
		LL:	4.80	2.9				Z0:	32.61		
LLG Gnd Return kA:	3.583	LLG:	5.78	3.5							
ESB5C-MCC	600	3 Phase:	5.54	5.8	2.27	5.88	5.71	Z1:	17.36	0.03	0.05
MAIN Bkr Line		SLG:	4.45	2.7	1.09	4.47		Z2:	17.36		
		LL:	4.80	2.9				Z0:	32.61		
LLG Gnd Return kA:	3.583	LLG:	5.78	3.5							
ESB5-MCC MAIN	600	3 Phase:	6.03	6.3	2.61	6.55	6.29	Z1:	15.95	0.03	0.05
Bkr Line Side		SLG:	5.22	3.1	1.28	5.26		Z2:	15.95		
		LL:	5.22	3.1				Z0:	25.53		
LLG Gnd Return kA:	4.427	LLG:	6.45	3.9							
LC3A-MCC MAIN	480	3 Phase:	6.86	5.7	2.44	7.36	7.11	Z1:	17.53	0.02	0.04
Bkr Line Side		SLG:	6.69	3.2	1.66	6.85		Z2:	17.53		
		LL:	5.94	2.9				Z0:	19.89		
LLG Gnd Return kA:	6.409	LLG:	7.50	3.6							
LC4A-MCC MAIN	480	3 Phase:	6.69	5.6	2.48	7.20	6.95	Z1:	17.97	0.02	0.04
Bkr Line Side		SLG:	6.55	3.1	1.73	6.72		Z2:	17.97		
		LL:	5.80	2.8				Z0:	20.06		
LLG Gnd Return kA:	6.308	LLG:	7.28	3.5							
LEVEE BUILDING	480	3 Phase:	0.92	0.8	0.34	0.92	0.92	Z1:	130.60	0.29	0.09
		SLG:	0.00	0.0	0.03	0.00		Z2:	130.60		
		LL:	0.80	0.4				Z0: 1	180,234.30		
LLG Gnd Return kA:	0.001	LLG:	0.80	0.4							
MCC LC-3	480	3 Phase:	7.86	6.5	4.44	9.58	8.74	Z1:	15.30	0.01	0.03
<del>-</del>		SLG:	8.77	4.2	4.12	10.51		Z2:	15.30		
		LL:	6.81	3.3				Z0:	10.53		
LLG Gnd Return kA:	9.926	LLG:	8.56	4.1							
MCC LC-4	480	3 Phase:	7.63	6.3	4.41	9.29	8.48	Z1:	15.76	0.01	0.04
		SLG:	8.48	4.1	4.33	10.28		Z2:	15.76		
		LL:	6.61	3.2				Z0:	11.03		
			5.01	٥.2				20.	11.00		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Se	equence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Imped	ance pu	R	+ <i>j</i> X
MCC-A	480	3 Phase:	13.65	11.3	4.43	16.63	15.18	Z1:	8.81	0.00	0.02
		SLG:	0.00	0.0	0.03	0.00		Z2:	8.81		
		LL:	11.82	5.7				Z0:	180,034.80		
LLG Gnd Return kA:	0.001	LLG:	11.82	5.7							
MCC-A MAIN Line	480	3 Phase:	14.20	11.8	4.79	17.61	15.95	Z1:	8.47	0.00	0.02
Side		SLG:	0.00	0.0	0.03	0.00		Z2:	8.47		
		LL:	12.30	5.9				Z0:	180,034.00		
LLG Gnd Return kA:	0.001	LLG:	12.30	5.9							
MCC-AX	480	3 Phase:	12.06	10.0	2.97	13.44	12.76	Z1:	9.97	0.01	0.02
		SLG:	0.00	0.0	0.03	0.00		Z2:	9.97		
		LL:	10.45	5.0				Z0:	180,037.90		
LLG Gnd Return kA:	0.001	LLG:	10.45	5.0							
МСС-В	480	3 Phase:	13.54	11.3	5.27	17.17	15.41	Z1:	8.88	0.00	0.02
		SLG:	0.00	0.0	0.02	0.00		Z2:	8.88		
		LL:	11.73	5.6				Z0:	182,361.00		
LLG Gnd Return kA:	0.001	LLG:	11.73	5.6							
MCC-B MAIN Line	480	3 Phase:	13.54	11.3	5.27	17.17	15.41	Z1:	8.88	0.00	0.02
Side		SLG:	0.00	0.0	0.02	0.00		Z2:	8.88		
		LL:	11.73	5.6				Z0:	182,361.00		
LLG Gnd Return kA:	0.001	LLG:	11.73	5.6							
MCC-DX	480	3 Phase:	6.64	5.5	2.27	7.05	6.85	Z1:	18.11	0.03	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	18.11		
		LL:	5.75	2.8				Z0:	180,056.40		
LLG Gnd Return kA:	0.001	LLG:	5.75	2.8					,		
МСС-Е	480	3 Phase:	9.96	8.3	3.97	11.84	10.92	Z1:	12.07	0.01	0.03
		SLG:	10.22	4.9	3.90	12.09		Z2:	12.07		
		LL:	8.63	4.1				Z0:	11.18		
LLG Gnd Return kA:	10.480	LLG:	10.12	4.9							
MCC-E MAIN Line	480	3 Phase:	9.96	8.3	3.97	11.84	10.92	Z1:	12.07	0.01	0.03
Side	.00	SLG:	10.22	4.9	3.90	12.09		Z2:	12.07		
		LL:	8.63	4.1				Z0:	11.18		
LLG Gnd Return kA:	10.480	LLG:	10.12	4.9				20.	11.10		
MCC-EX	480	3 Phase:	0.63	0.5	0.40	0.63	0.63	Z1:	192.41	0.41	0.16
2.1	-100	SLG:	0.00	0.0	0.03	0.00	0.03	Z2:	192.41		
		LL:	0.54	0.3	0.03	0.00			180,316.90		
		LL.	U.JT	0.5				<b>L</b> U.	100,510.70		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Se	equence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Imped	ance pu	R	+ <i>j</i> X
MCC-EX Line Side	480	3 Phase:	1.21	1.0	0.44	1.21	1.21	Z1:	99.62	0.21	0.09
		SLG:	0.00	0.0	0.03	0.00		Z2:	99.62		
		LL:	1.05	0.5				Z0:	180,177.40		
LLG Gnd Return kA:	0.001	LLG:	1.05	0.5							
MCC-F	480	3 Phase:	9.71	8.1	1.79	10.00	9.86	Z1:	12.38	0.01	0.02
		SLG:	0.00	0.0	0.03	0.00		Z2:	12.38		
		LL:	8.41	4.0				Z0:	180,041.40		
LLG Gnd Return kA:	0.001	LLG:	8.41	4.0							
MCC-LC-3 MAIN	480	3 Phase:	7.94	6.6	4.55	9.73	8.86	Z1:	15.15	0.01	0.03
BK Line Side		SLG:	8.94	4.3	4.26	10.79		Z2:	15.15		
		LL:	6.88	3.3				Z0:	10.09		
LLG Gnd Return kA:	10.215	LLG:	8.69	4.2							
MCC-LC-4 MAIN	480	3 Phase:	7.70	6.4	4.52	9.43	8.59	Z1:	15.61	0.01	0.04
BK Line Side		SLG:	8.63	4.1	4.48	10.54		Z2:	15.61		
		LL:	6.67	3.2				Z0:	10.59		
LLG Gnd Return kA:	9.807	LLG:	8.29	4.0							
MECH SHOP	480	3 Phase:	8.39	7.0	2.31	8.93	8.66	Z1:	14.33	0.01	0.03
PANEL		SLG:	8.05	3.9	2.19	8.49		Z2:	14.33		
		LL:	7.27	3.5				Z0:	16.18		
LLG Gnd Return kA:	7.731	LLG:	8.35	4.0							
PDP #1	480	3 Phase:	6.58	5.5	1.84	6.79	6.69	Z1:	18.29	0.03	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	18.29		
		LL:	5.70	2.7				Z0:	180,056.40		
LLG Gnd Return kA:	0.001	LLG:	5.70	2.7					,		
PDP #3	480	3 Phase:	7.09	5.9	2.33	7.56	7.33	Z1:	16.96	0.02	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	16.96		
		LL:	6.14	2.9				Z0:	180,053.60		
LLG Gnd Return kA:	0.001	LLG:	6.14	2.9					,		
PDP #4	480	3 Phase:	7.04	5.9	2.29	7.48	7.26	Z1:	17.08	0.02	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	17.08		
		LL:	6.10	2.9					180,053.90		
LLG Gnd Return kA:	0.001	LLG:	6.10	2.9							
PDP #5	480	3 Phase:	7.09	5.9	2.28	7.52	7.31	Z1:	16.97	0.02	0.03
121 110	400	SLG:	0.00	0.0	0.03	0.00	7.51	Z2:	16.97	0.02	
		LL:	6.14	2.9		0.00			180,053.60		
		LL.	0.17	2.)				۷٠.	100,033.00		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	It Duty	X/R	Asym	ı kA	Se	equence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Imped	ance pu	R	+ <i>j</i> X
PDP #6	480	3 Phase:	7.27	6.0	2.47	7.83	7.55	Z1:	16.54	0.02	0.03
		SLG:	0.00	0.0	0.03	0.00		Z2:	16.54		
		LL:	6.30	3.0				Z0:	180,052.70		
LLG Gnd Return kA:	0.001	LLG:	6.30	3.0							
PLM SHOP MCC	480	3 Phase:	8.42	7.0	2.38	9.00	8.71	Z1:	14.29	0.01	0.03
		SLG:	8.06	3.9	2.23	8.53		Z2:	14.29		
		LL:	7.29	3.5				Z0:	16.18		
LLG Gnd Return kA:	7.738	LLG:	8.38	4.0							
SUB1 12.5 kV Line	12,470	3 Phase:	3.43	74.0	4.91	4.28	3.86	Z1:	1.35	0.43	2.06
Side		SLG:	2.29	28.6	3.94	2.72		Z2:	1.35		
		LL:	2.97	37.0				Z0:	3.36		
LLG Gnd Return kA:	1.722	LLG:	3.15	39.2							
SUB1 Xmer Prim	12,470	3 Phase:	3.43	74.0	4.91	4.28	3.86	Z1:	1.35	0.43	2.06
Side	,	SLG:	2.29	28.6	3.94	2.72		Z2:	1.35		
		LL:	2.97	37.0				Z0:	3.36		
LLG Gnd Return kA:	1.722	LLG:	3.15	39.2							
SUB1 Xmer Sec	12,470	3 Phase:	2.18	47.1	6.31	2.88	2.54	Z1:	2.12	0.54	3.26
Side		SLG:	0.01	0.2	0.01	0.01		Z2:	2.12		
		LL:	1.89	23.6				Z0:	926.11		
LLG Gnd Return kA:	0.007	LLG:	1.89	23.6							
SUB1-PDC1	12,470	3 Phase:	2.18	47.1	6.28	2.87	2.54	Z1:	2.12	0.54	3.26
		SLG:	0.01	0.2	0.01	0.01		Z2:	2.12		
		LL:	1.89	23.5				Z0:	926.13		
LLG Gnd Return kA:	0.007	LLG:	1.89	23.6							
SUB2 12.5 kV Line	12,470	3 Phase:	2.47	53.4	2.59	2.68	2.58	Z1:	1.87	1.08	2.70
Side		SLG:	1.68	20.9	1.88	1.74		Z2:	1.87		
		LL:	2.14	26.7				Z0:	4.58		
LLG Gnd Return kA:	1.263	LLG:	2.34	29.1							
SUB2 Xmer Prim	12,470	3 Phase:	2.47	53.4	2.59	2.68	2.58	Z1:	1.87	1.08	2.70
Side		SLG:	1.68	20.9	1.88	1.74		Z2:	1.87		
		LL:	2.14	26.7				Z0:	4.58		
LLG Gnd Return kA:	1.263	LLG:	2.34	29.1							
SUB2 Xmer Sec	4,160	3 Phase:	2.34	16.9	4.71	2.90	2.63	Z1:	5.92	0.22	1.00
Side	,	SLG:	0.01	0.1	0.01	0.01		Z2:	5.92		
		LL:	2.03	8.4				Z0:	2,776.53		
LLG Gnd Return kA:	0.007	LLG:	2.03	8.5					,		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Sec	quence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impeda	nce pu	R	+ <i>j</i> X
SUB2-PDC1	4,160	3 Phase:	2.34	16.8	4.63	2.88	2.62	Z1:	5.94	0.22	1.00
		SLG:	0.01	0.1	0.01	0.01		Z2:	5.94		
		LL:	2.02	8.4				Z0:	2,776.68		
LLG Gnd Return kA:	0.007	LLG:	2.03	8.4							
T-3 Prim Side	4,160	3 Phase:	2.33	16.8	4.48	2.84	2.59	Z1:	5.97	0.23	1.01
		SLG:	0.01	0.1	0.01	0.01		Z2:	5.97		
		LL:	2.01	8.4				Z0:	2,776.83		
LLG Gnd Return kA:	0.007	LLG:	2.02	8.4							
T-3 Sec Side	480	3 Phase:	8.01	6.7	4.69	9.88	8.97	Z1:	15.02	0.01	0.03
		SLG:	9.10	4.4	4.69	11.24		Z2:	15.02		
		LL:	6.94	3.3				Z0:	9.60		
LLG Gnd Return kA:	10.545	LLG:	8.70	4.2							
T-4 Prim Side	4,160	3 Phase:	2.33	16.8	4.48	2.84	2.59	Z1:	5.97	0.23	1.01
		SLG:	0.01	0.1	0.01	0.01		Z2:	5.97		
		LL:	2.01	8.4				Z0:	2,776.83		
LLG Gnd Return kA:	0.007	LLG:	2.02	8.4					,		
T-4 Sec Side	480	3 Phase:	7.81	6.5	4.68	9.64	8.75	Z1:	15.39	0.01	0.03
		SLG:	8.85	4.2	4.69	10.92		Z2:	15.39		
		LL:	6.77	3.2				Z0:	10.00		
LLG Gnd Return kA:	10.195	LLG:	8.46	4.1							
TK71 MAIN BK	480	3 Phase:	2.91	2.4	1.02	2.92	2.91	Z1:	41.34	0.07	0.07
Line Side		SLG:	2.47	1.2	1.03	2.48		Z2:	41.34		
		LL:	2.52	1.2				Z0:	63.36		
LLG Gnd Return kA:	2.147	LLG:	2.72	1.3							
TK71 MCC	480	3 Phase:	2.91	2.4	1.02	2.92	2.91	Z1:	41.34	0.07	0.07
		SLG:	2.47	1.2	1.03	2.48		Z2:	41.34		
		LL:	2.52	1.2				Z0:	63.36		
LLG Gnd Return kA:	2.147	LLG:	2.72	1.3							
TK72 MAIN BK	480	3 Phase:	2.77	2.3	0.79	2.77	2.77	Z1:	43.39	0.08	0.06
Line Side		SLG:	2.37	1.1	0.76	2.37		Z2:	43.39		
		LL:	2.40	1.2				Z0:	65.50		
LLG Gnd Return kA:	2.069	LLG:	2.63	1.3							
TK72 MCC	480	3 Phase:	2.77	2.3	0.79	2.77	2.77	Z1:	43.39	0.08	0.06
50	.03	SLG:	2.37	1.1	0.76	2.37		Z2:	43.39		
		LL:	2.40	1.2				Z0:	65.50		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Fau	It Duty	X/R	Asym	ı kA	Seq	uence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impedan	ce pu	R	+ <i>j</i> X
TK73 MAIN BK	480	3 Phase:	2.83	2.4	1.43	2.86	2.85	Z1:	42.53	0.06	0.08
Line Side		SLG:	2.33	1.1	1.51	2.36		Z2:	42.53		
		LL:	2.45	1.2				Z0:	70.07		
LLG Gnd Return kA:	1.976	LLG:	2.59	1.2							
TK73 MCC	480	3 Phase:	2.83	2.4	1.43	2.86	2.85	Z1:	42.53	0.06	0.08
		SLG:	2.33	1.1	1.51	2.36		Z2:	42.53		
		LL:	2.45	1.2				Z0:	70.07		
LLG Gnd Return kA:	1.976	LLG:	2.59	1.2							
TK74 MAIN BK	480	3 Phase:	2.32	1.9	0.88	2.32	2.32	Z1:	51.89	0.09	0.08
Line Side		SLG:	1.92	0.9	0.92	1.93		Z2:	51.89		
		LL:	2.01	1.0				Z0:	83.77		
LLG Gnd Return kA:	1.645	LLG:	2.14	1.0							
TK74 MCC	480	3 Phase:	2.32	1.9	0.88	2.32	2.32	Z1:	51.89	0.09	0.08
		SLG:	1.92	0.9	0.92	1.93		Z2:	51.89		
		LL:	2.01	1.0				Z0:	83.77		
LLG Gnd Return kA:	1.645	LLG:	2.14	1.0							
TK81 MAIN BK	480	3 Phase:	2.91	2.4	0.80	2.92	2.92	Z1:	41.27	0.07	0.06
Line Side		SLG:	2.52	1.2	0.78	2.52		Z2:	41.27		
		LL:	2.52	1.2				Z0:	60.81		
LLG Gnd Return kA:	2.215	LLG:	2.77	1.3							
TK81 MCC	480	3 Phase:	2.91	2.4	0.80	2.92	2.92	Z1:	41.27	0.07	0.06
		SLG:	2.52	1.2	0.78	2.52		Z2:	41.27		
		LL:	2.52	1.2				Z0:	60.81		
LLG Gnd Return kA:	2.215	LLG:	2.77	1.3							
TK82 MAIN BK	480	3 Phase:	3.14	2.6	0.83	3.14	3.14	Z1:	38.26	0.07	0.06
Line Side		SLG:	2.72	1.3	0.79	2.72		Z2:	38.26		
		LL:	2.72	1.3				Z0:	55.98		
LLG Gnd Return kA:	2.402	LLG:	3.01	1.4							
TK82 MCC	480	3 Phase:	3.14	2.6	0.83	3.14	3.14	Z1:	38.26	0.07	0.06
		SLG:	2.72	1.3	0.79	2.72		Z2:	38.26		
		LL:	2.72	1.3				Z0:	55.98		
LLG Gnd Return kA:	2.402	LLG:	3.01	1.4							
TK83 MAIN BK	480	3 Phase:	3.94	3.3	0.82	3.94	3.94	Z1:	30.53	0.05	0.04
Line side		SLG:	3.57	1.7	0.73	3.57		Z2:	30.53		
		LL:	3.41	1.6				Z0:	40.32		
LLG Gnd Return kA:	3.253	LLG:	3.93	1.9							

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	kA	Seq	uence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Impedan	ice pu	R	+ <i>j</i> X
TK83 MCC	480	3 Phase:	3.94	3.3	0.82	3.94	3.94	Z1:	30.53	0.05	0.04
		SLG:	3.57	1.7	0.73	3.57		Z2:	30.53		
		LL:	3.41	1.6				Z0:	40.32		
LLG Gnd Return kA:	3.253	LLG:	3.93	1.9							
TK84 MAIN BK	480	3 Phase:	4.78	4.0	1.00	4.79	4.78	Z1:	25.16	0.04	0.04
Line Side		SLG:	4.45	2.1	0.86	4.45		Z2:	25.16		
		LL:	4.14	2.0				Z0:	31.15		
LLG Gnd Return kA:	4.142	LLG:	4.88	2.3							
TK84 MCC	480	3 Phase:	4.78	4.0	1.00	4.79	4.78	Z1:	25.16	0.04	0.04
		SLG:	4.45	2.1	0.86	4.45		Z2:	25.16		
		LL:	4.14	2.0				Z0:	31.15		
LLG Gnd Return kA:	4.142	LLG:	4.88	2.3							
TK85 MAIN BK	480	3 Phase:	6.37	5.3	1.81	6.57	6.47	Z1:	18.87	0.02	0.04
Line Side		SLG:	6.52	3.1	1.56	6.63		Z2:	18.87		
		LL:	5.52	2.6				Z0:	17.85		
LLG Gnd Return kA:	6.643	LLG:	6.81	3.3							
TK85 MCC	480	3 Phase:	6.37	5.3	1.81	6.57	6.47	Z1:	18.87	0.02	0.04
		SLG:	6.52	3.1	1.56	6.63		Z2:	18.87		
		LL:	5.52	2.6				Z0:	17.85		
LLG Gnd Return kA:	6.643	LLG:	6.81	3.3							
TK86 MAIN BK	480	3 Phase:	3.70	3.1	0.78	3.71	3.71	Z1:	32.47	0.06	0.04
Line Side		SLG:	3.30	1.6	0.67	3.30		Z2:	32.47		
		LL:	3.21	1.5				Z0:	44.61		
LLG Gnd Return kA:	2.971	LLG:	3.67	1.8							
TK86 MCC	480	3 Phase:	3.70	3.1	0.78	3.71	3.71	Z1:	32.47	0.06	0.04
		SLG:	3.30	1.6	0.67	3.30		Z2:	32.47		
		LL:	3.21	1.5				Z0:	44.61		
LLG Gnd Return kA:	2.971	LLG:	3.67	1.8							
TK87 MAIN BK	480	3 Phase:	2.83	2.4	1.01	2.83	2.83	Z1:	42.52	0.07	0.07
Line Side		SLG:	2.40	1.1	1.02	2.40		Z2:	42.52		
		LL:	2.45	1.2				Z0:	65.63		
LLG Gnd Return kA:	2.077	LLG:	2.64	1.3							
TK87 MCC	480	3 Phase:	2.83	2.4	1.01	2.83	2.83	Z1:	42.52	0.07	0.07
	.00	SLG:	2.40	1.1	1.02	2.40		Z2:	42.52		
		LL:	2.45	1.2				Z0:	65.63		

Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	t Duty	X/R	Asym	ı kA	Se	equence	Equiva	alent
Bus Name	Voltage		kA	MVA		Max RMS	Avg RMS	Imped	ance pu	R	+ <i>j</i> X
TK90/88 MAIN BK	480	3 Phase:	4.93	4.1	1.55	5.01	4.97	Z1:	24.42	0.03	0.05
Line Side		SLG:	4.54	2.2	1.41	4.59		Z2:	24.42		
		LL:	4.27	2.0				Z0:	30.70		
LLG Gnd Return kA:	4.208	LLG:	4.88	2.3							
TK90/88 MCC	480	3 Phase:	4.93	4.1	1.55	5.01	4.97	Z1:	24.42	0.03	0.05
		SLG:	4.54	2.2	1.41	4.59		Z2:	24.42		
		LL:	4.27	2.0				Z0:	30.70		
LLG Gnd Return kA:	4.208	LLG:	4.88	2.3							
TX-A Prim Side	12,470	3 Phase:	2.17	46.9	5.89	2.82	2.51	Z1:	2.13	0.58	3.26
		SLG:	0.01	0.2	0.01	0.01		Z2:	2.13		
		LL:	1.88	23.5				Z0:	926.18		
LLG Gnd Return kA:	0.007	LLG:	1.88	23.5							
TX-A Sec Side	480	3 Phase:	14.79	12.3	5.49	18.92	16.92	Z1:	8.13	0.00	0.02
		SLG:	0.00	0.0	0.03	0.00		Z2:	8.13		
		LL:	12.81	6.1				Z0:	180,033.20		
LLG Gnd Return kA:	0.001	LLG:	12.81	6.1							
TX-B Prim Side	12,470	3 Phase:	2.17	47.0	6.03	2.84	2.52	Z1:	2.13	0.57	3.26
		SLG:	0.01	0.2	0.01	0.01		Z2:	2.13		
		LL:	1.88	23.5				Z0:	926.17		
LLG Gnd Return kA:	0.007	LLG:	1.89	23.5							
TX-B Sec Side	480	3 Phase:	14.16	11.8	5.84	18.36	16.33	Z1:	8.50	0.00	0.02
		SLG:	0.00	0.0	0.02	0.00		Z2:	8.50		
		LL:	12.26	5.9				Z0:	182,360.20		
LLG Gnd Return kA:	0.001	LLG:	12.26	5.9							
TX-E Prim Side	12,470	3 Phase:	2.11	45.6	4.27	2.55	2.34	Z1:	2.19	0.80	3.32
		SLG:	0.01	0.2	0.01	0.01		Z2:	2.19		
		LL:	1.83	22.8				Z0:	926.41		
LLG Gnd Return kA:	0.007	LLG:	1.83	22.8							
TX-E Sec Side	480	3 Phase:	10.65	8.9	4.65	13.13	11.92	Z1:	11.29	0.01	0.03
		SLG:	11.35	5.4	4.66	14.00		Z2:	11.29		
		LL:	9.23	4.4				Z0:	9.20		
LLG Gnd Return kA:	12.153	LLG:	11.03	5.3							
TX-F Prim Side	12,470	3 Phase:	2.17	46.8	5.72	2.80	2.49	Z1:	2.14	0.60	3.27
	,	SLG:	0.01	0.2	0.01	0.01		Z2:	2.14		
		LL:	1.88	23.4				Z0:	926.20		
LLG Gnd Return kA:	0.007	LLG:	1.88	23.4							

#### Low Voltage 3 Phase and Unbalanced

Fault Location	Bus		Faul	It Duty	X/R	Asym	ı kA	Sequ	ience	Equivalent		
Bus Name	Voltage		kA	kA MVA		Max RMS	Avg RMS	Impedan	ce pu	R +		
TX-F Sec Side	4,160	3 Phase:	2.40	17.3	6.21	3.15	2.79	Z1:	5.79	0.16	0.99	
		SLG:	2.73	11.4	6.29	3.60		Z2:	5.79			
		LL:	2.08	8.6				Z0:	3.65			
LLG Gnd Return kA:	3.179	LLG:	2.61	10.8								

#### **Momentary 3 Phase**

		S	ym Fault D	uty	Mor	n kA	Cres	st kA		
Fault Location Bus Name	Bus Voltage	kA	MVA	X/R	Sym*1.6	Based on X/R	Sym*2.7	Based on X/R	Equi R	valent +jX
02-MAIN SERVICE SWGR	12,470	1.897	40.96	6.16	3.035	2.490	5.121	4.290	0.63	3.74
KV SWGR	4,160	2.265	16.32	6.06	3.624	2.960	6.116	5.110	0.17	1.05
BB-ESB1-TXR1 Prim Side	12,470	1.897	40.98	6.16	3.036	2.490	5.122	4.290	0.63	3.74
BB-ESB2-TXR1 Prim Side	12,470	1.897	40.98	6.16	3.036	2.490	5.122	4.290	0.63	3.74
BB-ESB3-TXR1 Prim Side	4,160	1.896	13.66	4.36	3.034	2.300	5.119	3.980	0.28	1.23
BB-ESB4-TXR1 Prim Side	4,160	1.896	13.66	4.36	3.034	2.300	5.119	3.980	0.28	1.23
BB-ESB5-TXR1 Prim Side	4,160	1.896	13.66	4.36	3.034	2.300	5.119	3.980	0.28	1.23
SUB1 12.5 kV Line Side	12,470	3.236	69.89	4.77	5.177	4.010	8.737	6.940	0.46	2.18
SUB1 Xmer Prim	12,470	3.236	69.89	4.77	5.177	4.010	8.737	6.940	0.46	2.18
SUB1 Xmer Sec	12,470	1.901	41.06	6.38	3.042	2.510	5.133	4.330	0.61	3.74
SUB1-PDC1	12,470	1.900	41.04	6.34	3.040	2.510	5.130	4.320	0.61	3.74
SUB2 12.5 kV Line	12,470	2.352	50.80	2.45	3.763	2.530	6.350	4.250	1.16	2.83
SUB2 Xmer Prim Side	12,470	2.352	50.80	2.45	3.763	2.530	6.350	4.250	1.16	2.83
SUB2 Xmer Sec Side	4,160	1.911	13.77	4.57	3.058	2.350	5.160	4.060	0.27	1.23
SUB2-PDC1	4,160	1.904	13.72	4.48	3.046	2.320	5.140	4.030	0.28	1.23
Γ-3 Prim Side	4,160	1.896	13.66	4.36	3.034	2.300	5.119	3.980	0.28	1.23
Γ-4 Prim Side	4,160	1.896	13.66	4.36	3.034	2.300	5.119	3.980	0.28	1.23
TX-A Prim Side	12,470	1.893	40.88	5.97	3.028	2.470	5.110	4.260	0.65	3.75
X-B Prim Side	12,470	1.895	40.94	6.11	3.033	2.480	5.118	4.280	0.63	3.74
X-E Prim Side	12,470	1.847	39.90	4.47	2.956	2.250	4.988	3.910	0.87	3.80
X-F Prim Side	12,470	1.889	40.81	5.82	3.023	2.450	5.102	4.230	0.66	3.75
X-F Sec Side	4,160	2.274	16.38	6.23	3.638	2.990	6.140	5.160	0.17	1.04

## **Momentary Unbalanced**

Fault Location Bus Name	Bus Voltage		Sym Fa	ault Duty MVA	X/R	Mo kA*1.6	om. Fault Duty Based on X/R	Imp	Sequence edance pu
02 MAIN CEDVICE	12 470	2 Dhagar			( 1 (			Z1:	2.44
02-MAIN SERVICE SWGR	12,470	3 Phase: SLG:	1.897 0.015	40.96 0.19	6.16 0.01	3.035 0.024	2.490 0.010	Z1: Z2:	2.44
		LL:	1.642		0.01	0.024	0.010	Z0:	2.44 926.16
LLG Gnd Return kA:	0.01	LLG:	1.642	20.48 20.53				20.	920.10
LLO Oliu Ketulli KA.	0.01	LLU.							
5KV SWGR	4,160	3 Phase:	2.265	16.32	6.06	3.624	2.960	Z1:	6.13
		SLG:	2.608	10.85	6.06	4.173	3.410	Z2:	6.13
		LL:	1.962	8.16				Z0:	3.71
LLG Gnd Return kA:	3.07	LLG:	2.490	10.36					
BB-ESB1-TXR1	12,470	3 Phase:	1.897	40.98	6.16	3.036	2.490	Z1:	2.44
Prim Side		SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.44
		LL:	1.643	20.49				Z0:	926.16
LLG Gnd Return kA:	0.01	LLG:	1.647	20.53					
BB-ESB2-TXR1	12,470	3 Phase:	1.897	40.98	6.16	3.036	2.490	Z1:	2.44
Prim Side	12,470	SLG:	0.015	0.19	0.10	0.024	0.010	Z2:	2.44
		LL:	1.643	20.49	0.01	0.024	0.010	Z0:	926.16
LLG Gnd Return kA:	0.01	LLG:	1.647	20.49				20.	920.10
BB-ESB3-TXR1	4,160	3 Phase:	1.896	13.66	4.36	3.034	2.300	Z1:	7.32
Prim Side		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.32
		LL:	1.642	6.83				Z0:	2,776.83
LLG Gnd Return kA:	0.01	LLG:	1.646	6.85					
BB-ESB4-TXR1	4,160	3 Phase:	1.896	13.66	4.36	3.034	2.300	Z1:	7.32
Prim Side		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.32
		LL:	1.642	6.83				Z0:	2,776.83
LLG Gnd Return kA:	0.01	LLG:	1.646	6.85					
BB-ESB5-TXR1	4,160	3 Phase:	1.896	13.66	4.36	3.034	2.300	Z1:	7.32
Prim Side	.,100	SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.32
		LL:	1.642	6.83				Z0:	2,776.83
LLG Gnd Return kA:	0.01	LLG:	1.646	6.85					2,7,70.00
GT:D4 40 51777		2 PI					4.040	71	
SUB1 12.5 kV Line Side	12,470	3 Phase:	3.236	69.89	4.77	5.177	4.010	Z1:	1.43
Side		SLG:	2.234	27.86	3.91	3.575	2.650	Z2:	1.43
HCC ID. IA	1.71	LL:	2.802	34.95				Z0:	3.36
LLG Gnd Return kA:	1.71	LLG:	2.981	37.18					
SUB1 Xmer Prim	12,470	3 Phase:	3.236	69.89	4.77	5.177	4.010	Z1:	1.43
Side		SLG:	2.234	27.86	3.91	3.575	2.650	Z2:	1.43
		LL:	2.802	34.95				Z0:	3.36
LLG Gnd Return kA:	1.71	LLG:	2.981	37.18					
SUB1 Xmer Sec Side	12,470	3 Phase:	1.901	41.06	6.38	3.042	2.510	Z1:	2.44
	,	SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.44
		LL:	1.647	20.53				Z0:	926.11
LLG Gnd Return kA:	0.01	LLG:	1.650	20.58					
						2.040		771	2 / /
SUB1-PDC1	12,470	3 Phase:	1.900	41.04	6.34	3.040	2.510	Z1:	2.44
		SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.44
II.C.CID-: 14	0.01	LL:	1.646	20.52				Z0:	926.13
LLG Gnd Return kA:	0.01	LLG:	1.649	20.57					

#### **Momentary Unbalanced**

Fault Location	Bus		Sym Fa	ault Duty	X/R	Mc	om. Fault Duty		Sequence
Bus Name	Voltage		kA	MVA		kA*1.6	Based on X/R	lmp	edance pu
SUB2 12.5 kV Line	12,470	3 Phase:	2.352	50.80	2.45	3.763	2.530	Z1:	1.97
Side		SLG:	1.639	20.44	1.86	2.622	1.690	Z2:	1.97
		LL:	2.037	25.40				Z0:	4.58
LLG Gnd Return kA:	1.25	LLG:	2.226	27.76					
SUB2 Xmer Prim	12,470	3 Phase:	2.352	50.80	2.45	3.763	2.530	Z1:	1.97
Side	12,	SLG:	1.639	20.44	1.85	2.622	1.690	Z2:	1.97
		LL:	2.037	25.40				Z0:	4.58
LLG Gnd Return kA:	1.25	LLG:	2.226	27.76					
SUB2 Xmer Sec Side	4,160	3 Phase:	1.911	13.77	4.57	3.058	2.350	Z1:	7.26
SOB2 Affici See Side	4,100	SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.26
		LL:	1.655	6.89	0.01	0.024	0.010	Z0:	2,776.53
LLG Gnd Return kA:	0.01	LLG:	1.659	6.90				20.	2,770.33
SUB2-PDC1	4,160	3 Phase:	1.904	13.72	4.48	3.046	2.320	Z1:	7.29
		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.29
		LL:	1.649	6.86				Z0:	2,776.68
LLG Gnd Return kA:	0.01	LLG:	1.652	6.87					
T-3 Prim Side	4,160	3 Phase:	1.896	13.66	4.36	3.034	2.300	Z1:	7.32
		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.32
		LL:	1.642	6.83				Z0:	2,776.83
LLG Gnd Return kA:	0.01	LLG:	1.646	6.85					
T-4 Prim Side	4,160	3 Phase:	1.896	13.66	4.36	3.034	2.300	Z1:	7.32
		SLG:	0.015	0.06	0.01	0.024	0.010	Z2:	7.32
		LL:	1.642	6.83				Z0:	2,776.83
LLG Gnd Return kA:	0.01	LLG:	1.646	6.85					
TX-A Prim Side	12,470	3 Phase:	1.893	40.88	5.97	3.028	2.470	Z1:	2.45
		SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.45
		LL:	1.639	20.44				Z0:	926.18
LLG Gnd Return kA:	0.01	LLG:	1.643	20.49					
TX-B Prim Side	12,470	3 Phase:	1.895	40.94	6.11	3.033	2.480	Z1:	2.44
	,	SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.44
		LL:	1.642	20.47				Z0:	926.17
LLG Gnd Return kA:	0.01	LLG:	1.645	20.52					,_,,,
TX-E Prim Side	12,470	3 Phase:	1.847	39.90	4.47	2.956	2.250	Z1:	2.51
TA E Timi olde	12,470	SLG:	0.015	0.19	0.01	0.024	0.010	Z2:	2.51
		LL:	1.600	19.95				Z0:	926.41
LLG Gnd Return kA:	0.01	LLG:	1.604	20.00				20.	720.41
TV E Drive Cide	12,470	3 Phase:	1.889	40.81	5.92	3.023	2.450	Z1:	2.45
TX-F Prim Side	12,470	SLG:	0.015		5.82 0.01	0.024	0.010	Z1:	
		LL:	1.636	0.19				Z0:	2.45
LLG Gnd Return kA:	0.01	LLG:	1.640	20.40 20.45				20.	926.20
TX-F Sec Side	4,160	3 Phase:	2.274	16.38	6.23	3.638	2.990	Z1:	6.10
		SLG:	2.625	10.92	6.30	4.200	3.460	Z2:	6.10
		LL:	1.969	8.19				Z0:	3.65
LLG Gnd Return kA:	3.10	LLG:	2.501	10.41					

## Interrupting 3 Phase and Unbalanced

Fault Location	Bus	-	Init Sym I	Fault	Equiv	alent	Seq.		Interrupting Fault kA				
Bus Name	Voltage		kA	X/R	R	+jX	lmp. pu		2 cyc.	3 сус.	5 cyc.	8 сус	
02-MAIN	12,470	3 Phase:	1.64	6.40	0.69	4.34	Z1: 2.83	3Ph.Sym:	1.64	1.64	1.64	1.64	
SERVICE SWGR		SLG:	0.01	0.01			Z2: 2.83	Tot:	1.79	1.64	1.64	1.64	
NACD:	0.87	LL:	1.42				Z0: 926.10	SLG Sym:	0.01	0.01	0.01	0.01	
LLG Gnd Return kA:	0.007	LLG:	1.42					Tot:	0.01	0.01	0.01	0.01	
5KV SWGR	4,160	3 Phase:	2.13	6.16	0.18	1.11	Z1: 6.51	3Ph.Sym:	2.13	2.13	2.13	2.13	
		SLG:	2.49	6.14			Z2: 6.51	Tot:	2.31	2.13	2.13	2.13	
NACD:	0.87	LL:	1.84				Z0: 3.71	SLG Sym:	2.49	2.49	2.49	2.49	
LLG Gnd Return kA:	2.988	LLG:	2.37					Tot:	2.70	2.49	2.49	2.49	
BB-ESB1-TXR1	12,470	3 Phase:	1.64	6.40	0.69	4.34	Z1: 2.83	3Ph.Sym:	1.64	1.64	1.64	1.64	
Prim Side		SLG:	0.01	0.01			Z2: 2.83	Tot:	1.79	1.64	1.64	1.64	
NACD:	0.87	LL:	1.42				Z0: 926.10	SLG Sym:	0.01	0.01	0.01	0.01	
LLG Gnd Return kA:	0.007	LLG:	1.42					Tot:	0.01	0.01	0.01	0.01	
BB-ESB2-TXR1	12,470	3 Phase:	1.64	6.40	0.69	4.34	Z1: 2.83	3Ph.Sym:	1.64	1.64	1.64	1.64	
Prim Side		SLG:	0.01	0.01			Z2: 2.83	Tot:	1.79	1.64	1.64	1.64	
NACD:	0.87	LL:	1.42				Z0: 926.10	SLG Sym:	0.01	0.01	0.01	0.01	
LLG Gnd Return kA:	0.007	LLG:	1.42					Tot:	0.01	0.01	0.01	0.01	
BB-ESB3-TXR1	4,160	3 Phase:	1.90	4.36	0.28	1.23	Z1: 7.32	3Ph.Sym:	1.90	1.90	1.90	1.90	
Prim Side		SLG:	0.01	0.01			Z2: 7.32	Tot:	1.98	1.90	1.90	1.90	
NACD:	1.00	LL:	1.64				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01	
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01	
BB-ESB4-TXR1	4,160	3 Phase:	1.90	4.36	0.28	1.23	Z1: 7.32	3Ph.Sym:	1.90	1.90	1.90	1.90	
Prim Side		SLG:	0.01	0.01			Z2: 7.32	Tot:	1.98	1.90	1.90	1.90	
NACD:	1.00	LL:	1.64				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01	
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01	
BB-ESB5-TXR1	4,160	3 Phase:	1.90	4.36	0.28	1.23	Z1: 7.32	3Ph.Sym:	1.90	1.90	1.90	1.90	
Prim Side		SLG:	0.01	0.01			Z2: 7.32	Tot:	1.98	1.90	1.90	1.90	
NACD:	1.00	LL:	1.64				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01	
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01	
SUB1 12.5 kV Line	12,470	3 Phase:	3.03	4.72	0.50	2.33	Z1: 1.53	3Ph.Sym:	3.03	3.03	3.03	3.03	
Side		SLG:	2.17	3.92			Z2: 1.53	Tot:	3.17	3.03	3.03	3.03	
NACD:	0.94	LL:	2.62				Z0: 3.36	SLG Sym:	2.17	2.17	2.17	2.17	
LLG Gnd Return kA:	1.685	LLG:	2.80					Tot:	2.25	2.17	2.17	2.17	
SUB1 Xmer Prim	12,470	3 Phase:	3.03	4.72	0.50	2.33	Z1: 1.53	3Ph.Sym:	3.03	3.03	3.03	3.03	
Side		SLG:	2.17	3.92			Z2: 1.53	Tot:	3.17	3.03	3.03	3.03	
NACD:	0.94	LL:	2.62				Z0: 3.36	SLG Sym:	2.17	2.17	2.17	2.17	
LLG Gnd Return kA:	1.685	LLG:	2.80					Tot:	2.25	2.17	2.17	2.17	
SUB1 Xmer Sec	12,470	3 Phase:	1.64	6.62	0.67	4.34	Z1: 2.82	3Ph.Sym:	1.64	1.64	1.64	1.64	
Side		SLG:	0.01	0.01			Z2: 2.82	Tot:	1.81	1.65	1.64	1.64	
NACD:	0.87	LL:	1.42				Z0: 926.1	SLG Sym:	0.01	0.01	0.01	0.01	
LLG Gnd Return kA:	0.007	LLG:	1.42					Tot:	0.01	0.01	0.01	0.01	

## Interrupting 3 Phase and Unbalanced

Fault Location	Bus		Init Sym I	ault	Equiv	alent	Seq.		lr	nterruptin	g Fault k	4
Bus Name	Voltage		kA	X/R	R	+jX	lmp. pu		2 cyc.	3 сус.	5 cyc.	8 cyc.
SUB1-PDC1	12,470	3 Phase:	1.64	6.57	0.67	4.34	Z1: 2.82	3Ph.Sym:	1.64	1.64	1.64	1.64
		SLG:	0.01	0.01			Z2: 2.82	Tot:	1.80	1.64	1.64	1.64
NACD:	0.87	LL:	1.42				Z0: 926.1.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.42					Tot:	0.01	0.01	0.01	0.01
SUB2 12.5 kV Line	12,470	3 Phase:	2.35	2.45	1.16	2.83	Z1: 1.97	3Ph.Sym:	2.35	2.35	2.35	2.35
Side		SLG:	1.64	1.86			Z2: 1.97	Tot:	2.40	2.35	2.35	2.35
NACD:	1.00	LL:	2.04				Z0: 4.58	SLG Sym:	1.64	1.64	1.64	1.64
LLG Gnd Return kA:	1.252	LLG:	2.23					Tot:	1.66	1.64	1.64	1.64
SUB2 Xmer Prim	12,470	3 Phase:	2.35	2.45	1.16	2.83	Z1: 1.97	3Ph.Sym:	2.35	2.35	2.35	2.35
Side		SLG:	1.64	1.85			Z2: 1.97	Tot:	2.40	2.35	2.35	2.35
NACD:	1.00	LL:	2.04				Z0: 4.58	SLG Sym:	1.64	1.64	1.64	1.64
LLG Gnd Return kA:	1.252	LLG:	2.23					Tot:	1.66	1.64	1.64	1.64
SUB2 Xmer Sec	4,160	3 Phase:	1.91	4.57	0.27	1.23	Z1: 7.26	3Ph.Sym:	1.91	1.91	1.91	1.91
Side		SLG:	0.01	0.01			Z2: 7.26	Tot:	2.00	1.91	1.91	1.91
NACD:	1.00	LL:	1.66				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.66					Tot:	0.01	0.01	0.01	0.01
SUB2-PDC1	4,160	3 Phase:	1.90	4.48	0.28	1.23	Z1: 7.29	3Ph.Sym:	1.90	1.90	1.90	1.90
		SLG:	0.01	0.01			Z2: 7.29	Tot:	1.99	1.90	1.90	1.90
NACD:	1.00	LL:	1.65				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01
T-3 Prim Side	4,160	3 Phase:	1.90	4.36	0.28	1.23	Z1: 7.32	3Ph.Sym:	1.90	1.90	1.90	1.90
		SLG:	0.01	0.01			Z2: 7.32	Tot:	1.98	1.90	1.90	1.90
NACD:	1.00	LL:	1.64				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01
T-4 Prim Side	4,160	3 Phase:	1.90	4.36	0.28	1.23	Z1: 7.32	3Ph.Sym:	1.90	1.90	1.90	1.90
		SLG:	0.01	0.01			Z2: 7.32	Tot:	1.98	1.90	1.90	1.90
NACD:	1.00	LL:	1.64				Z0: 2,776.	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.65					Tot:	0.01	0.01	0.01	0.01
TX-A Prim Side	12,470	3 Phase:	1.63	6.22	0.71	4.35	Z1: 2.83	3Ph.Sym:	1.63	1.63	1.63	1.63
		SLG:	0.01	0.01			Z2: 2.83	Tot:	1.78	1.64	1.63	1.63
NACD:	0.87	LL:	1.41				Z0: 926.11	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.42					Tot:	0.01	0.01	0.01	0.01
TX-B Prim Side	12,470	3 Phase:	1.64	6.34	0.70	4.35	Z1: 2.83	3Ph.Sym:	1.64	1.64	1.64	1.64
		SLG:	0.01	0.01			Z2: 2.83	Tot:	1.78	1.64	1.64	1.64
NACD:	0.87	LL:	1.42				Z0: 926.1'	-	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.42					Tot:	0.01	0.01	0.01	0.01
TX-E Prim Side	12,470	3 Phase:		4.77	0.93	4.40	Z1: 2.89	3Ph.Sym:	1.60	1.60	1.60	1.60
		SLG:	0.01	0.01			Z2: 2.89	Tot:	1.67	1.60	1.60	1.60
NACD:	0.87	LL:	1.39				Z0: 926.4	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.39					Tot:	0.01	0.01	0.01	0.01

## Interrupting 3 Phase and Unbalanced


Fault Location	Bus	-	Init Sym F	Fault	Equiv	/alent	Seq.		Interrupting Fault kA			
Bus Name	Voltage		kA	X/R	R	+jX	lmp. pu		2 cyc.	3 cyc.	5 cyc.	8 cyc.
TX-F Prim Side	12,470	3 Phase:	1.63	6.08	0.73	4.35	Z1: 2.84	3Ph.Sym:	1.63	1.63	1.63	1.63
		SLG:	0.01	0.01			Z2: 2.84	Tot:	1.77	1.63	1.63	1.63
NACD:	0.87	LL:	1.41				Z0: 926.20	SLG Sym:	0.01	0.01	0.01	0.01
LLG Gnd Return kA:	0.007	LLG:	1.42					Tot:	0.01	0.01	0.01	0.01
TX-F Sec Side	4,160	3 Phase:	2.14	6.33	0.18	1.11	Z1: 6.49	3Ph.Sym:	2.14	2.14	2.14	2.14
		SLG:	2.50	6.38			Z2: 6.49	Tot:	2.33	2.14	2.14	2.14
NACD:	0.87	LL:	1.85				Z0: 3.65	SLG Sym:	2.50	2.50	2.50	2.50
LLG Gnd Return kA:	3.018	LLG:	2.38					Tot:	2.74	2.51	2.50	2.50

A	Appendix 2 rc Flash Results and Protective Device Coordination





Bus Name	Protective Device	Bus kV	Bus Bolted	Prot Dev Bolted	Prot Dev Arcing	Trip/ Delay	Breaker Opening	Ground (Y/N)	Equip Type	Gap	Arc Flash Boundary	Working Distance	Incident Energy	Notes
	Name		Fault (kA)	Fault (kA)	Fault (kA)	Time (sec.)	Time (sec.)	(1714)	Туре	(mm)	(m)	(m)	(cal/cm2)	
02-MAIN SERVICE SWGR	SUB1-PDC1A Relay (50/51P)	12.47	2.20	1.94	1.93	0.1292	0.0830	No	SWG	152	0.40	0.91	0.53	(*S2)
BB-ESB1-TXR1 Prim Side	BB-ESB1-MCC LINE (50/51P)	12.47	2.20	1.96	1.95	0.2826	0.0830	No	SWG	152	0.64	0.91	0.85	(*S2)
BB-ESB2-TXR1 Prim Side	BB-ESB2-MCC LINE (50/51P)	12.47	2.20	1.93	1.92	0.2826	0.0830	No	SWG	152	0.64	0.91	0.85	(*S2)
SUB1 12.5 kV Line Side	MaxTripTime @2.0s	12.47	3.38	2.83	2.81	2	0.0000	Yes	SWG	152	5.26	0.91	6.6	(*N2) (*N9) (*S2)
SUB1 Xmer Prim Side	SUB1 Fdr Relay (50/51P)	12.47	3.38	2.83	2.38	0.348	0.0830	Yes	SWG	152	0.94	0.91	1.2	(*N3) (*S2)
SUB1 Xmer Sec Side	SUB1 Fdr Relay (50/51P)	12.47	2.21	1.30	1.10	1.354	0.0830	No	SWG	152	1.98	0.91	2.5	(*N3) (*S2)
SUB1-PDC1	SUB1 Fdr Relay (50/51P)	12.47	2.21	1.30	1.10	1.357	0.0830	No	SWG	152	1.98	0.91	2.5	(*N3) (*S2)
SUB2 12.5 kV Line Side	MaxTripTime @2.0s	12.47	2.47	2.35	2.34	2	0.0000	Yes	SWG	152	4.27	0.91	5.4	(*N2) (*N9) (*S3)
SUB2 Xmer Prim Side	SUB2 Xmer Prim Relay (50/51P)	12.47	2.47	2.35	2.34	0.1612	0.0830	Yes	SWG	152	0.50	0.91	0.67	(*S3)
TX-A Prim Side	SW-A	12.47	2.20	2.11	2.10	0.0381	0.0000	No	SWG	152	0.09	0.91	0.12	(*S2)
TX-B Prim Side	SW-B	12.47	2.20	2.13	2.12	0.0378	0.0000	No	SWG	152	0.09	0.91	0.12	(*S2)
TX-E Prim Side	SW-E	12.47	2.13	2.13	2.12	0.0325	0.0000	No	SWG	152	0.07	0.91	0.10	(*S2)
TX-F Prim Side	SW-F	12.47	2.19	2.09	1.77	0.0885	0.0000	No	SWG	152	0.17	0.91	0.23	(*N3) (*S2)
5KV SWGR	SUB1-PDC1A Relay (50/51P)	4.16	2.55	2.05	1.73	0.3107	0.0830	Yes	SWG	104	0.50	0.91	0.67	(*N3) (*N5) (*S2)
BB-ESB3-TXR1 Prim Side	BB-ESB3-MCC LINE (50/51P)	4.16	2.33	2.17	2.16	0.4077	0.0830	No	SWG	104	0.95	0.91	1.3	(*S3)
BB-ESB4-TXR1 Prim Side	BB-ESB4-MCC LINE (50/51P)	4.16	2.33	2.29	2.28	0.0646	0.0830	No	SWG	104	0.30	0.91	0.41	(*S3)
BB-ESB5-TXR1 Prim Side	BB-ESB5-MCC LINE (50/51P)	4.16	2.33	2.16	2.15	0.2018	0.0830	No	SWG	104	0.56	0.91	0.75	(*S3)
SUB2 Xmer Sec Side	SUB2 Xmer Prim Relay (50/51P)	4.16	2.34	1.91	1.62	0.5433	0.0830	No	SWG	104	1.02	0.91	1.3	(*N3) (*S3)
SUB2-PDC1	SUB2 Xmer Prim Relay (50/51P)	4.16	2.34	1.90	1.61	0.5473	0.0830	No	SWG	104	1.03	0.91	1.3	(*N3) (*S3)
T-3 Prim Side	LC3-MCC LINE Relay (50/51P)	4.16	2.33	2.29	2.28	0.1978	0.0830	No	SWG	104	0.55	0.91	0.74	(*S3)
T-4 Prim Side	LC4-MCC LINE Relay (50/51P)	4.16	2.33	2.29	2.28	0.2018	0.0830	No	SWG	104	0.56	0.91	0.75	(*S3)
TX-F Sec Side	SUB1-PDC1A Relay (50/51P)	4.16	2.56	2.06	1.74	0.3084	0.0830	Yes	SWG	104	0.50	0.91	0.67	(*N3) (*N5) (*S2)
BB-ESB1-MCC	ESB1-MCC MAIN Bkr	0.60	21.35	14.90	11.03	0.03	0.0000	Yes	PNL	25	0.72	0.45	2.5	(*S2)
BB-ESB1-TXR1 Sec Side	BB-ESB1-MCC LINE (50/51P)	0.60	22.03	16.55	10.39	0.8758	0.0830	Yes	PNL	25	3.36	0.45	32	(*N3) (*S3)
BB-ESB1-VFD11 Line Side	BPM-11 Bkr	0.60	20.95	19.27	14.29	0.0192	0.0000	Yes	PNL	25	0.42	0.45	1.0	(*S2)
BB-ESB2-VFD12 Line Side	BPM-12 Bkr	0.60	21.90	20.22	14.94	0.0186	0.0000	Yes	PNL	25	0.42	0.45	1.0	(*S2)





Bus Name	Protective	Bus	Bus	Prot Dev	Prot Dev	Trip/	Breaker	Ground	Equip	Gap	Arc Flash	Working	Incident	Notes
	Device	kV	Bolted	Bolted	Arcing	Delay	Opening	(Y/N)	Туре		Boundary	Distance	Energy	
	Name		Fault	Fault	Fault	Time	Time			(mm)	(m)	(m)	(cal/cm2)	
			(kA)	(kA)	(kA)	(sec.)	(sec.)							
BB-ESB1-VFD21 Line Side	BPM-21 Bkr	0.60	20.95	19.27	14.29	0.0179	0.0000	Yes	PNL	25	0.40	0.45	0.96	(*S2)
BB-ESB2-VFD22 Line Side	BPM-22 Bkr	0.60	21.90	20.22	14.94	0.0178	0.0000	Yes	PNL	25	0.41	0.45	1.0	(*S2)
BB-ESB1-VFD31 Line Side	BPM-31 Bkr	0.60	20.95	19.27	14.29	0.0179	0.0000	Yes	PNL	25	0.40	0.45	0.96	(*S2)
BB-ESB2-VFD32 Line Side	BPM-32 Bkr	0.60	21.90	20.22	14.94	0.0178	0.0000	Yes	PNL	25	0.41	0.45	1.0	(*S2)
BB-ESB2A	ESB2A-MCC MAIN Bkr	0.60	20.20	18.32	13.62	0.014	0.0000	Yes	PNL	25	0.34	0.45	0.73	(*S2)
BB-ESB2-MCC	ESB2-MCC MAIN Bkr	0.60	22.33	14.82	10.93	0.03	0.0000	Yes	PNL	25	0.76	0.45	2.8	(*S2)
BB-ESB2-TXR1 Sec Side	BB-ESB2-MCC LINE (50/51P)	0.60	22.86	16.43	10.28	0.8925	0.0830	Yes	PNL	25	3.40	0.45	32	(*N3) (*S3)
BB-ESB3A-MCC	BB-ESB3A-MCC Main Bkr	0.60	6.19	5.83	4.76	0.0137	0.0000	Yes	PNL	25	0.16	0.45	0.22	(*S3)
BB-ESB3A-MCC Main Bkr LineSide	BB-ESB3A-MCC LINE Bkr	0.60	6.48	6.12	4.98	0.0169	0.0000	Yes	PNL	25	0.19	0.45	0.28	(*S3)
BB-ESB3B-MCC	BB-ESB3B-MCC Main Bkr	0.60	6.49	6.04	4.91	0.0135	0.0000	Yes	PNL	25	0.16	0.45	0.23	(*S3)
BB-ESB3B-MCC Main Bkr LineSide	BB-ESB3B-MCC LINE Bkr	0.60	6.49	6.04	4.91	0.0135	0.0000	Yes	PNL	25	0.16	0.45	0.23	(*S3)
BB-ESB3-MCC	ESB3-MCC MAIN Bkr	0.60	6.78	5.52	4.47	0.0254	0.0000	Yes	PNL	25	0.25	0.45	0.45	(*S3)
BB-ESB3-TXR1 Sec Side	BB-ESB3-MCC LINE (50/51P)	0.60	7.11	5.87	4.03	0.9687	0.0830	Yes	PNL	25	1.94	0.45	13	(*N3) (*S3)
BB-ESB4-MCC	BB-ESB4-MCC LINE (50/51P)	0.60	1.88	1.58	1.20	1.515	0.0830	Yes	PNL	25	1.15	0.45	5.5	(*N3) (*N5) (*S3)
BB-ESB4-TXR1 Sec Side	BB-ESB4-MCC LINE (50/51P)	0.60	2.02	1.72	1.30	1.302	0.0830	Yes	PNL	25	1.11	0.45	5.1	(*N3) (*S3)
BB-ESB5A-MCC	ESB5A-MCC MAIN Bkr	0.60	5.50	5.32	4.38	0.0112	0.0000	Yes	PNL	25	0.13	0.45	0.16	(*S3)
BB-ESB5B-MCC	ESB5B-MCC MAIN Bkr	0.60	5.54	5.08	4.19	0.0114	0.0000	Yes	PNL	25	0.13	0.45	0.16	(*S3)
BB-ESB5C-MCC	ESB5C-MCC MAIN Bkr	0.60	5.54	5.08	4.19	0.0114	0.0000	Yes	PNL	25	0.13	0.45	0.16	(*S3)
BB-ESB5-MCC	ESB5-MCC MAIN Bkr	0.60	6.03	4.76	3.90	0.0281	0.0000	Yes	PNL	25	0.31	0.45	0.63	(*S3)
BB-ESB5-TXR1 Sec Side	BB-ESB5-MCC LINE (50/51P)	0.60	7.15	5.86	4.02	0.4804	0.0830	Yes	PNL	25	1.34	0.45	7.1	(*N3) (*S3)
ESB1-MCC MAIN Bkr Line side	BB-ESB1-MCC LINE (50/51P)	0.60	20.44	14.55	9.19	1.096	0.0830	Yes	PNL	25	3.55	0.45	35	(*N3) (*S3)
ESB2A-MCC MAIN Bkr Line Side	ESB2A-MCC LINE Bkr	0.60	20.22	18.34	13.63	0.014	0.0000	Yes	PNL	25	0.34	0.45	0.73	(*S2)
ESB2-MCC MAIN Bkr Line side	BB-ESB2-MCC LINE (50/51P)	0.60	21.41	14.45	9.09	1.117	0.0830	Yes	PNL	25	3.59	0.45	35	(*N3) (*S3)
ESB3-MCC MAIN Bkr Line Side	BB-ESB3-MCC LINE (50/51P)	0.60	6.78	5.52	3.80	1.07	0.0830	Yes	PNL	25	1.98	0.45	13	(*N3) (*S3)
ESB4-MCC MAIN Bkr Line Side	BB-ESB4-MCC LINE (50/51P)	0.60	1.88	1.58	1.20	1.515	0.0830	Yes	PNL	25	1.15	0.45	5.5	(*N3) (*S3)
ESB5A-MCC MAIN Bkr Line Side	ESB5A-MCC LINE Bkr	0.60	5.51	5.33	4.39	0.0112	0.0000	Yes	PNL	25	0.13	0.45	0.16	(*S3)





Bus Name	Protective	Bus	Bus	Prot Dev	Prot Dev	Trip/	Breaker	Ground	Equip	Gap	Arc Flash	Working	Incident	Notes
Dub Humo	Device	kV	Bolted	Bolted	Arcing	Delay	Opening	(Y/N)	Type	Cup	Boundary	Distance	Energy	
	Name		Fault	Fault	Fault	Time	Time	(,,,	,,,,	(mm)	(m)	(m)	(cal/cm2)	
			(kA)	(kA)	(kA)	(sec.)	(sec.)							
ESB5B-MCC MAIN Bkr Line Side	ESB5B-MCC LINE Bkr	0.60	5.54	5.09	4.19	0.0114	0.0000	Yes	PNL	25	0.14	0.45	0.16	(*S3)
ESB5C-MCC MAIN Bkr Line Side	ESB5C-MCC LINE Bkr	0.60	5.54	5.09	4.19	0.0127	0.0000	Yes	PNL	25	0.14	0.45	0.18	(*S3)
ESB5-MCC MAIN Bkr Line Side	BB-ESB5-MCC LINE (50/51P)	0.60	6.03	4.76	3.31	0.6789	0.0830	Yes	PNL	25	1.43	0.45	7.8	(*N3) (*S3)
BB-LC3A-MCC	LC3A-MCC MAIN Bkr	0.48	6.86	6.65	4.61	0.0121	0.0000	Yes	PNL	25	0.14	0.45	0.18	(*S3)
BB-LC4A-MCC	LC4A-MCC MAIN Bkr	0.48	5.84	5.62	3.98	0.0128	0.0000	Yes	PNL	25	0.14	0.45	0.17	(*S3)
CDP PANEL A	CDP A FDR BK	0.48	7.20	7.20	4.95	0.0193	0.0000	No	PNL	25	0.23	0.45	0.39	(*S2)
CDP PANEL AX (CTRL RM BLDG)	CDP-AX FDR BK	0.48	5.70	5.70	4.05	0.0157	0.0000	No	PNL	25	0.18	0.45	0.26	(*S2)
CDP PANEL BX	CDP-BX FDR BK	0.48	6.73	5.43	3.77	0.0166	0.0000	No	PNL	25	0.20	0.45	0.32	(*S2)
CDP PANEL SB-A1	CDP SB-A1 FDR BK	0.48	4.37	4.37	3.24	0.0169	0.0000	No	PNL	25	0.16	0.45	0.22	(*S2)
DIV. OFFICE BASEMENT	DIV OFFICE FDR BK	0.48	1.64	1.63	1.18	0.1676	0.0000	No	PNL	25	0.33	0.45	0.71	(*N3) (*S3)
LC3A-MCC MAIN Bkr Line Side	LC3A-MCC LINE Bkr	0.48	6.86	6.65	4.61	0.0135	0.0000	Yes	PNL	25	0.15	0.45	0.20	(*S3)
LC4A-MCC MAIN Bkr Line Side	LC4A-MCC LINE Bkr	0.48	6.69	6.46	4.49	0.0135	0.0000	Yes	PNL	25	0.15	0.45	0.20	(*S3)
LEVEE BUILDING	LEVEE BLDG FDR FU	0.48	0.84	0.83	0.78	0.01	0.0000	No	PNL	25	0.05	0.45	0.03	(*S2)
MCC LC-3	MCC-LC-3 MAIN BK	0.48	7.86	7.53	5.12	0.0222	0.0000	Yes	PNL	25	0.22	0.45	0.38	(*S3)
MCC LC-4	MCC-LC-4 MAIN BK	0.48	7.63	7.31	4.98	0.03	0.0000	Yes	PNL	25	0.27	0.45	0.50	(*S3)
MCC-A	MCC-A MAIN	0.48	12.61	9.87	6.26	0.0233	0.0000	No	PNL	25	0.48	0.45	1.3	(*S2)
MCC-A MAIN Line Side	SW-A	0.48	13.00	10.29	5.52	1.745	0.0000	No	PNL	25	3.82	0.45	39	(*N3) (*S3)
MCC-AX	ATS FDR BK	0.48	11.12	9.54	6.16	0.013	0.0000	No	PNL	25	0.23	0.45	0.39	(*S2)
MCC-B	SW-B	0.48	12.40	10.20	5.51	1.753	0.0000	No	PNL	25	3.80	0.45	39	(*N3) (*N5) (*S3)
MCC-B MAIN Line Side	SW-B	0.48	12.40	10.20	5.51	1.753	0.0000	No	PNL	25	3.80	0.45	39	(*N3) (*S3)
MCC-DX	MCC-DX FDR BK	0.48	6.07	5.45	3.84	0.0162	0.0000	No	PNL	25	0.19	0.45	0.28	(*S2)
MCC-E	SW-E	0.48	9.12	9.03	5.10	1.165	0.0000	Yes	PNL	25	2.36	0.45	18	(*N3) (*N5) (*S3)
MCC-E MAIN Line Side	SW-E	0.48	9.12	9.03	5.10	1.165	0.0000	Yes	PNL	25	2.36	0.45	18	(*N3) (*S3)
MCC-EX	MCC-EX FDR BK	0.48	0.57	0.57	0.57	1.814	0.0000	No	PNL	25	0.46	0.45	1.2	(*N5) (*N1) (*S3)
MCC-EX Line Side	MCC-EX FDR BK	0.48	1.10	1.10	0.84	0.6517	0.0000	No	PNL	25	0.61	0.45	1.9	(*N3) (*S3)
MCC-F	MCCF FDR BK	0.48	8.93	8.90	5.94	0.0117	0.0000	No	PNL	25	0.19	0.45	0.29	(*S2)





Bus Name	Protective Device Name	Bus kV	Bus Bolted Fault (kA)	Prot Dev Bolted Fault (kA)	Prot Dev Arcing Fault (kA)	Trip/ Delay Time (sec.)	Breaker Opening Time (sec.)	Ground (Y/N)	Equip Type	Gap (mm)	Arc Flash Boundary (m)	Working Distance (m)	Incident Energy (cal/cm2)	Notes
MCC-LC-3 MAIN BK Line Side	LC3-MCC LINE Relay (50/51P)	0.48	7.94	7.61	4.39	0.5995	0.0830	Yes	PNL	25	1.55	0.45	8.9	(*N3) (*S2)
MCC-LC-4 MAIN BK Line Side	LC4-MCC LINE Relay (50/51P)	0.48	7.70	7.38	4.27	0.6413	0.0830	Yes	PNL	25	1.58	0.45	9.2	(*N3) (*S2)
MECH SHOP PANEL	MECH SHOP BKR	0.48	7.74	7.74	5.27	0.0177	0.0000	Yes	PNL	25	0.19	0.45	0.30	(*S2)
PDP #1	PDP1 FDR BK	0.48	6.01	5.89	4.16	0.0156	0.0000	No	PNL	25	0.18	0.45	0.27	(*S2)
PDP #3	PDP3/4 FDR BK	0.48	6.48	6.18	4.32	0.0154	0.0000	No	PNL	25	0.19	0.45	0.28	(*S2)
PDP #4	PDP3/4 FDR BK	0.48	6.43	6.14	4.29	0.0155	0.0000	No	PNL	25	0.19	0.45	0.28	(*S2)
PDP #5	PDP5 FDR BK	0.48	6.48	6.33	4.42	0.0153	0.0000	No	PNL	25	0.19	0.45	0.28	(*S2)
PDP #6	PDP6 FDR BK	0.48	6.65	6.55	4.56	0.0152	0.0000	No	PNL	25	0.19	0.45	0.29	(*S2)
PLM SHOP MCC	PLM SHOP BKR	0.48	7.76	7.67	5.22	0.0177	0.0000	Yes	PNL	25	0.20	0.45	0.30	(*S2)
T-3 Sec Side	LC3-MCC LINE Relay (50/51P)	0.48	8.01	7.68	4.42	0.5911	0.0830	Yes	PNL	25	1.54	0.45	8.9	(*N3) (*S3)
T-4 Sec Side	LC4-MCC LINE Relay (50/51P)	0.48	7.81	7.49	4.33	0.627	0.0830	Yes	PNL	25	1.57	0.45	9.1	(*N3) (*S3)
TK71 MAIN BK Line Side	LC 71 FDR BK	0.48	2.91	2.90	2.27	0.0193	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S3)
TK71 MCC	TK71 MAIN BK	0.48	2.91	2.90	2.27	0.0193	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S3)
TK72 MAIN BK Line Side	LC 72 FDR BK	0.48	2.77	2.76	2.18	0.0197	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S3)
TK72 MCC	TK72 MAIN BK	0.48	2.77	2.76	2.18	0.0197	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S3)
TK73 MAIN BK Line Side	LC 73 FDR BK	0.48	2.83	2.81	2.22	0.0171	0.0000	Yes	PNL	25	0.11	0.45	0.11	(*S3)
TK73 MCC	TK73 MAIN BK	0.48	2.83	2.81	2.22	0.0163	0.0000	Yes	PNL	25	0.10	0.45	0.11	(*S3)
TK74 MAIN BK Line Side	LC 74 FDR BK	0.48	2.32	2.31	1.88	2	0.0000	Yes	PNL	25	1.73	0.45	11	(*N9) (*S2)
TK74 MCC	TK74 MAIN BK	0.48	2.32	2.31	1.60	0.0279	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*N3) (*S2)
TK81 MAIN BK Line Side	LC 81 FDR BK	0.48	2.91	2.91	2.28	0.0192	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S3)
TK81 MCC	TK81 MAIN BK	0.48	2.91	2.91	2.28	0.0192	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*\$3)
TK82 MAIN BK Line Side	LC 82 FDR BK	0.48	3.14	3.14	2.44	0.0187	0.0000	Yes	PNL	25	0.12	0.45	0.14	(*S3)
TK82 MCC	TK82 MAIN BK	0.48	3.14	3.14	2.44	0.0187	0.0000	Yes	PNL	25	0.12	0.45	0.14	(*S3)
TK83 MAIN BK Line side	LC 83 FDR BK	0.48	3.94	3.94	2.96	0.0171	0.0000	Yes	PNL	25	0.13	0.45	0.15	(*S3)
TK83 MCC	TK83 MAIN BK	0.48	3.94	3.94	2.96	0.0171	0.0000	Yes	PNL	25	0.13	0.45	0.15	(*S3)
TK84 MAIN BK Line Side	LC 84 FDR BK	0.48	4.78	4.77	3.49	0.0163	0.0000	Yes	PNL	25	0.14	0.45	0.18	(*S3)

#### Worst Case Arc Flash Results - In Service Mode - (Group 2) Settings

Burnaby Terminal 216239 Rev B - Issued For Review

Bus Name	Protective Device Name	Bus	Bus Bolted Fault	Prot Dev	Prot Dev Arcing Fault (kA)	Trip/ Delay Time (sec.)	Breaker Opening Time	Ground (Y/N)	Equip Type	Gap	Arc Flash Boundary (m)	Working Distance (m)	Incident Energy (cal/cm2)	Notes
		kV		Bolted Fault (kA)										
										(mm)				
			(kA)				(sec.)							
TK84 MCC	TK84 MAIN BK	0.48	4.78	4.77	3.49	0.0163	0.0000	Yes	PNL	25	0.14	0.45	0.18	(*S3)
TK85 MAIN BK Line Side	LC 85 FDR BK	0.48	6.37	6.36	4.45	0.0153	0.0000	Yes	PNL	25	0.16	0.45	0.21	(*S3)
TK85 MCC	TK85 MAIN BK	0.48	6.37	6.36	4.45	0.0153	0.0000	Yes	PNL	25	0.16	0.45	0.21	(*S3)
TK86 MAIN BK Line Side	LC 86 FDR BK	0.48	3.70	3.69	2.79	0.0176	0.0000	Yes	PNL	25	0.13	0.45	0.15	(*S3)
FK86 MCC	TK86 MAIN BK	0.48	3.70	3.69	2.79	0.0176	0.0000	Yes	PNL	25	0.13	0.45	0.15	(*S3)
TK87 MAIN BK Line Side	LC 87 FDR BK	0.48	2.83	2.81	1.89	0.0237	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*N3) (*S2)
TK87 MCC	TK87 MAIN BK	0.48	2.83	2.81	2.22	0.0181	0.0000	Yes	PNL	25	0.11	0.45	0.12	(*S3)
TK90/88 MAIN BK Line Side	LC 90/88 FDR BK	0.48	4.93	4.89	3.55	0.0175	0.0000	Yes	PNL	25	0.15	0.45	0.19	(*S3)
FK90/88 MCC	TK90/88 MAIN BK	0.48	4.93	4.89	3.55	0.0173	0.0000	Yes	PNL	25	0.15	0.45	0.19	(*S3)
TX-A Sec Side	SW-A	0.48	13.55	10.88	5.80	1.524	0.0000	No	PNL	25	3.62	0.45	35.96	(*N3) (*S3)
X-B Sec Side	SW-B	0.48	12.97	10.78	5.79	1.534	0.0000	No	PNL	25	3.61	0.45	35.79	(*N3) (*S3)
X-E Sec Side	SW-E	0.48	9.76	9.67	5.41	1.033	0.0000	Yes	PNL	25	2.27	0.45	16.71	(*N3) (*S3)

(\*N1) - Out of IEEE 1584 Range; Lee Equation Used

(\*N2) - <80% Cleared Fault Threshold


(\*N3) - Arcing Current Low Tolerances Used


(\*N5) - Miscoordinated, Upstream Device Tripped


(\*N9) - Max Arcing Duration Reached

(\*S2) - AF In Service Mode-1 jet fuel


(\*S3) - AF In Service Mode-no jet fuel











# From Page 1 BB-ESB4-TXR1 BB-ESB4-GEN BB-ESB4-GEN Bkr P-ESB4-TRS P-ESB4-GEN BB-ESB4-TRS **Burnaby Terminal Substation 2 Equipment - Page 5 of 6** P-ESB4-MCC Arc Flash Analysis \*\*\* In Service Mode \*\*\* ESB4-MCC MAIN Bkr Line Side Incident Energy 5.5 Cal/cm^2 Working Distance 0.46 m Flash Boundary 1.1 m ESB4-MCC MAIN Bkr BB-ESB4-MCC Incident Energy 5.5 Cal/cm^2 Working Distance 0.46 m ESB4-LP1 Bkr Flash Boundary 1.1 m P-ESB4-LP1 ESB4-LP1 BB-ESB4-MCC<50HP-1 BB-ESB4-MCC<50HP -2





























Bus Name	Protective Device Name	Bus kV	Bus Bolted Fault (kA)	Prot Dev Bolted Fault (kA)	Prot Dev Arcing Fault (kA)	Trip/ Delay Time (sec.)	Breaker Opening Time (sec.)	Ground (Y/N)	Equip Type	Gap (mm)	Arc Flash Boundary (m)	Working Distance (m)	Incident Energy (cal/cm2)	Notes
02-MAIN SERVICE SWGR	SUB1-PDC1A Relay (50/51P)	12.47	2.17	1.90	1.89	0.0167	0.0830	No	SWG	152	0.22	0.91	0.30	(*S7)
BB-ESB1-TXR1 Prim Side	BB-ESB1-MCC LINE (50/51P)	12.47	2.06	1.84	1.84	0.0167	0.0830	No	SWG	152	0.21	0.91	0.29	(*S8)
BB-ESB2-TXR1 Prim Side	BB-ESB2-MCC LINE (50/51P)	12.47	2.07	1.81	1.80	0.0167	0.0830	No	SWG	152	0.21	0.91	0.29	(*S8)
SUB1 12.5 kV Line Side	MaxTripTime @2.0s	12.47	3.36	2.83	2.81	2	0.0000	Yes	SWG	152	5.26	0.91	6.6	(*S7)
SUB1 Xmer Prim Side	SUB1 Fdr Relay (50/51P)	12.47	3.31	2.83	2.38	0.3478	0.0830	Yes	SWG	152	0.93	0.91	1.2	(*N3) (*S8)
SUB1 Xmer Sec Side	SUB1 Fdr Relay (50/51P)	12.47	2.07	1.30	1.10	1.351	0.0830	No	SWG	152	1.96	0.91	2.5	(*N3) (*S8)
SUB1-PDC1	SUB1 Fdr Relay (50/51P)	12.47	2.17	1.30	1.10	1.356	0.0830	No	SWG	152	1.98	0.91	2.5	(*N3) (*S7)
SUB2 12.5 kV Line Side	MaxTripTime @2.0s	12.47	2.47	2.35	2.34	2	0.0000	Yes	SWG	152	4.27	0.91	5.4	(*N2) (*N9) (*S7)
SUB2 Xmer Prim Side	SUB2 Xmer Prim Relay (50/51P)	12.47	2.47	2.35	2.34	0.1612	0.0830	Yes	SWG	152	0.50	0.91	0.67	(*S8)
TX-A Prim Side	SW-A	12.47	2.16	2.07	2.06	0.0388	0.0000	No	SWG	152	0.09	0.91	0.12	(*S7)
TX-E Prim Side	SW-E	12.47	2.09	2.09	2.08	0.0329	0.0000	No	SWG	152	0.07	0.91	0.10	(*S7)
TX-B Prim Side	SW-B	12.47	2.17	2.09	2.09	0.0384	0.0000	No	SWG	152	0.09	0.91	0.12	(*S7)
TX-F Prim Side	SW-F	12.47	2.16	2.06	1.74	0.0906	0.0000	No	SWG	152	0.17	0.91	0.23	(*N3) (*S7)
5KV SWGR	SUB1-PDC1A Relay (50/51P)	4.16	2.53	2.03	2.01	0.0167	0.0830	Yes	SWG	104	0.18	0.91	0.25	(*N5) (*S7)
BB-ESB3-TXR1 Prim Side	BB-ESB3-MCC LINE (50/51P)	4.16	2.33	2.17	2.16	0.0167	0.0830	No	SWG	104	0.22	0.91	0.29	(*S8)
BB-ESB4-TXR1 Prim Side	BB-ESB4-MCC LINE (50/51P)	4.16	2.33	2.29	2.28	0.0646	0.0830	No	SWG	104	0.30	0.91	0.41	(*S7)
BB-ESB5-TXR1 Prim Side	BB-ESB5-MCC LINE (50/51P)	4.16	2.33	2.16	2.15	0.2018	0.0830	No	SWG	104	0.56	0.91	0.75	(*S7)
SUB2 Xmer Sec Side	SUB2 Xmer Prim Relay (50/51P)	4.16	2.34	1.91	1.62	0.5433	0.0830	No	SWG	104	1.02	0.91	1.3	(*N3) (*S8)
SUB2-PDC1	SUB2 Xmer Prim Relay (50/51P)	4.16	2.34	1.90	1.61	0.5473	0.0830	No	SWG	104	1.03	0.91	1.3	(*N3) (*S7)
T-3 Prim Side	LC3-MCC LINE Relay (50/51P)	4.16	2.33	2.29	2.28	0.1978	0.0830	No	SWG	104	0.55	0.91	0.74	(*S7)
T-4 Prim Side	LC4-MCC LINE Relay (50/51P)	4.16	2.33	2.29	2.28	0.2018	0.0830	No	SWG	104	0.56	0.91	0.75	(*S7)
TX-F Sec Side	SUB1-PDC1A Relay (50/51P)	4.16	2.54	2.04	2.02	0.0167	0.0830	Yes	SWG	104	0.18	0.91	0.25	(*N5) (*S7)
BB-ESB1-MCC	ESB1-MCC MAIN Bkr	0.60	20.74	14.85	11.02	0.03	0.0000	Yes	PNL	25	0.70	0.45	2.4	(*S7)
BB-ESB1-TXR1 Sec Side	BB-ESB1-MCC LINE (50/51P)	0.60	22.03	16.55	12.22	0.0167	0.0830	Yes	PNL	25	1.13	0.45	5.3	(*S8)






Bus Name	Protective Device Name	Bus kV	Bus Bolted Fault (kA)	Prot Dev Bolted Fault (kA)	Prot Dev Arcing Fault (kA)	Trip/ Delay Time (sec.)	Breaker Opening Time (sec.)	Ground (Y/N)	Equip Type	Gap (mm)	Arc Flash Boundary (m)	Working Distance (m)	Incident Energy (cal/cm2)	Notes
BB-ESB1-VFD11 Line Side	BPM-11 Bkr	0.60	18.39	16.85	12.62	0.0197	0.0000	Yes	PNL	25	0.39	0.45	0.93	(*S7)
BB-ESB1-VFD21 Line Side	BPM-21 Bkr	0.60	18.35	16.81	12.59	0.018	0.0000	Yes	PNL	25	0.37	0.45	0.85	(*S7)
BB-ESB1-VFD31 Line Side	BPM-31 Bkr	0.60	18.35	16.81	12.59	0.018	0.0000	Yes	PNL	25	0.37	0.45	0.85	(*S7)
BB-ESB2A	ESB2A-MCC MAIN Bkr	0.60	19.57	17.72	13.21	0.0141	0.0000	Yes	PNL	25	0.33	0.45	0.71	(*S7)
BB-ESB2-MCC	ESB2-MCC MAIN Bkr	0.60	21.71	14.76	10.92	0.03	0.0000	Yes	PNL	25	0.74	0.45	2.6	(*S7)
BB-ESB2-TXR1 Sec Side	BB-ESB2-MCC LINE (50/51P)	0.60	22.86	16.43	12.10	0.0167	0.0830	Yes	PNL	25	1.16	0.45	5.5	(*S8)
BB-ESB2-VFD12 Line Side	BPM-12 Bkr	0.60	19.09	17.55	13.11	0.0191	0.0000	Yes	PNL	25	0.39	0.45	0.94	(*S7)
BB-ESB2-VFD22 Line Side	BPM-22 Bkr	0.60	19.09	17.55	13.11	0.0179	0.0000	Yes	PNL	25	0.38	0.45	0.88	(*S7)
BB-ESB2-VFD32 Line Side	BPM-32 Bkr	0.60	19.09	17.55	13.11	0.0179	0.0000	Yes	PNL	25	0.38	0.45	0.88	(*S7)
BB-ESB3A-MCC	BB-ESB3A-MCC Main Bkr	0.60	6.19	5.83	4.76	0.0137	0.0000	Yes	PNL	25	0.16	0.45	0.22	(*S7)
BB-ESB3A-MCC Main Bkr LineSide	BB-ESB3A-MCC LINE Bkr	0.60	6.48	6.12	4.98	0.0169	0.0000	Yes	PNL	25	0.19	0.45	0.28	(*S8)
BB-ESB3B-MCC	BB-ESB3B-MCC Main Bkr	0.60	6.49	6.04	4.91	0.0135	0.0000	Yes	PNL	25	0.16	0.45	0.23	(*S7)
BB-ESB3B-MCC Main Bkr LineSide	BB-ESB3B-MCC LINE Bkr	0.60	6.49	6.04	4.91	0.0135	0.0000	Yes	PNL	25	0.16	0.45	0.23	(*S7)
BB-ESB3-MCC	ESB3-MCC MAIN Bkr	0.60	6.78	5.52	4.47	0.0254	0.0000	Yes	PNL	25	0.25	0.45	0.45	(*S7)
BB-ESB3-TXR1 Sec Side	BB-ESB3-MCC LINE (50/51P)	0.60	7.11	5.87	4.74	0.0167	0.0830	Yes	PNL	25	0.58	0.45	1.8	(*S8)
BB-ESB4-MCC	BB-ESB4-MCC LINE (50/51P)	0.60	1.88	1.58	1.20	1.515	0.0830	Yes	PNL	25	1.15	0.45	5.5	(*N3) (*N5) (*S7)
BB-ESB4-TXR1 Sec Side	BB-ESB4-MCC LINE (50/51P)	0.60	2.02	1.72	1.30	1.302	0.0830	Yes	PNL	25	1.11	0.45	5.1	(*N3) (*S7)
BB-ESB5A-MCC	ESB5A-MCC MAIN Bkr	0.60	5.50	5.32	4.38	0.0112	0.0000	Yes	PNL	25	0.13	0.45	0.16	(*S7)
BB-ESB5B-MCC	ESB5B-MCC MAIN Bkr	0.60	5.54	5.08	4.19	0.0114	0.0000	Yes	PNL	25	0.13	0.45	0.16	(*S7)
BB-ESB5C-MCC	ESB5C-MCC MAIN Bkr	0.60	5.54	5.08	4.19	0.0114	0.0000	Yes	PNL	25	0.13	0.45	0.16	(*S7)
BB-ESB5-MCC	ESB5-MCC MAIN Bkr	0.60	6.03	4.76	3.90	0.0281	0.0000	Yes	PNL	25	0.31	0.45	0.63	(*S7)
BB-ESB5-TXR1 Sec Side	BB-ESB5-MCC LINE (50/51P)	0.60	7.15	5.86	4.02	0.4804	0.0830	Yes	PNL	25	1.34	0.45	7.1	(*N3) (*S7)
ESB1-MCC MAIN Bkr Line side	BB-ESB1-MCC LINE (50/51P)	0.60	20.44	14.55	10.81	0.0167	0.0830	Yes	PNL	25	1.08	0.45	4.9	(*S8)
ESB2A-MCC MAIN Bkr Line Side	ESB2A-MCC LINE Bkr	0.60	19.57	17.72	13.21	0.0141	0.0000	Yes	PNL	25	0.33	0.45	0.71	(*S7)





Bus Name  ESB2-MCC MAIN Bkr Line side	Protective Device Name	Bus kV	Bus Bolted Fault (kA)	Prot Dev Bolted Fault (kA)	Prot Dev Arcing Fault (kA)	Trip/ Delay Time (sec.)	Breaker Opening Time (sec.)	Ground (Y/N)	Equip Type PNL	Gap (mm)	Arc Flash Boundary (m)	Working Distance (m)	Incident Energy (cal/cm2)	Notes
ESB2-MCC MAIN BKr Line side	BB-ESB2-MCC LINE (50/51P)	0.60	21.41	14.45	10.70	0.0167	0.0830	Yes	PNL	25	1.11	0.45	5.1	(*S8)
ESB3-MCC MAIN Bkr Line Side	BB-ESB3-MCC LINE (50/51P)	0.60	6.78	5.52	4.47	0.0167	0.0830	Yes	PNL	25	0.56	0.45	1.7	(*S8)
ESB4-MCC MAIN Bkr Line Side	BB-ESB4-MCC LINE (50/51P)	0.60	1.88	1.58	1.20	1.515	0.0830	Yes	PNL	25	1.15	0.45	5.5	(*N3) (*S7)
SB5A-MCC MAIN Bkr Line Side	ESB5A-MCC LINE Bkr	0.60	5.51	5.33	4.39	0.0112	0.0000	Yes	PNL	25	0.13	0.45	0.16	(*S7)
SB5B-MCC MAIN Bkr Line Side	ESB5B-MCC LINE Bkr	0.60	5.54	5.09	4.19	0.0114	0.0000	Yes	PNL	25	0.14	0.45	0.16	(*S7)
SB5C-MCC MAIN Bkr Line Side	ESB5C-MCC LINE Bkr	0.60	5.54	5.09	4.19	0.0127	0.0000	Yes	PNL	25	0.14	0.45	0.18	(*S7)
ESB5-MCC MAIN Bkr Line Side	BB-ESB5-MCC LINE (50/51P)	0.60	6.03	4.76	3.31	0.6789	0.0830	Yes	PNL	25	1.43	0.45	7.8	(*N3) (*S7)
BB-LC3A-MCC	LC3A-MCC MAIN Bkr	0.48	6.86	6.65	4.61	0.0121	0.0000	Yes	PNL	25	0.14	0.45	0.18	(*S7)
BB-LC4A-MCC	LC4A-MCC MAIN Bkr	0.48	5.84	5.62	3.98	0.0128	0.0000	Yes	PNL	25	0.14	0.45	0.17	(*S7)
CDP PANEL A	CDP A FDR BK	0.48	7.34	7.34	5.04	0.0192	0.0000	No	PNL	25	0.23	0.45	0.40	(*S7)
CDP PANEL AX (CTRL RM BLDG)	CDP-AX FDR BK	0.48	5.81	5.81	4.13	0.0156	0.0000	No	PNL	25	0.18	0.45	0.26	(*S7)
CDP PANEL BX	CDP-BX FDR BK	0.48	6.87	5.54	3.84	0.0166	0.0000	No	PNL	25	0.20	0.45	0.32	(*S7)
CDP PANEL SB-A1	CDP SB-A1 FDR BK	0.48	4.47	4.47	3.30	0.0168	0.0000	No	PNL	25	0.16	0.45	0.22	(*S7)
DIV. OFFICE BASEMENT	DIV OFFICE FDR BK	0.48	1.64	1.63	1.18	0.1676	0.0000	No	PNL	25	0.33	0.45	0.71	(*N3) (*S8)
C3A-MCC MAIN Bkr Line Side	LC3A-MCC LINE Bkr	0.48	6.86	6.65	4.61	0.0135	0.0000	Yes	PNL	25	0.15	0.45	0.20	(*S7)
C4A-MCC MAIN Bkr Line Side	LC4A-MCC LINE Bkr	0.48	6.69	6.46	4.49	0.0135	0.0000	Yes	PNL	25	0.15	0.45	0.20	(*S7)
EVEE BUILDING	LEVEE BLDG FDR FU	0.48	0.86	0.85	0.80	0.01	0.0000	No	PNL	25	0.05	0.45	0.03	(*S7)
MCC LC-3	MCC-LC-3 MAIN BK	0.48	7.86	7.53	5.12	0.0222	0.0000	Yes	PNL	25	0.22	0.45	0.38	(*S7)
MCC LC-4	MCC-LC-4 MAIN BK	0.48	7.63	7.31	4.98	0.0225	0.0000	Yes	PNL	25	0.22	0.45	0.37	(*S7)
MCC-A	MCC-A MAIN	0.48	12.80	9.99	6.32	0.0233	0.0000	No	PNL	25	0.48	0.45	1.3	(*S7)
MCC-A MAIN Line Side	SUB1-PDC1A Relay (50/51P)	0.48	13.00	10.29	6.49	0.0167	0.0830	No	PNL	25	0.85	0.45	3.4	(*N5) (*S8)
MCC-AX	ATS FDR BK	0.48	11.30	9.68	6.24	0.0129	0.0000	No	PNL	25	0.23	0.45	0.40	(*S7)
ИСС-В	SUB1-PDC1A Relay (50/51P)	0.48	12.50	9.35	5.04	0.0167	0.0830	No	PNL	25	0.75	0.45	2.7	(*N3) (*N5) (*S7)
MCC-B MAIN Line Side	SUB1-PDC1A Relay (50/51P)	0.48	12.40	10.20	6.48	0.0167	0.0830	No	PNL	25	0.83	0.45	3.2	(*N5) (*S8)





Bus Name	Protective Device Name	Bus kV	Bus Bolted Fault (kA)	Prot Dev Bolted Fault (kA)	Prot Dev Arcing Fault (kA)	Trip/ Delay Time (sec.)	Breaker Opening Time (sec.)	Ground (Y/N)	Equip Type	Gap (mm)	Arc Flash Boundary (m)	Working Distance (m)	Incident Energy (cal/cm2)	Notes
MCC-DX	MCC-DX FDR BK	0.48	6.20	5.57	3.91	0.0162	0.0000	No	PNL	25	0.19	0.45	0.29	(*S7)
MCC-E	SUB1-PDC1A Relay (50/51P)	0.48	9.20	8.00	4.51	0.0167	0.0830	Yes	PNL	25	0.55	0.45	1.6	(*N3) (*N5) (*S7)
MCC-E MAIN Line Side	SUB1-PDC1A Relay (50/51P)	0.48	9.12	8.34	5.54	0.0167	0.0830	Yes	PNL	25	0.61	0.45	1.9	(*N5) (*S8)
MCC-EX	MCC-EX FDR BK	0.48	0.57	0.57	0.57	1.814	0.0000	No	PNL	25	0.46	0.45	1.2	(*N5) (*S8)
MCC-EX Line Side	MCC-EX FDR BK	0.48	1.10	1.10	0.84	0.6517	0.0000	No	PNL	25	0.61	0.45	1.9	(*N3) (*S8)
MCC-F	MCCF FDR BK	0.48	9.09	9.06	6.03	0.0116	0.0000	No	PNL	25	0.19	0.45	0.29	(*S7)
MCC-LC-3 MAIN BK Line Side	LC3-MCC LINE Relay (50/51P)	0.48	7.94	7.61	4.39	0.5995	0.0830	Yes	PNL	25	1.55	0.45	8.9	(*N3) (*S7)
MCC-LC-4 MAIN BK Line Side	LC4-MCC LINE Relay (50/51P)	0.48	7.70	7.38	4.27	0.6413	0.0830	Yes	PNL	25	1.58	0.45	9.2	(*N3) (*S7)
MECH SHOP PANEL	MECH SHOP BKR	0.48	7.72	7.72	5.26	0.0177	0.0000	Yes	PNL	25	0.19	0.45	0.30	(*S7)
PDP #1	PDP1 FDR BK	0.48	6.14	6.02	4.24	0.0155	0.0000	No	PNL	25	0.18	0.45	0.27	(*S7)
PDP #3	PDP3/4 FDR BK	0.48	6.62	6.31	4.40	0.0154	0.0000	No	PNL	25	0.19	0.45	0.29	(*S7)
PDP #4	PDP3/4 FDR BK	0.48	6.57	6.27	4.37	0.0154	0.0000	No	PNL	25	0.19	0.45	0.29	(*S7)
PDP #5	PDP5 FDR BK	0.48	6.61	6.46	4.50	0.0153	0.0000	No	PNL	25	0.19	0.45	0.29	(*S7)
PDP #6	PDP6 FDR BK	0.48	6.79	6.69	4.64	0.0151	0.0000	No	PNL	25	0.19	0.45	0.29	(*S7)
PLM SHOP MCC	PLM SHOP BKR	0.48	7.74	7.66	5.21	0.0177	0.0000	Yes	PNL	25	0.19	0.45	0.30	(*S7)
T-3 Sec Side	LC3-MCC LINE Relay (50/51P)	0.48	8.01	7.68	4.42	0.5911	0.0830	Yes	PNL	25	1.54	0.45	8.9	(*N3) (*S7)
T-4 Sec Side	LC4-MCC LINE Relay (50/51P)	0.48	7.81	7.49	4.33	0.627	0.0830	Yes	PNL	25	1.57	0.45	9.1	(*N3) (*S7)
TK71 MAIN BK Line Side	LC 71 FDR BK	0.48	2.91	2.90	2.27	0.0193	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S7)
TK71 MCC	TK71 MAIN BK	0.48	2.91	2.90	2.27	0.0193	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S7)
TK72 MAIN BK Line Side	LC 72 FDR BK	0.48	2.77	2.76	2.18	0.0197	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S7)
TK72 MCC	TK72 MAIN BK	0.48	2.77	2.76	2.18	0.0197	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S7)
TK73 MAIN BK Line Side	LC 73 FDR BK	0.48	2.83	2.81	2.22	0.0171	0.0000	Yes	PNL	25	0.11	0.45	0.11	(*S7)
TK73 MCC	TK73 MAIN BK	0.48	2.83	2.81	2.22	0.0163	0.0000	Yes	PNL	25	0.10	0.45	0.11	(*S7)
TK74 MAIN BK Line Side	LC 74 FDR BK	0.48	2.32	2.31	1.88	2	0.0000	Yes	PNL	25	1.73	0.45	11	(*N9) (*S7)

### Worst Case Arc Flash Results - Maintenance Mode - (Group 1) Settings

**Burnaby Terminal** 216239 Rev B - Issued For Review

Bus Name	Protective	Bus	Bus	Prot Dev	Prot Dev	Trip/	Breaker	Ground	Equip	Gap	Arc Flash	Working	Incident	Notes
	Device	kV	Bolted Fault	Bolted	Arcing	Delay	Opening	(Y/N)	Туре		Boundary	Distance	Energy	
	Name			Fault (kA)	Fault (kA)	Time	Time (sec.)			(mm)	(m)	(m)	(cal/cm2)	
			(kA)			(sec.)								
TK74 MCC	TK74 MAIN BK	0.48	2.32	2.31	1.60	0.0279	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*N3) (*S7)
FK81 MAIN BK Line Side	LC 81 FDR BK	0.48	2.91	2.91	2.28	0.0192	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S7)
K81 MCC	TK81 MAIN BK	0.48	2.91	2.91	2.28	0.0192	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*S7)
K82 MAIN BK Line Side	LC 82 FDR BK	0.48	3.14	3.14	2.44	0.0187	0.0000	Yes	PNL	25	0.12	0.45	0.14	(*S7)
TK82 MCC	TK82 MAIN BK	0.48	3.14	3.14	2.44	0.0187	0.0000	Yes	PNL	25	0.12	0.45	0.14	(*S7)
K83 MAIN BK Line side	LC 83 FDR BK	0.48	3.94	3.94	2.96	0.0171	0.0000	Yes	PNL	25	0.13	0.45	0.15	(*S7)
FK83 MCC	TK83 MAIN BK	0.48	3.94	3.94	2.96	0.0171	0.0000	Yes	PNL	25	0.13	0.45	0.15	(*S7)
K84 MAIN BK Line Side	LC 84 FDR BK	0.48	4.78	4.77	3.49	0.0163	0.0000	Yes	PNL	25	0.14	0.45	0.18	(*S7)
K84 MCC	TK84 MAIN BK	0.48	4.78	4.77	3.49	0.0163	0.0000	Yes	PNL	25	0.14	0.45	0.18	(*S7)
TK85 MAIN BK Line Side	LC 85 FDR BK	0.48	6.37	6.36	4.45	0.0153	0.0000	Yes	PNL	25	0.16	0.45	0.21	(*S7)
TK85 MCC	TK85 MAIN BK	0.48	6.37	6.36	4.45	0.0153	0.0000	Yes	PNL	25	0.16	0.45	0.21	(*S7)
TK86 MAIN BK Line Side	LC 86 FDR BK	0.48	3.70	3.69	2.79	0.0176	0.0000	Yes	PNL	25	0.13	0.45	0.15	(*S7)
TK86 MCC	TK86 MAIN BK	0.48	3.70	3.69	2.79	0.0176	0.0000	Yes	PNL	25	0.13	0.45	0.15	(*S7)
TK87 MAIN BK Line Side	LC 87 FDR BK	0.48	2.83	2.81	1.89	0.0237	0.0000	Yes	PNL	25	0.12	0.45	0.13	(*N3) (*S7)
K87 MCC	TK87 MAIN BK	0.48	2.83	2.81	2.22	0.0181	0.0000	Yes	PNL	25	0.11	0.45	0.12	(*S7)
K90/88 MAIN BK Line Side	LC 90/88 FDR BK	0.48	4.93	4.89	3.55	0.0175	0.0000	Yes	PNL	25	0.15	0.45	0.19	(*S7)
K90/88 MCC	TK90/88 MAIN BK	0.48	4.93	4.89	3.55	0.0173	0.0000	Yes	PNL	25	0.15	0.45	0.19	(*S7)
X-A Sec Side	SUB1-PDC1A Relay (50/51P)	0.48	13.89	10.47	6.54	0.0167	0.0830	No	PNL	25	0.89	0.45	3.56	(*N5) (*S7)
X-B Sec Side	SUB1-PDC1A Relay (50/51P)	0.48	13.08	9.89	6.23	0.0167	0.0830	No	PNL	25	0.86	0.45	3.38	(*N5) (*S7)
X-E Sec Side	SUB1-PDC1A Relay (50/51P)	0.48	9.84	8.57	5.63	0.0167	0.0830	Yes	PNL	25	0.63	0.45	2.05	(*N5) (*S7)

(\*N1) - Out of IEEE 1584 Range; Lee Equation Used


(\*N2) - <80% Cleared Fault Threshold


(\*N3) - Arcing Current Low Tolerances Used

(\*N5) - Miscoordinated, Upstream Device Tripped


(\*N9) - Max Arcing Duration Reached


(\*S7) - AF Maintenance Mode -1 jet fuel (\*S8) - AF Maintenance Mode-no jet fuel








### From Page 1 ΔΨ T4 ₽ΥΥ **Burnaby Terminal** Substation 2 Equipment - Page 3 of 6 MCC-LC-4 MAIN BK Line Side ■Incident Energy 9.2 Cal/cm^2 Working Distance 0.46 m Flash Boundary 1.6 m Arc Flash Analysis \*\*\* Maintenance Mode \*\*\* MCC-LC-4 MAIN BK G-LC-4 BK ATS-LC-4 Incident Energy 0.4 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.2 m ) LC4A-MCC LINE Bkr PFC-LC4 FD BK LC 71 FDR BK LC 73 FDR BK LC 81 FDR BK LC 83 FDR BK LC 85 FDR BK LC 87 FDR BK P-LC4A-MCC TK71 MAIN BK Line Side Incident Energy 0.1 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m TK73 MAIN BK Line Side Incident Energy 0.1 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m TK81 MAIN BK Line Side Incident Energy 0.1 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m TK83 MAIN BK Line side Incident Energy 0.2 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m TK85 MAIN BK Line Side Incident Energy 0.2 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.2 m TK87 MAIN BK Line Side Incident Energy 0.1 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m PFC-LC-4 LC4A-MCC MAIN Bkr Line Side Incident Energy 0.2 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.2 m TK71 MAIN BK TK73 MAIN BK TK81 MAIN BK TK83 MAIN BK TK85 MAIN BK TK87 MAIN BK TK85 MCC Incident Energy 0.2 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.2 m \_TK87 MCC Incident Energy 0.1 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m TK81 MCC Incident Energy 0.1 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m TK71 MCC TK83 MCC TK73 MCC Incident Energy 0.1 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m Incident Energy 0.1 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m Incident Energy 0.2 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m MCP-MXR83 MCP-MXR71 MCP-MXR73 MCP-MXR81 MCP-MXR85 MCP-MXR87 LC4A-MCC MAIN Bkr MOV-TK85 MOV-TK73 MOV-TK81 MOV-TK83 MOV-TK71 MOV-TK87 LOAD-TK71 LOAD-TK73 LOAD-TK81 LOAD-TK83 LOAD-TK85 LOAD-TK87 BB-LC4A-MCC Incident Energy 0.2 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.1 m ) BPM-89 Bkr LC4A-LP1 Bkr P-LC4A-VFD1 P-LC4A-LP1 BB-LC4A-VFD1 LC4A-LP1 BB-LC4A-MCC<50HP ₹ P-BPM-89 BM-89

















# From Page 1 ∆∰ BB-ESB2-TXR1 BB-ESB2-GEN **Burnaby Terminal Substation 1 Equipment - Page 4 of 4 Arc Flash Analysis** ) BB-ESB2-GEN Bkr P-ESB2-TRS \*\*\* Maintenance Mode \*\*\* P-ESB2-GEN \*\*\* One of Jet Fuel Pumps is Running \*\*\* BB-ESB2-TRS P-ESB2-MCC ESB2-MCC MAIN Bkr Line side Incident Energy 5.2 Cal/cm^2 Working Distance 0.46 m Flash Boundary 1.1 m ESB2-MCC MAIN Bkr BB-ESB2-MCC Incident Energy 2.6 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.7 m ESB2A-MCC LINE Bkr ESB2-LP1 Bkr BPM-12 Bkr BPM-22 Bkr BPM-32 Bkr ESB2-AHU Bkr P-ESB2A-MCC P-ESB1-VFD12 P-ESB1-VFD22 P-ESB1-VFD32 P-ESB2-LP1 BB-ESB2-MCC<50HP P-ESB2-AHU BB-ESB2-VFD22 Line Side Incident Energy 0.9 Cal/cm\*2 Working Distance 0.46 m Hash Boundary 0.4 m BB-ESB2-VFD22 BB-ESB2-VFD12 Line Side Incident Energy 0.9 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.4 m BB-ESB2-VFD12 BB-ESB2-VFD32 Line Side Incident Energy 0.9 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.4 m BB-ESB2-VFD32 ESB2-LP1 ESB2-AHU ₹ P-BPM-12 ≥ P-BPM-22 ► P-BPM-32 ESB2A-MCC MAIN Bkr Line Side Incident Energy 0.7 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.3 m → BPM-22 → BPM-32 BPM-12 ESB2A-MCC MAIN Bkr BB-ESB2A Incident Energy 0.7 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.3 m ESB2A-LP1 Bkr P-ESB2A-LP1

BB-ESB2A-MCC<50HP


ESB2A-LP1








# From Page 1 BB-ESB2-TXR1 ₽Y G BB-ESB2-GEN **Burnaby Terminal** BB-ESB2-GEN Bkr ₹ P-ESB2-TRS Substation 1 Equipment - Page 4 of 4 P-ESB2-GEN Arc Flash Analysis \*\*\* Maintenance Mode \*\*\* BB-ESB2-TRS \*\*\* None of Jet Fuel Pumps is Running \*\*\* P-ESB2-MCC ESB2-MCC MAIN Bkr Line side Incident Energy 5.1 Cal/cm^2 Working Distance 0.46 m Flash Boundary 1.1 m ESB2-MCC MAIN Bkr BB-ESB2-MCC Incident Energy 2.6 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.7 m ESB2A-MCC LINE Bkr ESB2-LP1 Bkr BPM-12 Bkr BPM-22 Bkr BPM-32 Bkr ESB2-AHU Bkr P-ESB1-VFD12 P-ESB1-VFD22 P-ESB1-VFD32 P-ESB2A-MCC P-ESB2-LP1 BB-ESB2-MCC<50HP P-ESB2-AHU BB-ESB2-VFD12 Line Side Incident Energy 0.9 Cal/cm^2 Working Distance 0.46 m BB-ESB2-VFD12 Line Side Incident Energy 0.9 Cal/cm^2 Working Distance 0.46 m BB-ESB2-VFD12 Working Distance 0.46 m BB-ESB2-VFD12 BB-ESB2-VFD12 Working Distance 0.46 m BB-ESB2-VFD12 Working Distance 0.46 m BB-ESB2-VFD12 BB-ESB2-VFD12 BB-ESB2-VFD12 Working Distance 0.46 m BB-ESB2-VFD12 ESB2-LP1 ESB2-AHU P-BPM-12 P-BPM-22 F-BPM-32 ESB2A-MCC MAIN Bkr Line Side Incident Energy 0.7 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.3 m BPM-12 BPM-22 BPM-32 ESB2A-MCC MAIN Bkr BB-ESB2A ESB2A-LP1 Bkr Incident Energy 0.7 Cal/cm^2 Working Distance 0.46 m Flash Boundary 0.3 m ₹ P-ESB2A-LP1 BB-ESB2A-MCC<50HP ESB2A-LP1



Branch #1-BB-ESB1-MCC IN-SVC TCC

Current Scale: x 1
Reference Voltage: 600



Burnaby Terminal(AF In Service Mode-1 jet fuel ) Proiect Name: Branch #1-BB-ESB1-MCC IN-SVC TCC.tcc TCC Name: Reference Voltage: 600 V Current Scale: x 10^0 TCC Notes: TCC Comment: Fault Duty Option: Study Result - Bus Fault Current ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION, AND APPLICATION BY A REGISTERED ENGINEER ONLY. SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING FROM THE USE AND INTERPRETATION OF THIS SOFTWARE. CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting) COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 Device Name: BB-ESB1-TXR1
Bus Name: BB-ESB1-TXR1 Prim Side TCC Name: Branch #1-BB-ESB1-MCC IN-SVC TCC.tcc Bus Voltage: 124/0.0v Tcc Current Multiplier: 1 Bus Voltage: 12470.0V / 600V Tcc Time Multiplier: 1 Tcc Time Adder: Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/600 LL Nominal kVA: 2000.0kVĀ Full Load kVA: 2000.0kVĀ Pri Connection: Delta Sec Connection: Wye-Ground

Impedance (%Z): 6.0000 Inrush Factor: 12.0x

TCC Name: Bus Voltage: Device Name: SUB1 Fdr Relay (50/51P) Branch #1-BB-ESB1-MCC IN-SVC TCC.tcc

Bus Name: SUB1 Xmer Prim Side 12470.0V

Function Name: Phase Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 3362.2A 850 Type: AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0 Test Points: @2.0X, 4.375s Setting: 1) 51P 1 (300A)

@5.0x, 0.762s 2) IEEE, Ext. Inverse 0.61

@10.0x, 0.246s

Device Name: SUB1 Xmer TCC Name: Branch #1-BB-ESB1-MCC IN-SVC TCC.tcc

Bus Name: SUB1 Xmer Prim Side Bus Voltage: 12470.0V / 12470V

Tcc Current Multiplier: 1 Tcc Time Adder: 0

Tcc Time Multiplier: 1 12470 LL/12470 LL

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 Nominal kVA: 5000.0kVA Pri Connection: Delta Full Load kVA: 5000.0kVA Sec Connection: Wye-Ground

Impedance (%Z): 8.0000

Device Name: SUB1 Xmer Pirm Relay (50/51P) TCC Name: Branch #1-BB-ESB1-MCC IN-SVC TCC.tcc Bus Name: SUB1 Xmer Prim Side Bus Voltage: 12470.0V

Function Name: Phase

Manufacturer: GE MULTILIN Description: 50/51P

Type: 845 Class Desc: 845 AIC Rating: N/A
Current Rating: 300A / 5A
Tcc Time Multiplier: 1
Setting: 1) Phase TOC1
2) IEEE Mod Inv

Current Multiplier: 1
Tcc Time Adder: 0
Test Points: @2.0X, 4.184s
2) IEEE Mod Inv

Current Multiplier: 1
Tcc Time Adder: 0
Test Points: @2.0X, 4.184s

@5.0x, 1.857s @10.0x, 1.327s

Device Name: BB-ESB1-MCC LINE (50/51P) TCC Name: Branch #1-BB-ESB1-MCC IN-SVC TCC.tcc Bus Name: SUB1-PDC1 Bus Voltage: 12470.0V Function Name: Phase

Manufacturer: GE MULTILIN Description: 50/51P

Class Desc: GE-850 Fault Duty: 2168.6A 850 Type: AIC Rating: N/A TCC Time Multiplier: 1
Setting: 1) 51P
2) IEEE, Ext. Inverse

TCC Current Multiplier: 1
TCC Time Adder: 0
Test Points: @2.0X, 5.020s
@5 0Y 0 9750

@10.0x, 0.283s

TCC Name: Branch #1-BB-ESB1-MCC IN-SVC TCC.tcc Bus Voltage: 600.0V Device Name: BPM-11 Bkr

Bus Name: BB-ESB1-MCC

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 300-600A

Type: HLD AIC Rating: 35kA Fault Duty: 20727.0A

HLD 600V 600A Tcc Current Multiplier: 1 Frame: Tcc Time Adder: Tcc Time Multiplier: 1

Trip: 400A

Setting: 1) Thermal Curve (Fixed

2) INST (5-10 x Trip) 8.52 (3408A)

TCC Name: Bus Voltage: Branch #1-BB-ESB1-MCC IN-SVC TCC.tcc ESB1-MCC MAIN Bkr Device Name:

Bus Name: BB-ESB1-MCC 600.0V

Function Name: Phase

Manufacturer: MERLIN GERIN

LSI, 2000A Sensor Description: Type: Masterpact, STR 58U

Fault Duty: 20727.0A Tcc Current Multiplier: 1 AIC Rating: 65kA ShortTime:65 MC20H1 600V 2000A Frame: Tcc Time Multiplier: 1 Tcc Time Adder:

Sensor: 2000A Plug: 2000A

Setting: 1) LTPU (lo x lr x S) 2) LTD (15-480 Sec.) 1; 1 (2000A)

3) STPU (1.5-10 x LTPU) 10 (20000A)

4) STD (INST-0.4) I∧2 t Out 0.1

5) INST (2-20 x S) 4 (8000A)


TCC Name: BPM-11 Branch #1-BB-ESB1-MCC IN-SVC TCC.tcc Device Name: BUS-0043 Bus Voltage: 600.0V Bus Name:

Tcc Current Multiplier: 1 Tcc Time Adder: Tcc Time Multiplier: 1

6.5 (1881.4A) Description: Motor Starting Curve Inrush: Rated Size: 300HP (1 of 1 Plotted) FLA+Load Adder: 289.5A + 0.0A


Power Factor: 0.8 Starting Time: 5.00s

0.93 Full Voltage (Square Transient) Efficiency:



Branch #2-BB-ESB2-MCC IN-SVC TCC

Current Scale: x 10 Reference Voltage: 600



Burnaby Terminal(AF In Service Mode-1 jet fuel ) Proiect Name:

Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc TCC Name:

Reference Voltage: 600 V x 10^1 Current Scale:

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION.

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

Device Name: BB-ESB2-TXR1
Bus Name: BB-ESB2-TXR1 Prim Side Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc TCC Name:

Bus Voltage: 12470.0V / 600V Tcc Current Multiplier: 1

Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/600 LL

Nominal kVA: 2000.0kVA Full Load kVA: 2000.0kVA Pri Connection: Delta Sec Connection: Wye-Ground Impedance (%z): 6.0000 Inrush Factor: 12.0x

TCC Name: Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc Bus Voltage: 12470.0V Device Name: SUB1 Breaker

SUB1 Xmer Prim Side Bus Name:

Function Name: Phase Manufacturer: GE

600-3000A Description: PVDB1 Type:

AIC Rating: 16kA Fault Duty: 3362.2A Frame:

Tcc Time Multiplier: 1 Tcc Time Adder: 0

TCC Name: Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc Bus Voltage: 12470.0V Device Name: SUB1 Fdr Relay (50/51P)

Bus Name: SUB1 Xmer Prim Side

Function Name: Phase

Manufacturer: GE MULTILIN Description: 50/51P

850 Type: Class Desc: GE-850 Fault Duty: 3362.2A N/A AIC Rating: Current Rating: 300A / 5A Tcc Time Multiplier: 1 Tcc Current Multiplier: 1 Tcc Time Adder: 0

Setting: 1) 51P 1 (300A)
2) IEEE, Ext. Inverse 0.61 Test Points: @2.0x, 4.375s @5.0x, 0.762s

@10.0x, 0.246s

TCC Name: Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc Bus Voltage: 12470.0V / 12470V Device Name: SUB1 Xmer Bus Name: SUB1 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Adder: 0 Tcc Time Multiplier: 1

Rated Volts: 12470 LL/12470 LL

Description: 2-Winding Transformer Damage Curve
Nominal kVA: 5000.0kVA
Full Load kVA: 5000.0kVA
Impedance (%Z): 8.0000 Pri Connection: Delta

Sec Connection: Wye-Ground Inrush Factor: 12.0x

Device Name: SUB1 Xmer Pirm Relay (50/51P)
Bus Name: SUB1 Xmer Prim Side
Function Name: Phase TCC Name: Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc Bus Voltage: 12470.0V

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: 845
Fault Duty: 3362.2A
Tcc Current Multiplier: 1 845 Type: N/A AIC Rating: Current Rating: 300A / 5A
Tcc Time Multiplier: 1 Tcc Time Adder: 0

@10.0x. 1.327s

Device Name: BB-ESB2-MCC LINE (50/51P) TCC Name: Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc Bus Name: SUB1-PDC1 Bus Voltage: 12470.0V Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

850 class Desc: GE-850 Type: Fault Duty: 2168.6A Tcc Current Multiplier: 1 AIC Rating: N/A Current Rating: 100A / 5A Tcc Time Adder: 0 Tcc Time Multiplier: 1

Test Points: @2.0x, 5.020s Setting: 1) 51P 1 (100A)

2) IEEE, Ext. Inverse 0.7 @5.0x, 0.875s 30 (3000A) @10.0X, 0.283s

TCC Name: Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc Bus Voltage: 12470.0V Device Name: BB-ESB2-MCC LINE Bkr Bus Name: SUB1-PDC1

Function Name: Phase
Manufacturer: TOSHIBA
Description: 600-3000A

Type: VK

AIC Rating: 28kA Frame: VK-10M40A 15000V 1200A Fault Duty: 2168.6A Tcc Current Multiplier: 1

Tcc Time Multiplier: 1 Tcc Time Adder: 0

TCC Name: Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc Bus Voltage: 600.0V

Device Name: BPM-12 Bkr
Bus Name: BB-ESB2-MCC
Function Name: Phase
Manufacturer: CUTLER-HAMMER
Description: 300-600A
Type: HLD
AIC Rating: HLD 600V 600A
Frame: HLD 600V 600A

Fault Duty: 21702.7A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 400A

Setting: 1) Thermal Curve (Fixed

2) INST (5-10 x Trip) 7.47 (2988A)

Device Name: ESB2-MCC MAIN Bkr
Bus Name: BB-ESB2-MCC
Function Name: Phase TCC Name: Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc Bus Voltage: 600.0V

Manufacturer: MERLIN GERIN

Description: LSI, 2000A Sensor Type: Masterpact, STR 58U AIC Rating: 65kA ShortTime:65 Frame: MC20H1 600V 2000A

Fault Duty: 21702.7A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Sensor: 2000A Plug: 2000A Plug:

Setting: 1) LTPU (lo x lr x S) 1; 1 (2000A) 2) LTD (15-480 Sec.) 60

3) STPU (1.5-10 x LTPU) 10 (20000A) 4) STD (INST-0.4) 0.1 I^2 t Out

5) INST (2-20 x S) 4 (8000A)


TCC Name: Branch Bus Voltage: 600.0V Device Name: BPM-12 Branch #2-BB-ESB2-MCC IN-SVC TCC.tcc Bus Name: BUS-0059

Tcc Current Multiplier: 1

Tcc Time Adder: 0
Inrush: 6.5 (1881.4A) Tcc Time Multiplier: 1
Description: Motor Motor Starting Curve 300HP (1 of 1 Plotted)


Rated Size: 300H Power Factor: 0.8

FLA+Load Adder: 289.5A + 0.0A Starting Time: 5.00s Full Voltage (Square Transient) Efficiency: 0.93



Branch #3-MCC-AX IN-SVC TCC Current Scale: x 1

Reference Voltage: 600



#### Branch #3-MCC-AX IN-SVC TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF In Service Mode-1 jet fuel)

Branch #3-MCC-AX IN-SVC TCC.tcc TCC Name:

Reference Voltage: 600 V Current Scale: x 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION,

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

TCC Name: Branch #3-MCC-AX IN-SVC TCC.tcc Bus Voltage: 12470.0V Device Name:

Bus Name: 02-MAIN SERVICE SWGR

Function Name: Phase

Manufacturer: S&C

Description: 5E-200E Standard Speed SMU-20. 14.4kV E-Rated Type:

AIC Rating: 14kA

Fault Duty: 2163.9A Tcc Current Multiplier: 1 Cartridge: SMU-20, 50E 12470V 50A Tcc Time Multiplier: 1 Tcc Time Adder: 0

50A Size:

Device Name: TX-A Bus Name: BUS-0005 TCC Name: Branch #3-MCC-AX IN-SVC TCC.tcc

Bus Voltage: 12470.0V / 480V

Tcc Current Multiplier: 1 Tcc Time Adder: 0

Tcc Time Multiplier: 1

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/480 LL

Nominal kva: 750.0kva Pri Connection: Delta Full Load kVA: 750.0kVA Sec Connection: Wye-Ground Impedance (%Z): 5.9400 Inrush Factor: 12.0x

Device Name: SUB1 Fdr Relay (50/51P)
Bus Name: SUB1 Xmer Prim Side TCC Name: Bus Voltage: Branch #3-MCC-AX IN-SVC TCC.tcc

12470.0v

#### Branch #3-MCC-AX IN-SVC TCC-rpt.txt

Function Name: Phase

Manufacturer: GE MULTILIN Description: 50/51P

850 Type: AIC Rating: N/A Current Rating: 300A / 5A Tcc Time Multiplier: 1

Setting: 1) 51P 1 (300A)

0.61 2) IEEE, Ext. Inverse

class Desc: GE-850 Fault Duty: 3362.2A Tcc Current Multiplier: 1 Tcc Time Adder: 0 Test Points: @2.0X, 4.375s

@5.0x, 0.762s @10.0x, 0.246s

Device Name: SUB1 Xmer TCC Name: Branch #3-MCC-AX IN-SVC TCC.tcc

Bus Voltage: 12470.0V / 12470V Bus Name: SUB1 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve 12470 LL/12470 LL Rated Volts:

Nominal kva: 5000.0kvA Pri Connection: Delta Full Load kVA: 5000.0kVA Sec Connection: Wye-Ground Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Device Name: SUB1 Xmer Pirm Relay (50/51P) TCC Name: Bus Name: SUB1 Xmer Prim Side Bus Voltage: Function Name: Phase Branch #3-MCC-AX IN-SVC TCC.tcc

12470.0V

Manufacturer: GE MULTILIN

50/51P Description:

845 class Desc: Type: 845 Fault Duty: 3362.2A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) 1.1 Setting: 1) Phase TOC1 Test Points: @2.0X, 4.184s 2) IEEE Mod Inv

@5.0x, 1.857s @10.0x, 1.327s

Device Name: SUB1-PDC1/ABUS Name: SUB1-PDC1 TCC Name: Branch #3-MCC-AX IN-SVC TCC.tcc Bus Voltage: 12470.0V SUB1-PDC1A Relay (50/51P)

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 2168.6A 850 Type: AIC Rating: N/A Current Rating: 100A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Branch #3-MCC-AX IN-SVC ICC-IPL.LXL
1 (100A) Test Points: @2.0X, 2.295s
2) IEEE, Ext. Inverse 0.32 @5.0X, 0.400s @10.0x, 0.129s

TCC Name: Branch #3-MCC-AX IN-SVC TCC.tcc 8us Voltage: 480.0V Device Name: PDP1 FDR BK

Bus Name: CDP PANEL BX Function Name: Phase

CUTLER-HAMMER

Manufacturer: CUTLER-H Description: 15-225A

FD Type:

AIC Rating: 25kA Frame: FD 480V 100A Fault Duty: 6712.4A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 100A

Setting: 1) Fixed

TCC Name: Branch #3-MCC-AX IN-SVC TCC.tcc 8us Voltage: 480.0V Device Name: ATS FDR BK

Bus Name: MCC-A

Function Name: Phase Manufacturer: WESTINGHOUSE

Description: 100-400A
Type: KDB, KD
AIC Rating: 35kA
Frame: KD 480V 225A

Fault Duty: 12575.5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 225A

Setting: 1) LTD

2) INST 8 (1800A)

TCC Name: Branch #3-MCC-AX IN-SVC TCC.tcc Bus Voltage: 480.0V Device Name: MCC-A MAIN

Bus Name: MCC-A Function Name: Phase

Manufacturer: CUTLER-HAMMER 700-1200A

Type: NB

AIC Rating: 30kA Frame: NB 480V 800A Fault Duty: 12575.5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 700A

Setting: 1) Thermal Curve (Fixed 2) INST (3000-6000A)

3000 (3000A)

TCC Name: Branch #3-MCC-AX IN-SVC TCC.tcc Bus Voltage: 480.0V Device Name: CDP-BX FDR BK

Bus Name: MCC-AX

Function Name: Phase

CUTLER-HAMMER Manufacturer:


Description: 15-225A Type: HFD

AÍC Rating: 65ka


Fault Duty: 11085.0A Tcc Current Multiplier: 1 Tcc Time Adder: 0 HFD 480V 125A Frame: Tcc Time Multiplier: 1

125A Trip:

Setting: 1) Fixed



Branch #4-MCC-B IN-SVC TCC Current Scale: x 1 Reference Voltage: 480



Proiect Name: Burnaby Terminal(AF In Service Mode-1 jet fuel)

Branch #4-MCC-B IN-SVC TCC.tcc TCC Name:

Reference Voltage: 480 V Current Scale: x 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION,

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

Device Name: SW-B

TCC Name: Branch #4-MCC-B IN-SVC TCC.tcc Bus Voltage: 12470.0V Bus Name: 02-MAIN SERVICE SWGR

Function Name: Phase

Manufacturer: S&C

Description: 5E-200E Standard Speed SMU-20. 14.4kV E-Rated Type:

AIC Rating: 14ka

Fault Duty: 2163.9A Tcc Current Multiplier: 1 Cartridge: SMU-20, 50E 12470V 50A Tcc Time Multiplier: 1 Tcc Time Adder: 0

50A Size:

Device Name: TX-B Bus Name: BUS-0006 TCC Name: Branch #4-MCC-B IN-SVC TCC.tcc

Bus Voltage: 12470.0V / 480V

Tcc Current Multiplier: 1 Tcc Time Adder: Tcc Time Multiplier: 1 0

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/480 LL

Nominal kva: 750.0kva Pri Connection: Delta Full Load kVA: 750.0kVA Sec Connection: Wye-Ground Impedance (%z): 6.0200 Inrush Factor: 12.0x

Device Name: SUB1 Fdr Relay (50/51P)
Bus Name: SUB1 Xmer Prim Side TCC Name: Bus Voltage: Branch #4-MCC-B IN-SVC TCC.tcc

12470.0v

Function Name: Phase

Manufacturer: GE MULTILIN

50/51P Description: 850 class Desc: Type: GE-850 Fault Duty: AIC Rating: N/A 3362.2A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Test Points: @2.0x, 4.375s Setting: 1) 51P 1 (300A) 0.61 2) IEEE, Ext. Inverse

@5.0x, 0.762s @10.0x, 0.246s

Device Name: SUB1 Xmer TCC Name: Branch #4-MCC-B IN-SVC TCC.tcc

Bus Voltage: 12470.0V / 12470V Bus Name: SUB1 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/12470 LL

Nominal kva: 5000.0kvA Pri Connection: Delta Full Load kVA: 5000.0kVA Sec Connection: Wye-Ground

Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Device Name: SUB1 Xmer Pirm Relay (50/51P) TCC Name: Branch #4
Bus Name: SUB1 Xmer Prim Side Bus Voltage: 12470.0V
Function Name: Phase Branch #4-MCC-B IN-SVC TCC.tcc

Manufacturer: GE MULTILIN

50/51P Description:

845 class Desc: Type: 845 Fault Duty: 3362.2A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) 1.1 Setting: 1) Phase TOC1 Test Points: @2.0X, 4.184s 2) IEEE Mod Inv

@5.0x, 1.857s @10.0x, 1.327s

Device Name: SUB1-PDC1A Relay (50/51P)
Bus Name: SUB1-PDC1 TCC Name: Branch #4-MCC-B IN-SVC TCC.tcc Bus Voltage: 12470.0V

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 2168.6A 850 Type: AIC Rating: N/A Current Rating: 100A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Setting: 1) 51P

1) 51P 1 (100A) Test Points: @2.0X, 2.295s 2) IEEE, Ext. Inverse 0.32 @5.0x. 0.400s @10.0x. 0.129s

TCC Name: Branch #4-MCC-B IN-SVC TCC.tcc Bus Voltage: 480.0V Device Name: HMCP-PM#4

Bus Name: MCC-B

Function Name: Phase

Manufacturer: CUTLER-HAMMER
Description: 250A (1000-2000A Inst)

Type: HMCP

AIC Rating: 65kA Frame: HMCP 480V 250A Fault Duty: 12489.9A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Setting: 1) INST (1000-2000A) D (1375A)

TCC Name: Branch #4-MCC-B IN-SVC TCC.tcc Bus Voltage: 480.0V Device Name: MCC-B Bus Name: MCC-B MCC-B MAIN

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 125-800A

Type: MA

AIC Rating: 30kA Frame: MA 480V 800A Fault Duty: 12489.9A Tcc Current Multiplier: 1 Frame: Tcc Time Multiplier: 1 Tcc Time Adder: 0

. 800A Trip:

Setting: 1) Thermal Curve (Fixed

2) INST (3000-6000A) 5000 (5000A)

Device Name: PUMP #4


TCC Name: Branch #4-MCC-B IN-SVC TCC.tcc 8us Voltage: 480.0V Bus Name: MCC-B

Tcc Current Multiplier: 1 Tcc Time Adder: 0 Tcc Time Multiplier: 1


Description: Motor Starting Curve Rated Size: 125HP (1 of 1 Plo 5.9 (855.5A) Inrush: FLA+Load Adder: 145.0A + 0.0A (1 of 1 Plotted)

Starting Time: 6.00s Power Factor: 0.832

Efficiency: 0.93 Full Voltage (Square Transient)



Branch #5-MCC-E IN-SVC TCC Current Scale: x 1 Reference Voltage: 480



Proiect Name: Burnaby Terminal(AF In Service Mode-1 jet fuel)

Branch #5-MCC-E IN-SVC TCC.tcc TCC Name:

Reference Voltage: 480 V Current Scale: x 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION,

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

TCC Name: Branch #5-MCC-E IN-SVC TCC.tcc Bus Voltage: 12470.0V Device Name: SW-E

Bus Name: 02-MAIN SERVICE SWGR

Function Name: Phase

Manufacturer: S&C

5E-200E Standard Speed Description: SMU-20. 14.4kV E-Rated Type:

AIC Rating: 14ka

Fault Duty: 2163.9A SMU-20, 40E 12470V 40A Tcc Current Multiplier: 1 Cartridge: Tcc Time Multiplier: 1 Tcc Time Adder: 0

· 40A Size:

Device Name: TX-E Bus Name: BUS-0007 TCC Name: Branch #5-MCC-E IN-SVC TCC.tcc

Bus Voltage: Branch #5-MCC-E 12470.0V / 480V

Tcc Current Multiplier: 1 Tcc Time Adder: Tcc Time Multiplier: 1 0

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/480 LL

Nominal kva: 500.0kva Pri Connection: Delta Full Load kVA: 625.0kVA Sec Connection: Wye-Ground Impedance (%Z): 4.6000 Inrush Factor: 12.0x

Device Name: SUB1 Fdr Relay (50/51P)
Bus Name: SUB1 Xmer Prim Side TCC Name: Bus Voltage: Branch #5-MCC-E IN-SVC TCC.tcc

12470.0v

Function Name: Phase

Manufacturer: GE MULTILIN 50/51P

Description: 850 class Desc: Type: GE-850 Fault Duty: AIC Rating: N/A 3362.2A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Test Points: @2.0x, 4.375s Setting: 1) 51P 1 (300A) 0.61 2) IEEE, Ext. Inverse

@5.0x, 0.762s @10.0x, 0.246s

Device Name: SUB1 Xmer TCC Name: Branch #5-MCC-E IN-SVC TCC.tcc

Bus Voltage: 12470.0V / 12470V Bus Name: SUB1 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/12470 LL

Nominal kva: 5000.0kvA Pri Connection: Delta Full Load kVA: 5000.0kVA Sec Connection: Wye-Ground

Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Device Name: SUB1 Xmer Pirm Relay (50/51P) TCC Name: Branch #5
Bus Name: SUB1 Xmer Prim Side Bus Voltage: 12470.0V
Function Name: Phase Branch #5-MCC-E IN-SVC TCC.tcc

Manufacturer: GE MULTILIN

50/51P Description:

845 class Desc: Type: 845 Fault Duty: 3362.2A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) 1.1 Setting: 1) Phase TOC1 Test Points: @2.0X, 4.184s 2) IEEE Mod Inv

@5.0x, 1.857s @10.0x, 1.327s

Device Name: SUB1-PDC1/ABUS Name: SUB1-PDC1 TCC Name: Branch #5-MCC-E IN-SVC TCC.tcc Bus Voltage: 12470.0V SUB1-PDC1A Relay (50/51P)

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 2168.6A 850 Type: AIC Rating: N/A Current Rating: 100A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Branch #5-MCC-E IN-SVC ICC-rpt.LXL

1 (100A) Test Points: @2.0X, 2.295s
2) IEEE, Ext. Inverse 0.32 @5.0X, 0.400s @10.0X. 0.129s

TCC Name: Branch #5-MCC-E IN-SVC TCC.tcc Bus Voltage: 480.0V Device Name: MCC-E MAIN

Bus Name: MCC-E Function Name: Phase

Manufacturer: WESTINGHOUSE Description: 125-600A

Type: HLA
AIC Rating: 35kA
Frame: HLA 480V 600A Fault Duty: 9187.4A Tcc Current Multiplier: 1 Tcc Time Adder: 0

Tcc Time Multiplier: 1 Trip: 600A

Trip: Setting: 1) LTD 2) INST

8 (4800A)

Device Name: PLM SHOP BKR Bus Name: MCC-E TCC Name: Branch #5-MCC-E IN-SVC TCC.tcc Bus Voltage: 480.0V

Function Name: Phase

Manufacturer: CUTLER-HAMMER
Description: 15-225A
Type: FDC
AIC Rating: 100kA
Frame: FDC 480V 200A Fault Duty: 9187.4A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 200A

Setting: 1) Fixed

TCC Name: Branch #5-MCC-E IN-SVC TCC.tcc Bus Voltage: 480.0V Tcc Current Multiplier: 1 Device Name: AIR COMP

Bus Name: PLM SHOP MCC

Rated Size: 15HP (1 of 1 Plotted)
Power Factor: 0.85
Efficiency: 0.93 Tcc Time Adder: 0
Inrush: 5.9 (112.1A)
FLA+Load Adder: 19.0A + 0.0A
Starting Time: 10.00s

Full Voltage (Square Transient)

Device Name: HMCP-AComp Bus Name: PLM SHOP MCC Function Name: Phase TCC Name: Branch #5-MCC-E IN-SVC TCC.tcc Bus Voltage: 480.0V


Manufacturer: CUTLER-HAMMER

Description: 30A (90-300A Inst)

Type: AIC Rating: HMCP


Fault Duty: 7735.7A Tcc Current Multiplier: 1 Tcc Time Adder: 0 65kA Frame: HMCP 480V 30A
Tcc Time Multiplier: 1

Setting: 1) INST (90-300A) E (210A)



Branch #6-5kV SWGR IN-SVC TCC

Current Scale: x 1 Reference Voltage: 4160



## Branch #6-5kV SWGR IN-SVC TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF In Service Mode-1 jet fuel)

Branch #6-5kV SWGR IN-SVC TCC.tcc TCC Name:

Reference Voltage: 4160 V x 10^0 Current Scale:

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION,

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

TCC Name: Branch #6-5kV SWGR IN-SVC TCC.tcc Bus Voltage: 12470.0V Device Name: SW-F

Bus Name: 02-MAIN SERVICE SWGR

Function Name: Phase

Manufacturer: S&C

5E-200E Standard Speed Description: SMU-20. 14.4kV E-Rated Type:

AIC Rating: 14ka

Fault Duty: 2163.9A Tcc Current Multiplier: 1 Cartridge: SMU-20, 80E 12470V 80A Tcc Time Multiplier: 1 Tcc Time Adder: 0

Size:

Device Name: TX-F Bus Name: BUS-0008 TCC Name: Branch #6-5kV SWGR IN-SVC TCC.tcc

Bus Voltage: 12470.0V / 4160V

Tcc Current Multiplier: 1 Tcc Time Adder: Tcc Time Multiplier: 1 0

Description: 2-Winding Transformer Damage Curve 12470 LL/4160 LL Rated Volts:

Nominal kva: 1500.0kvA Pri Connection: Delta Full Load kVA: 1680.0kVA Sec Connection: Wye-Ground Impedance (%z): 5.4800 Inrush Factor: 12.0x

Device Name: SUB1 Fdr Relay (50/51P)

Rus Name: SUB1 Xmer Prim Side TCC Name: Bus Voltage: Branch #6-5kV SWGR IN-SVC TCC.tcc

SUB1 Xmer Prim Side Bus Name: 12470.0v

## Branch #6-5kV SWGR IN-SVC TCC-rpt.txt

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P 850

class Desc: Type: GE-850 Fault Duty: AIC Rating: N/A 3362.2A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Test Points: @2.0X, 4.375s Setting: 1) 51P 1 (300A) 2) IEEE, Ext. Inverse 0.61

@5.0x, 0.762s @10.0x, 0.246s

Device Name: SUB1 Xmer TCC Name: Branch #6-5kV SWGR IN-SVC TCC.tcc

Bus Voltage: 12470.0V / 12470V Bus Name: SUB1 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve 12470 LL/12470 LL Rated Volts:

Nominal kva: 5000.0kvA Pri Connection: Delta Full Load kVA: 5000.0kVA Sec Connection: Wye-Ground Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Device Name: SUB1 Xmer Pirm Relay (50/51P) TCC Name: Bus Name: SUB1 Xmer Prim Side Bus Voltage: Function Name: Phase Branch #6-5kV SWGR IN-SVC TCC.tcc

12470.0V

Manufacturer: GE MULTILIN

Description: 50/51P

845 class Desc: Type: 845 Fault Duty: 3362.2A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) 1.1 Setting: 1) Phase TOC1 Test Points: @2.0X, 4.184s 2) IEEE Mod Inv

@5.0x, 1.857s @10.0x, 1.327s

Device Name: SUB1-PDC1A
Bus Name: SUB1-PDC1 TCC Name: Branch #6-5kV SWGR IN-SVC TCC.tcc Bus Voltage: 12470.0V SUB1-PDC1A Relay (50/51P)

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 2168.6A 850 Type: AIC Rating: N/A Current Rating: 100A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Branch #6-5kV SWGR IN-SVC TCC-rpt.txt

Setting: 1) 51P

1) 51P 1 (100A) Test Points: @2.0X, 2.295s 2) IEEE, Ext. Inverse 0.32 @5.0X. 0.400s @10.0x. 0.129s

Branch #6-5kV SWGR IN-SVC TCC.tcc TCC Name:

Device Name: JET FUEL BP #1
Bus Name: SKV SWGR Bus Voltage: 4160.0V Tcc Current Multiplier: 1 Tcc Time Adder: 0 Tcc Time Multiplier: 1

Description: Motor Starting Curve Inrush: 4.0 (248.0A) 500HP (1 of 1 Plotted) Rated Size: FLA+Load Adder: 62.0A + 0.0A

Starting Time: Power Factor: 0.898 10.00s

Efficiency: 0.93 Auto Transformer

TCC Name: Branch #6-5kV SWGR IN-SVC TCC.tcc Bus Voltage: 4160.0V

Device Name: JFBP#1 FU Bus Name: 5KV SWGR

Function Name: Phase Manufacturer: BUSSMANN Description: 30A & 2R-24R

JCL-B, 5.08kV R-Rated Type:

50ka Fault Duty: 2532.9A AIC Rating: Cartridge: JCL-B-4R 5080V 130A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Size: 130A


Device Name: JFBP#1 MPR Bus Name: 5KV SWGR TCC Name: Branch #6-5kV SWGR IN-SVC TCC.tcc Bus Voltage: 4160.0V

Function Name: Phase Manufacturer: GE MULTILIN Description: 49/50

269 Plus class Desc: 269 Plus Type: Fault Duty: 2532.9A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0 Current Rating: 100A / 5A FLA: 62.00A


Setting: 1) O/L Pickup 1.25 (77.5A)
2) O/L Curves Curve 3 Test Points: @2.0X, 87.000s

@5.0x, 10.000s 3) S/C Trip @10.0x, 4.000s 8 (496A)



Branch #7-BB-ESB1-MCC MAINT TCC

Current Scale: x 1
Reference Voltage: 600



#### Branch #7-BB-ESB1-MCC MAINT TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF Maintenance Mode -1 jet fue) Branch #7-BB-ESB1-MCC MAINT TCC.tcc TCC Name:

Reference Voltage: 600 V Current Scale: x 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION.

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

TCC Name: Branch #7-BB-ESB1-MCC MAINT TCC.tcc

Device Name: BB-ESB1-TXR1
Bus Name: BB-ESB1-TXR1 Prim Side Bus Voltage: 12470.0V / 600V

Bus Voltage:
Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/600 LL

Nominal kVA: 2000.0kVĀ Full Load kVA: 2000.0kVĀ Pri Connection: Delta Sec Connection: Wye-Ground Impedance (%Z): 6.0000 Inrush Factor: 12.0x

Device Name: SUB1 Fdr Relay (50/51P) Branch #7-BB-ESB1-MCC MAINT TCC.tcc

TCC Name: Bus Voltage: Bus Name: SUB1 Xmer Prim Side 12470.0V

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 3364.7A 850 Type: AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Test Points: @2.0X, 4.375s Setting: 1) 51P 1 (300A) @5.0x, 0.762s 2) IEEE, Ext. Inverse 0.61

@10.0x, 0.246s

Branch #7-BB-ESB1-MCC MAINT TCC-rpt.txt

TCC Name: Device Name: SUB1 Xmer Branch #7-BB-ESB1-MCC MAINT TCC.tcc

Bus Name: SUB1 Xmer Prim Side Bus Voltage: 12470.0V / 12470V

> Tcc Current Multiplier: 1 Tcc Time Adder: 0

Tcc Time Multiplier: 1 12470 LL/12470 LL

Description: 2-Winding Transformer Damage Curve Rated Volts:
Nominal kVA: 5000.0kVA Pri Connection: Pri Connection: Delta Full Load kVA: 5000.0kVA Sec Connection: Wye-Ground

Impedance (%Z): 8.0000

Device Name: SUB1 Xmer Pirm Relay (50/51P) TCC Name: Branch #7-BB-ESB1-MCC MAINT TCC.tcc Bus Name: SUB1 Xmer Prim Side Bus Voltage: 12470.0V

Function Name: Phase

Manufacturer: GE MULTILIN Description: 50/51P

845 Class Desc: 845 Type: AIC Rating: N/A
Current Rating: 300A / 5A
Tcc Time Multiplier: 1
Tcc Time Multiplier: 1
Setting: 1) Phase ToC1
2) IEEE Mod Inv

Ctass Desc.
Fault Duty: 3364.7A
Tcc Current Multiplier: 1
Tcc Time Adder: 0
Test Points: @2.0X, 4.184s
@5.0X, 1.857s

@5.0x, 1.857s @10.0x, 1.327s

Device Name: BB-ESB1-MCC LINE (50/51P) TCC Name: Branch #7-BB-ESB1-MCC MAINT TCC.tcc Bus Name: SUB1-PDC1 Bus Voltage: 12470.0V Function Name: Phase

Manufacturer: GE MULTILIN Description: 50/51P

Class Desc: GE-850 Fault Duty: 2173.0A 850 Type: N/A AIC Rating: Current Rating: 100A / 5A Tcc Current Multiplier: 1

Tcc Time Multiplier: 1

Setting: 1) 51P

2) IEEE, Ext. Inverse
3) 50P

Tcc Time Adder: 0

Test Points: @2.0X, 5.020s

@5.0X, 0.875s

@10.0X, 0.283s

@10.0x, 0.283s

TCC Name: Branch #7-BB-ESB1-MCC MAINT TCC.tcc Bus Voltage: 600.0V Device Name: BPM-11 Bkr

Bus Name: BB-ESB1-MCC

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 300-600A

Type: HLD AIC Rating: 35kA Fault Duty: 20739.1A Branch #7-BB-ESB1-MCC MAINT TCC-rpt.txt

HLD 600V 600A Tcc Current Multiplier: 1 Frame: Tcc Time Adder: Tcc Time Multiplier: 1

Trip: 400A

Setting: 1) Thermal Curve (Fixed

2) INST (5-10 x Trip) 8.52 (3408A)

Branch #7-BB-ESB1-MCC MAINT TCC.tcc ESB1-MCC MAIN Bkr Device Name:

TCC Name: Bus Voltage: Bus Name: BB-ESB1-MCC 600.0V

Function Name: Phase

MERLIN GERIN Manufacturer:

LSI, 2000A Sensor Description: Type: Masterpact, STR 58U

Fault Duty: 20739.1A Tcc Current Multiplier: 1 AIC Rating: 65kA ShortTime:65 MC20H1 600V 2000A Frame: Tcc Time Multiplier: 1 Tcc Time Adder:

Sensor: 2000A Plug: 2000A

Setting: 1) LTPU (lo x lr x S) 2) LTD (15-480 Sec.) 1; 0.8 (1600A)

3) STPU (1.5-10 x LTPU) 10 (16000A)

4) STD (INST-0.4) 0.1 I<sup>2</sup> t Out

5) INST (2-20 x S) 4 (8000A)


TCC Name: Device Name: BPM-11 Branch #7-BB-ESB1-MCC MAINT TCC.tcc BUS-0043 Bus Voltage: 600.0V Bus Name:

Tcc Current Multiplier: 1 Tcc Time Adder: Tcc Time Multiplier: 1

6.5 (1881.4A) Description: Motor Starting Curve Inrush: Rated Size: 300HP (1 of 1 Plotted) FLA+Load Adder: 289.5A + 0.0A


Power Factor: 0.8 Starting Time: 5.00s

0.93 Full Voltage (Square Transient) Efficiency:



Branch #8-BB-ESB2-MCC MAINT TCC Current Scale: x 10

Reference Voltage: 600



#### Branch #8-BB-ESB2-MCC MAINT TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF Maintenance Mode -1 jet fue)

Branch #8-BB-ESB2-MCC MAINT TCC.tcc TCC Name:

Reference Voltage: 600 V x 10^1 Current Scale:

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION.

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

TCC Name: Branch #8-BB-ESB2-MCC MAINT TCC.tcc

Device Name: BB-ESB2-TXR1
Bus Name: BB-ESB2-TXR1 Prim Side

Bus Voltage: 12470.0V / 600V Tcc Current Multiplier: 1

Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/600 LL

Nominal kVA: 2000.0kVA Full Load kVA: 2000.0kVA Pri Connection: Delta Sec Connection: Wye-Ground Impedance (%z): 6.0000 Inrush Factor: 12.0x

TCC Name: Branch #8-BB-ESB2-MCC MAINT TCC.tcc Bus Voltage: 12470.0V Device Name: SUB1 Breaker

Bus Name: SUB1 Xmer Prim Side

Function Name: Phase Manufacturer: GE

600-3000A Description: PVDB1 Type:

AIC Rating: 16kA Fault Duty: 3364.7A Frame:

Tcc Time Multiplier: 1 Tcc Time Adder: 0

Device Name: SUB1 Fdr Relay (50/51P)
Bus Name: SUB1 Xmer Prim Side TCC Name: Branch #8-BB-ESB2-MCC MAINT TCC.tcc Bus Voltage: 12470.0V

Function Name: Phase

#### Branch #8-BB-ESB2-MCC MAINT TCC-rpt.txt

Manufacturer: GE MULTILIN

Description: 50/51P

850 Type: Class Desc: GE-850 Fault Duty: 3364.7A AIC Rating: N/A Current Rating: 300A / 5A Tcc Time Multiplier: 1 Tcc Current Multiplier: 1 Tcc Time Adder: 0

Setting: 1) 51P 1 (300A)
2) IEEE, Ext. Inverse 0.61 Test Points: @2.0x, 4.375s @5.0x, 0.762s

@10.0x, 0.246s

TCC Name: Branch #8-BB-ESB2-Bus Voltage: 12470.0V / 12470V Device Name: SUB1 Xmer Bus Name: SUB1 Xmer Prim Side Branch #8-BB-ESB2-MCC MAINT TCC.tcc

Tcc Current Multiplier: 1 Tcc Time Adder: 0 Tcc Time Multiplier: 1

Rated Volts: 12470 LL/12470 LL

Description: 2-Winding Transformer Damage Curve
Nominal kVA: 5000.0kVA
Full Load kVA: 5000.0kVA
Impedance (%Z): 8.0000 Pri Connection: Delta

Sec Connection: Wye-Ground Inrush Factor: 12.0x

Device Name: SUB1 Xmer Pirm Relay (50/51P)
Bus Name: SUB1 Xmer Prim Side
Function Name: Phase TCC Name: Branch #8-BB-ESB2-MCC MAINT TCC.tcc Bus Voltage: 12470.0V

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: 845
Fault Duty: 3364.7A
Tcc Current Multiplier: 1 845 Type: N/A AIC Rating: Current Rating: 300A / 5A
Tcc Time Multiplier: 1 Tcc Time Adder: 0

TCC Time Adder: 0
Setting: 1) Phase TOC1 1 (300A) Test Points: @2.0X, 4.184s
2) IEEE Mod Inv 1.1 @5.0X, 1.857s

@10.0x, 1.327s

Device Name: BB-ESB2-MCC LINE (50/51P) TCC Name: Branch #8-BB-ESB2-MCC MAINT TCC.tcc Bus Name: SUB1-PDC1 Bus Voltage: 12470.0V

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850
Fault Duty: 2173.0A
Tcc Current Multiplier: 1 850 Type: AIC Rating: N/A Current Rating: 100A / 5A Tcc Time Adder: 0 Tcc Time Multiplier: 1

Test Points: @2.0x, 5.020s Setting: 1) 51P 1 (100A)

Branch #8-BB-ESB2-MCC MAINT TCC-rpt.txt

U./ @5.0x, 0.875s 4 (400A) 2) IEEE, Ext. Inverse 0.7 @10.0x. 0.283s

TCC Name: Branch #8-BB-ESB2-MCC MAINT TCC.tcc Bus Voltage: 12470.0V Device Name: BB-ESB2-MCC LINE Bkr Bus Name: SUB1-PDC1

Function Name: Phase
Manufacturer: TOSHIBA
Description: 600-3000A

Type: VK

AIC Rating: 28kA Frame: VK-10M40A 15000V 1200A Fault Duty: 2173.0A Tcc Current Multiplier: 1

Tcc Time Adder: 0 Tcc Time Multiplier: 1

TCC Name: Branch #8-BB-ESB2-MCC MAINT TCC.tcc Bus Voltage: 600.0V

Device Name: BPM-12 Bkr
Bus Name: BB-ESB2-MCC
Function Name: Phase
Manufacturer: CUTLER-HAMMER
Description: 300-600A
Type: HLD

AIC Rating: 35kA Frame: HLD 600V 600A Fault Duty: 21714.8A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 400A

Setting: 1) Thermal Curve (Fixed

2) INST (5-10 x Trip) 7.47 (2988A)

TCC Name: Branch #8-BB-ESB2-MCC MAINT TCC.tcc Bus Voltage: 600.0V Device Name: ESB2-MCC MAIN Bkr

Bus Name: BB-ESB2-MCC
Function Name: Phase

Manufacturer: MERLIN GERIN

Description: LSI, 2000A Sensor Type: Masterpact, STR 58U AIC Rating: 65kA ShortTime:65 Frame: MC20H1 600V 2000A

Fault Duty: 21714.8A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Sensor: 2000A Plug: 2000A Plug:

Setting: 1) LTPU (lo x lr x S) 2) LTD (15-480 Sec.) 1; 0.8 (1600A)

60

3) STPU (1.5-10 x LTPU) 10 (16000A) 4) STD (INST-0.4) 0.1 I^2 t Out

## Branch #8-BB-ESB2-MCC MAINT TCC-rpt.txt 5) INST (2-20 x S) 4 (8000A)

Device Name: BPM-12 Branch #8-BB-ESB2-MCC MAINT TCC.tcc


TCC Name: Branch Bus Voltage: 600.0V Bus Name: BUS-0059 Tcc Current Multiplier: 1

Tcc Time Adder: 0
Inrush: 6.5 (1881.4A) Tcc Time Multiplier: 1
Description: Motor Motor Starting Curve 300HP (1 of 1 Plotted)


Rated Size: 300H Power Factor: 0.8

Efficiency: 0.93

FLA+Load Adder: 289.5A + 0.0A Starting Time: 5.00s Full Voltage (Square Transient)



Branch #9-MCC-AX MAINT TCC Current Scale: x 1 Reference Voltage: 600



Proiect Name: Burnaby Terminal(AF Maintenance Mode -1 jet fue)

Branch #9-MCC-AX MAINT TCC.tcc TCC Name:

Reference Voltage: 600 V Current Scale: x 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION.

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

TCC Name: Branch #9-MCC-AX MAINT TCC.tcc Bus Voltage: 12470.0V Device Name:

Bus Name: 02-MAIN SERVICE SWGR

Function Name: Phase

Manufacturer: S&C

5E-200E Standard Speed Description: SMU-20. 14.4kV E-Rated Type:

AIC Rating: 14kA

Fault Duty: 2168.4A Tcc Current Multiplier: 1 Cartridge: SMU-20, 50E 12470V 50A Tcc Time Multiplier: 1 Tcc Time Adder: 0

50A Size:

Device Name: TX-A Bus Name: BUS-0005 TCC Name: Branch #9-MCC-AX MAINT TCC.tcc

Bus Voltage: 12470.0V / 480V

Tcc Current Multiplier: 1 Tcc Time Adder: 0

Tcc Time Multiplier: 1

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/480 LL

Nominal kva: 750.0kva Pri Connection: Delta Full Load kVA: 750.0kVA Sec Connection: Wye-Ground Impedance (%Z): 5.9400 Inrush Factor: 12.0x

Device Name: SUB1 Fdr Relay (50/51P)
Bus Name: SUB1 Xmer Prim Side TCC Name: Bus Voltage: Branch #9-MCC-AX MAINT TCC.tcc

12470.0v

class Desc:

Fault Duty:

Tcc Current Multiplier: 1

Function Name: Phase

Manufacturer: GE MULTILIN 50/51P Description:

850 Type: AIC Rating: N/A Current Rating: 300A / 5A Tcc Time Multiplier: 1

Tcc Time Adder: 0 Test Points: @2.0X, 4.375s Setting: 1) 51P 1 (300A) 0.61 2) IEEE, Ext. Inverse

@5.0x, 0.762s @10.0x, 0.246s

GE-850

3364.7A

Device Name: SUB1 Xmer TCC Name: Branch #9-MCC-AX MAINT TCC.tcc

Bus Voltage: 12470.0V / 12470V Bus Name: SUB1 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/12470 LL

Nominal kva: 5000.0kvA Pri Connection: Delta Full Load kVA: 5000.0kVA Sec Connection: Wye-Ground

Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Device Name: SUB1 Xmer Pirm Relay (50/51P) TCC Name: Branch #9
Bus Name: SUB1 Xmer Prim Side Bus Voltage: 12470.0V
Function Name: Phase Branch #9-MCC-AX MAINT TCC.tcc

Manufacturer: GE MULTILIN

50/51P Description:

Type: 845 class Desc: 845 Fault Duty: 3364.7A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) 1.1 Setting: 1) Phase TOC1 Test Points: @2.0X, 4.184s 2) IEEE Mod Inv

@5.0x, 1.857s @10.0x, 1.327s

Device Name: SUB1-PDC1/ABUS Name: SUB1-PDC1 TCC Name: Branch #9-MCC-AX MAINT TCC.tcc Bus Voltage: 12470.0V SUB1-PDC1A Relay (50/51P)

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 2173.0A 850 Type: AIC Rating: N/A Current Rating: 100A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Setting: 1) 51P

@5.UX, U.4UUS @10.OX, O.129s

TCC Name: Branch #9-MCC-AX MAINT TCC.tcc Bus Voltage: 480.0V Device Name: PDP1 FDR BK

Bus Name: CDP PANEL BX Function Name: Phase

CUTLER-HAMMER

Manufacturer: CUTLER-H Description: 15-225A

FD Type:

AIC Rating: 25kA Frame: FD 480V 100A Fault Duty: 6867.6A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 100A

Setting: 1) Fixed

TCC Name: Branch #9-MCC-AX MAINT TCC.tcc Bus Voltage: 480.0V Device Name: ATS FDR BK

Bus Name: MCC-A

Function Name: Phase Manufacturer: WESTINGHOUSE

Description: 100-400A
Type: KDB, KD
AIC Rating: 35kA
Frame: KD 480V 225A

Fault Duty: 12803.5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 225A

Setting: 1) LTD

2) INST 8 (1800A)

TCC Name: Branch #9-MCC-AX MAINT TCC.tcc Bus Voltage: 480.0V Device Name: MCC-A MAIN

Bus Name: MCC-A Function Name: Phase

Manufacturer: CUTLER-HAMMER 700-1200A

Type: NB

AIC Rating: 30kA Frame: NB 480V 800A Fault Duty: 12803.5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 700A

Setting: 1) Thermal Curve (Fixed 2) INST (3000-6000A)

3000 (3000A)

TCC Name: Branch #9-MCC-AX MAINT TCC.tcc Bus Voltage: 480.0V Device Name: CDP-BX FDR BK

Bus Name: MCC-AX

Function Name: Phase

CUTLER-HAMMER Manufacturer:


Description: 15-225A

Type: HFD AÍC Rating:


Fault Duty: 11300.7A Tcc Current Multiplier: 1 Tcc Time Adder: 0 65kA HFD 480V 125A Frame: Tcc Time Multiplier: 1

125A Trip:

Setting: 1) Fixed



Branch #10-MCC-B MAINT TCC Current Scale: x 1 Reference Voltage: 480



Proiect Name: Burnaby Terminal(AF Maintenance Mode -1 jet fue)

Branch #10-MCC-B MAINT TCC.tcc TCC Name:

Reference Voltage: 480 V Current Scale: x 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION,

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

TCC Name: Branch #10-MCC-B MAINT TCC.tcc Bus Voltage: 12470.0V Device Name: SW-B

Bus Name: 02-MAIN SERVICE SWGR

Function Name: Phase

Manufacturer: S&C

5E-200E Standard Speed Description: SMU-20. 14.4kV E-Rated Type:

AIC Rating: 14ka

2168.4A Fault Duty: Tcc Current Multiplier: 1 Cartridge: SMU-20, 50E 12470V 50A Tcc Time Multiplier: 1 Tcc Time Adder: 0

50A Size:

Device Name: TX-B Bus Name: BUS-0006 TCC Name: Branch #10-MCC-B MAINT TCC.tcc

Bus Voltage: 12470.0V / 480V

Tcc Current Multiplier: 1 Tcc Time Adder: Tcc Time Multiplier: 1 0

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/480 LL

Nominal kva: 750.0kva Pri Connection: Delta Full Load kVA: 750.0kVA Sec Connection: Wye-Ground Impedance (%z): 6.0200 Inrush Factor: 12.0x

Device Name: SUB1 Fdr Relay (50/51P)
Bus Name: SUB1 Xmer Prim Side TCC Name: Bus Voltage: Branch #10-MCC-B MAINT TCC.tcc

12470.0v

Function Name: Phase

Manufacturer: GE MULTILIN 50/51P

Description: 850 class Desc: Type: GE-850 Fault Duty: AIC Rating: N/A 3364.7A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Test Points: @2.0X, 4.375s Setting: 1) 51P 1 (300A) 0.61 2) IEEE, Ext. Inverse

@5.0x, 0.762s @10.0x, 0.246s

TCC Name: Branch #10-MCC-B M Bus Voltage: 12470.0V / 12470V Device Name: SUB1 Xmer Branch #10-MCC-B MAINT TCC.tcc

Bus Name: SUB1 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/12470 LL

Nominal kva: 5000.0kvA Pri Connection: Delta Full Load kVA: 5000.0kVA Sec Connection: Wye-Ground

Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Device Name: SUB1 Xmer Pirm Relay (50/51P) TCC Name: Branch #1
Bus Name: SUB1 Xmer Prim Side Bus Voltage: 12470.0V
Function Name: Phase Branch #10-MCC-B MAINT TCC.tcc

Manufacturer: GE MULTILIN

50/51P Description:

845 class Desc: Type: 845 Fault Duty: 3364.7A AIC Rating: N/A Tcc Current Multiplier: 1 Current Rating: 300A / 5A Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) 1.1 Setting: 1) Phase TOC1 Test Points: @2.0X, 4.184s

@5.0x, 1.857s @10.0x, 1.327s 2) IEEE Mod Inv

Device Name: SUB1-PDC1A Relay (50/51P)
Bus Name: SUB1-PDC1 TCC Name: Branch #10-MCC-B MAINT TCC.tcc Bus Voltage: 12470.0V

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 2173.0A 850 Type: AIC Rating: N/A Current Rating: 100A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Setting: 1) 51P

3) 50P 1 (100A) @10.0x. 0.129s

TCC Name: Branch #10-MCC-B MAINT TCC.tcc Bus Voltage: 480.0V Device Name: HMCP-PM#4

Bus Name: MCC-B

Function Name: Phase

Manufacturer: CUTLER-HAMMER
Description: 250A (1000-2000A Inst)

Type:
AIC Rating: 65kA
HMCP\_480V 250A Fault Duty: 12500.3A Tcc Current Multiplier: 1 Tcc Time Adder: 0

Setting: 1) INST (1000-2000A) D (1375A)

TCC Name: Branch #10-MCC-B MAINT TCC.tcc Bus Voltage: 480.0V Device Name: MCC-B MAIN

MCC-B Bus Name:

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 125-800A

Type: MA

AIC Rating: 30kA Frame: MA 480V 800A Fault Duty: 12500.3A Tcc Current Multiplier: 1 Frame: Tcc Time Multiplier: 1 Tcc Time Adder: 0

. 800A Trip:

Setting: 1) Thermal Curve (Fixed

2) INST (3000-6000A) 5000 (5000A)


TCC Name: Branch #10-MCC-B MAINT TCC.tcc Bus Voltage: 480.0V Device Name: PUMP #4 Bus Name: MCC-B

Tcc Current Multiplier: 1 Tcc Time Adder: 0 Tcc Time Multiplier: 1


Description: Motor Starting Curve Rated Size: 125HP (1 of 1 Plo 5.9 (855.5A) Inrush: FLA+Load Adder: 145.0A + 0.0A (1 of 1 Plotted)

Power Factor: 0.832 Starting Time: 6.00s

Efficiency: 0.93 Full Voltage (Square Transient)



Branch #11-MCC-E MAINT TCC Current Scale: x 1 Reference Voltage: 480



Proiect Name: Burnaby Terminal(AF Maintenance Mode -1 jet fue)

Branch #11-MCC-E MAINT TCC.tcc TCC Name:

Reference Voltage: 480 V Current Scale: x 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION.

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

TCC Name: Branch #11-MCC-E MAINT TCC.tcc Bus Voltage: 12470.0V Device Name: SW-E

Bus Name: 02-MAIN SERVICE SWGR

Function Name: Phase Manufacturer: S&C

5E-200E Standard Speed Description:

SMU-20. 14.4kV E-Rated Type:

AIC Rating: 14ka

Fault Duty: 2168.4A SMU-20, 40E 12470V 40A Tcc Current Multiplier: 1 Cartridge: Tcc Time Multiplier: 1 Tcc Time Adder: 0

40A Size:

Device Name: TX-E Bus Name: BUS-0007 TCC Name: Branch #11-MCC-E MAINT TCC.tcc

Bus Voltage: 12470.0V / 480V

Tcc Current Multiplier: 1 Tcc Time Adder: Tcc Time Multiplier: 1 0

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/480 LL

Nominal kva: 500.0kva Pri Connection: Delta Full Load kVA: 625.0kVA Sec Connection: Wye-Ground Impedance (%Z): 4.6000 Inrush Factor: 12.0x

Device Name: SUB1 Fdr Relay (50/51P)
Bus Name: SUB1 Xmer Prim Side TCC Name: Bus Voltage: Branch #11-MCC-E MAINT TCC.tcc

12470.0v

Function Name: Phase

Manufacturer: GE MULTILIN

50/51P Description: 850 class Desc: Type: GE-850 Fault Duty: AIC Rating: N/A 3364.7A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Test Points: @2.0X, 4.375s Setting: 1) 51P 1 (300A) 0.61 2) IEEE, Ext. Inverse

@5.0x, 0.762s @10.0x, 0.246s

TCC Name: Branch #11-MCC-E M Bus Voltage: 12470.0V / 12470V Device Name: SUB1 Xmer Branch #11-MCC-E MAINT TCC.tcc

Bus Name: SUB1 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/12470 LL

Nominal kva: 5000.0kvA Pri Connection: Delta

Full Load kVA: 5000.0kVA Sec Connection: Wye-Ground Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Device Name: SUB1 Xmer Pirm Relay (50/51P) TCC Name: Branch #1
Bus Name: SUB1 Xmer Prim Side Bus Voltage: 12470.0V
Function Name: Phase Branch #11-MCC-E MAINT TCC.tcc

Manufacturer: GE MULTILIN

50/51P Description:

845 class Desc: Type: 845 Fault Duty: 3364.7A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) 1.1 Setting: 1) Phase TOC1 Test Points: @2.0X, 4.184s

@5.0x, 1.857s @10.0x, 1.327s 2) IEEE Mod Inv

Device Name: SUB1-PDC1/ABUS Name: SUB1-PDC1 TCC Name: Branch #11-MCC-E MAINT TCC.tcc Bus Voltage: 12470.0V SUB1-PDC1A Relay (50/51P)

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 2173.0A 850 Type: AIC Rating: N/A Current Rating: 100A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Branch #11-MCC-E MAINT TCC-rpt.txt

Setting: 1) 51P

1) 51P 1 (100A) Test Points: @2.0X, 2.295s
2) IEEE, Ext. Inverse 0.32 @5.0X, 0.400s
3) 50P 1 (100A) @10.0X, 0.1299 @5.0X, 0.40Us @10.0X, 0.129s

TCC Name: Branch #11-MCC-E MAINT TCC.tcc Bus Voltage: 480.0V Device Name: MCC-E MAIN

Bus Name: MCC-E Function Name: Phase

Manufacturer: WESTINGHOUSE Description: 125-600A

Type: HLA
AIC Rating: 35kA
Frame: HLA 480V 600A Fault Duty: 9195.3A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 600A

Setting: 1) LTD
2) INST

8 (4800A)

Device Name: PLM SHOP BKR Bus Name: MCC-E TCC Name: Branch #11-MCC-E MAINT TCC.tcc Bus Voltage: 480.0V

Function Name: Phase

Manufacturer: CUTLER-HAMMER
Description: 15-225A
Type: FDC
AIC Rating: 100kA
Frame: FDC 480V 200A Fault Duty: 9195.3A

Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 200A Setting: 1) Fixed

TCC Name: Branch #11-MCC-E MAINT TCC.tcc Bus Voltage: 480.0V
Tcc Current Multiplier: 1 Device Name: AIR COMP

Bus Name: PLM SHOP MCC

Rated Size: 15HP (1 of 1 Plotted)
Power Factor: 0.85
Efficiency: 0.93 Tcc Time Adder: 0
Inrush: 5.9 (112.1A)
FLA+Load Adder: 19.0A + 0.0A
Starting Time: 10.00s

Full Voltage (Square Transient)

Device Name: HMCP-AComp Bus Name: PLM SHOP MCC Function Name: Phase TCC Name: Branch #11-MCC-E MAINT TCC.tcc Bus Voltage: 480.0V

Branch #11-MCC-E MAINT TCC-rpt.txt


Manufacturer: CUTLER-HAMMER

Description: 30A (90-300A Inst)

Type: AIC Rating: HMCP


Fault Duty: 7741.9A Tcc Current Multiplier: 1 Tcc Time Adder: 0 65kA Frame: HMCP 480V 30A
Tcc Time Multiplier: 1

Setting: 1) INST (90-300A) E (210A)



Branch #12-5kV SWGR MAINT TCC

Current Scale: x 1 Reference Voltage: 4160



### Branch #12-5kV SWGR MAINT TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF Maintenance Mode -1 jet fue)

Branch #12-5kV SWGR MAINT TCC.tcc TCC Name:

Reference Voltage: 4160 V x 10^0 Current Scale:

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION.

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

TCC Name: Branch #12-5kV SWGR MAINT TCC.tcc Bus Voltage: 12470.0V Device Name: SW-F

Bus Name: 02-MAIN SERVICE SWGR

Function Name: Phase

Manufacturer: S&C

5E-200E Standard Speed Description: SMU-20. 14.4kV E-Rated Type:

AIC Rating: 14ka

2168.4A Fault Duty: Tcc Current Multiplier: 1 Cartridge: SMU-20, 80E 12470V 80A Tcc Time Multiplier: 1 Tcc Time Adder: 0

Size:

Device Name: TX-F Bus Name: BUS-0008 TCC Name: Branch #12-5kV SWGR MAINT TCC.tcc

Bus Voltage: 12470.0V / 4160V

Tcc Current Multiplier: 1 Tcc Time Adder: Tcc Time Multiplier: 1 0

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/4160 LL

Nominal kva: 1500.0kvA Pri Connection: Delta Full Load kVA: 1680.0kVA Sec Connection: Wye-Ground Impedance (%Z): 5.4800 Inrush Factor: 12.0x

Device Name: SUB1 Fdr Relay (50/51P)
Bus Name: SUB1 Xmer Prim Side TCC Name: Bus Voltage: Branch #12-5kV SWGR MAINT TCC.tcc

SUB1 Xmer Prim Side Bus Name: 12470.0v

#### Branch #12-5kV SWGR MAINT TCC-rpt.txt

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P 850 Type: AIC Rating: N/A

Current Rating: 300A / 5A

Tcc Time Multiplier: 1

Setting: 1) 51P 1 (300A)

2) IEEE, Ext. Inverse 0.61 class Desc: GE-850 Fault Duty: 3364.7A Tcc Current Multiplier: 1 Tcc Time Adder: 0

Test Points: @2.0X, 4.375s

@5.0x, 0.762s @10.0x, 0.246s

Device Name: SUB1 Xmer TCC Name: Branch #12-5kV SWGR MAINT TCC.tcc

Bus Voltage: 12470.0V / 12470V Bus Name: SUB1 Xmer Prim Side Tcc Current Multiplier: 1

Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve 12470 LL/12470 LL Rated Volts:

Nominal kva: 5000.0kvA Pri Connection: Delta Full Load kVA: 5000.0kVA Sec Connection: Wye-Ground

Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Device Name: SUB1 Xmer Pirm Relay (50/51P) TCC Name: Bus Name: SUB1 Xmer Prim Side Bus Voltage: Function Name: Phase Branch #12-5kV SWGR MAINT TCC.tcc

12470.0V

Manufacturer: GE MULTILIN

Description: 50/51P

845 class Desc: Type: 845 Fault Duty: 3364.7A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) 1.1 Setting: 1) Phase TOC1 Test Points: @2.0X, 4.184s 2) IEEE Mod Inv

@5.0x, 1.857s @10.0x, 1.327s

Device Name: SUB1-PDC1/ABUS Name: SUB1-PDC1 TCC Name: Branch #12-5kV SWGR MAINT TCC.tcc Bus Voltage: 12470.0V SUB1-PDC1A Relay (50/51P)

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 2173.0A 850 Type: AIC Rating: N/A Current Rating: 100A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Branch #12-5kV SWGR MAINT TCC-rpt.txt

1 (10 0.32 1 (100A) Test Points: @2.0X, 2.295s Setting: 1) 51P

2) IEEE, Ext. Inverse @5.0x, 0.400s 3) 50P 1 (100A) @10.0x. 0.129s

JET FUEL BP #1 Branch #12-5kV SWGR MAINT TCC.tcc Device Name: TCC Name:

Bus Name: 5KV SWGR Bus Voltage: 4160.0V Tcc Current Multiplier: 1

Tcc Time Adder: 0 Tcc Time Multiplier: 1

Description: Motor Starting Curve Inrush: 4.0 (248.0A) 500HP (1 of 1 Plotted) Rated Size: FLA+Load Adder: 62.0A + 0.0A

Starting Time: Power Factor: 0.898 10.00s

Efficiency: 0.93 Auto Transformer

TCC Name: Branch #12-5kV SWGR MAINT TCC.tcc Bus Voltage: 4160.0V

Device Name: JFBP#1 FU Bus Name: 5KV SWGR

Function Name: Phase Manufacturer: BUSSMANN Description: 30A & 2R-24R

JCL-B, 5.08kV R-Rated Type:

50ka Fault Duty: 2534.5A AIC Rating: Cartridge: JCL-B-4R 5080V 130A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Size: 130A

Device Name: JFBP#1 MPR Bus Name: 5KV SWGR TCC Name: Branch #12-5kV SWGR MAINT TCC.tcc Bus Voltage: 4160.0V


Function Name: Phase Manufacturer: GE MULTILIN

Description: 49/50

269 Plus class Desc: 269 Plus Type: Fault Duty: 2534.5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0 Current Rating: 100A / 5A FLA: 62.00A


Setting: 1) O/L Pickup Test Points: @2.0x, 87.000s

1.25 (77.5A)
Curve 3 2) O/L Curves @5.0x, 10.000s 3) S/C Trip @10.0x, 4.000s 8 (496A)



Branch #13-SHELLMONT MV GROUND FAULT TCC Current Scale: x 1

Reference Voltage: 12470



### Branch #13-SHELLMONT MV GROUND FAULT TCC-rpt.txt

Project Name: Burnaby Terminal(AF In Service Mode-1 jet fuel) Branch #13-SHELLMONT MV GROUND FAULT TCC.tcc TCC Name: Reference Voltage: 12470 V Current Scale: X 10^0 TCC Notes: TCC Comment: Fault Duty Option: Study Result - Bus Fault Current ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION, AND APPLICATION BY A REGISTERED ENGINEER ONLY. SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING FROM THE USE AND INTERPRETATION OF THIS SOFTWARE. CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting) COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 Device Name: BB-ESB1-MCC LINE (50/51G) FAULT TCC.tcc TCC Name: Branch #13-SHELLMONT MV GROUND Bus Name: SUB1-PDC1 Bus Voltage: 12470.0V Function Name: Neutral Manufacturer: GE MULTILIN Description: 50/51G Class Desc: GE-850 Fault Duty: 15.0A 850 Type: AIC Rating: N/A Current Rating: 50A / 5A Tcc Time Multiplier: 1 Tcc Current Multiplier: 1 Tcc Time Adder: 0 Tcc Time Adder: 0 0.05 (2.5A) Test Points: @2.0X, 0.200s 0.2 (seconds) @5.0X, 0.200s Setting: 1) 50G 2) Definite Time @10.0X, 0.200s Device Name: BB-ESB2-MCC LINE (50/51G) TCC Name: Branch #13-SHELLMONT MV GROUND FAULT TCC.tcc SUB1-PDC1 Bus Voltage: 12470.0V Bus Name: Function Name: Neutral Manufacturer: GE MULTILIN 50/51G Description: Class Desc: GE-850 Fault Duty: 15.0A Type: 850 AIC Rating: N/A Current Rating: 50A / 5A Tcc Time Multiplier: 1 Tcc Current Multiplier: 1 Tcc Time Adder: 0

Test Points: @2.0X, 0.200s

@5.0x, 0.200s

1) 50G 0.05 (2.5A)
2) Definite Time 0.2 (seconds)

Setting: 1) 50G

### Branch #13-SHELLMONT MV GROUND FAULT TCC-rpt.txt @10.0x, 0.200s

TCC Name: Branch #13-SHELLMONT MV GROUND Device Name: SUB1 Xmer Relay (51G)

FAULT TCC.tcc

Bus Name: SUB1-PDC1 Bus Voltage: 12470.0V

Function Name: Neutral

Function Name.
Manufacturer: STARTCO
Description: 50/ 51G/ 51N, CT200
SE-325 Class Desc: SE-325 Fault Duty: 15.0A Type: SE-3 AIC Rating: N/A Current Rating: 200A / 5A
Tcc Time Multiplier: 1
Setting: 1) GF Trip Level 4 (4A)
2) GF Trip Time 0.42 (seconds)

Tcc Time Adder: 0
Test Points: @2.0X, 0.420s
@5.0X, 0.419s
@10.0X, 0.419s Current Rating: 200A / 5A
Tcc Time Multiplier: 1 Tcc Current Multiplier: 1

@10.0x. 0.419s

Device Name: SUB1-PDC1A Relay (50/51G) TCC Name: Branch #13-SHELLMONT MV GROUND

FAULT TCC.tcc


Bus Name: SUB1-PDC1 Bus Voltage: 12470.0V

Function Name: Neutral Manufacturer: GE MULTILIN Description: 50/51G

Class Desc: GE-850 Fault Duty: 15.0A Tcc Current Multiplier: 1 850 Type: AIC Rating: N/A Current Rating: 50A / 5A
Tcc Time Multiplier: 1
Setting: 1) 50G Tcc Time Adder: 0 Test Points: @2.0X, 0.200s


1) 50G 0.05 (2.5A)
2) Definite Time 0.2 (seconds) @5.0x, 0.200s

@10.0x, 0.200s



Branch #14-BB-ESB1-MCC GROUND FAULT TCC

Current Scale: x 1 Reference Voltage: 600



# Branch #14-BB-ESB1-MCC GROUND FAULT TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF In Service Mode-1 jet fuel)

Branch #14-BB-ESB1-MCC GROUND FAULT TCC.tcc TCC Name:

Reference Voltage: 600 V Current Scale: x 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION,

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016

Device Name: ESB1-MCC MAIN Bkr TCC Name: Branch #14-BB-ESB1-MCC GROUND FAULT TCC.tcc

Bus Name: BB-ESB1-MCC

Function Name: Neutral Manufacturer: MERLIN GERIN

GF, 1600-2500A Sensors Description:

Masterpact, STR 58U Type:

AIC Rating: 65kA ShortTime:65 Fault Duty: 19941.7A MC20H1 600V 2000A Tcc Current Multiplier: 1 Frame: Tcc Time Multiplier: 1 Tcc Time Adder: 0


2000A Sensor: 2000A Plug:

250A (250A)

Setting: 1) GFPU (250-1200A) 2) GFD (0.1-0.4) I^2 t Out 0.2


Bus Voltage:

600.0V



Branch #15-BB-ESB2-MCC GROUND FAULT TCC

Current Scale: x 1 Reference Voltage: 600



## Branch #15-BB-ESB2-MCC GROUND FAULT TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF In Service Mode-1 jet fuel)

Branch #15-BB-ESB2-MCC GROUND FAULT TCC.tcc TCC Name:

Reference Voltage: 600 V Current Scale: x 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION,

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

Branch #15-BB-ESB2-MCC GROUND FAULT Device Name: ESB2-MCC MAIN Bkr TCC Name:

TCC.tcc

Bus Name: BB-ESB2-MCC

Bus Voltage: 600.0V

Function Name: Neutral MERLIN GERIN Manufacturer:


GF, 1600-2500A Sensors Description: Masterpact, STR 58U Type:

AIC Rating: 65kA ShortTime:65 Fault Duty: 20501.6A MC20H1 600V 2000A Tcc Current Multiplier: 1 Frame: Tcc Time Adder: 0 Tcc Time Multiplier: 1

2000A Sensor: 2000A Plug:


250A (250A)

Setting: 1) GFPU (250-1200A) 2) GFD (0.1-0.4) I^2 t Out 0.2



Branch #1-BB-ESB3A-MCC IN-SVC TCC Current Scale: x 1

Reference Voltage: 600



# Branch #1-BB-ESB3A-MCC IN-SVC TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF In Service Mode-1 jet fuel)

Branch #1-BB-ESB3A-MCC IN-SVC TCC.tcc TCC Name:

Reference Voltage: 600 V x 10^0 Current Scale:

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION.

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 201.112011. 2101. 2101. 2101. 2101. 2202.

TCC Name: Branch #1-BB-ESB3A-MCC IN-SVC Device Name: SUB2 Fdr Relay (50/51P)

TCC.tcc

Bus Name: SUB2 Xmer Prim Side

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

850 Type: N/A AIC Rating: Current Rating: 300A / 5A
TCC Time Multiplier: 1
Setting: 1) 51P

Setting: 1) 51P 1 (300 2) IEEE, Ext. Inverse 0.63 1 (300A)

Class Desc: GE-850 Fault Duty: 2474.1A Tcc Current Multiplier: 1 Tcc Time Adder:

Bus Voltage: 12470.0V

Test Points: @2.0x, 4.518s @5.0x, 0.787s

@10.0x. 0.254s

Device Name: SUB2 Xmer TCC Name: Branch #1-BB-ESB3A-MCC IN-SVC

TCC.tcc

Bus Name: SUB2 Xmer Prim Side Bus Voltage: 12470.0V / 4160V

Tcc Current Multiplier: 1 Tcc Time Adder:

Tcc Time Multiplier: 1

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/4160 LL

Nominal kva: 1500.0kvA Pri Connection: Delta Full Load kVA: 1500.0kVA Sec Connection: Wye-Ground Branch #1-BB-ESB3A-MCC IN-SVC TCC-rpt.txt

Device Name: SUB2 Xmer Prim Relay (50/51P) TCC Name: Branch #1-BB-ESB3A-MCC IN-SVC

TCC.tcc

Bus Name: SUB2 Xmer Prim Side Function Name: Phase Bus Voltage: 12470.0V

Manufacturer: GE MULTILIN Description: 50/51P

Class Desc: 845 Fault Duty: 2474.1A 845 Type: Type: 845 AIC Rating: N/A Tcc Current Multiplier: 1 Current Rating: 300A / 5A Tcc Time Multiplier: 1

Setting: 1) Phase ToC1

2) IEEE Mod Inv

Tcc Current Multiplier: 1

Tcc Time Adder: 0

Test Points: @2.0x, 0.456s

@5.0x, 0.203s

@5.0x, 0.203s @10.0x, 0.145s

Device Name: BB-ESB3-TXR1 TCC Name: Branch #1-BB-ESB3A-MCC IN-SVC

TCC.tcc

Bus Voltage: 4160.0V / 600V Bus Name: BB-ESB3-TXR1 Prim Side

Tcc Current Multiplier: 1

Tcc Time Multiplier: 1 Tcc Time Adder: 0

Description: 2-Winding Transformer Damage Curve Rated Volts: 4160 LL/600 LL Nominal kVA: 500.0kVA Pri Connection: Delta

Full Load kVA: 500.0kVA
Impedance (%Z): 5.0000 Sec Connection: Wye-Ground Inrush Factor: 12.0x

Device Name: BB-ESB3-MCC LINE (50/51P) TCC Name: Branch #1-BB-ESB3A-MCC IN-SVC TCC.tcc

Bus Name: SUB2-PDC1

Bus Voltage: 4160.0V

Function Name: Phase

Manufacturer: GE MULT Description: 50/51P GE MULTILIN

Type: 850

Class Desc: GE-850 Fault Duty: 2337.7A AIC Rating: N/A Tcc Current Multiplier: 1 Current Rating: 100A / 1A

Tcc Time Multiplier: 1

Setting: 1) 51P

2) IEEE, Ext. Inverse

1.01

Tcc Time Adder: 0

Test Points: @2.0x, 7.243s

@5.0x, 1.262s

@10.0x, 0.408

@10.0x, 0.408s

TCC Name: Branch #1-BB-ESB3A-MCC IN-SVC Device Name: BB-ESB3A-MCC LINE Bkr

TCC.tcc

Branch #1-BB-ESB3A-MCC IN-SVC TCC-rpt.txt 600.0V Bus Name: BB-ESB3-MCC Bus Voltage: Function Name: Phase Manufacturer: CUTLER-HAMMER Description: 100-400A Type: HKD 35kA HKD 600V 400A Fault Duty: 6777.3A AIC Rating: Tcc Current Multiplier: 1 Frame: Tcc Time Multiplier: 1 Tcc Time Adder: 0 Trip: 400A Setting: 1) Thermal Curve (Fixed 2) INST (5-10 x Trip) 7.31 (2924A) TCC Name: Device Name: ESB3-MCC MAIN Bkr Branch #1-BB-ESB3A-MCC IN-SVC TCC.tcc Bus Name: BB-ESB3-MCC Bus Voltage: 600.0V Function Name: Phase Manufacturer: CUTLER-HAMMER 70-600A Description: Type: HLAFault Duty: 6777.3A AIC Rating: 25kA HLA 600V 600A Tcc Current Multiplier: 1 Frame: Tcc Time Multiplier: 1 Tcc Time Adder: 0 Trip: 500A Setting: 1) Thermal Curve (Fixed 2) INST (5-10 x Trip) 5 (2500A) TCC Name: Device Name: BB-ESB3A-MCC Main Bkr Branch #1-BB-ESB3A-MCC IN-SVC TCC.tcc BB-ESB3A-MCC Bus Voltage: 600.0V Bus Name: Function Name: Phase Manufacturer: CUTLER-HAMMER Description: 100-400A Type: HKD 35kA µv~ Fault Duty: 6186.0A AIC Rating: HKD 600V 400A Tcc Current Multiplier: 1 Frame: Tcc Time Multiplier: 1 Tcc Time Adder: 0 400A Trip: Setting: 1) Thermal Curve (Fixed 2) INST (5-10 x Trip) 5 (2000A) TCC Name: Branch #1-BB-ESB3A-MCC IN-SVC Device Name: BM-98 Bkr

## Branch #1-BB-ESB3A-MCC IN-SVC TCC-rpt.txt

TCC.tcc

Bus Voltage: 600.0V Bus Name: BB-ESB3A-MCC

Function Name: Phase

Manufacturer: CUTLER-HAMMER

Description: 15-225A Type: FDC

AIC Rating: 35kA

Fault Duty: 6186.0A FDC 600V 30A Tcc Current Multiplier: 1 Frame: Tcc Time Adder: Tcc Time Multiplier: 1

Trip: 30A

Setting: 1) Fixed

Device Name: BM-98 TCC Name: Branch #1-BB-ESB3A-MCC IN-SVC

TCC.tcc


Bus Voltage: 600.0V Tcc Current Multiplier: 1 Bus Name: BUS-0119

Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 6.5 (125.4A) Motor Starting Curve Inrush: 19.3A + 0.0A(1 of 1 Plotted) Rated Size: 20HP FLA+Load Adder:


Power Factor: 0.8 Starting Time: 5.00s

Full Voltage (Square Transient) Efficiency: 0.93



Branch #2-BB-ESB4-MCC IN-SVC TCC

Current Scale: x 1
Reference Voltage: 600



#### Branch #2-BB-ESB4-MCC IN-SVC TCC-rpt.txt

Burnaby Terminal(AF In Service Mode-1 jet fuel ) Proiect Name:

Branch #2-BB-ESB4-MCC IN-SVC TCC.tcc TCC Name:

Reference Voltage: 600 V x 10^0 Current Scale:

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION,

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

TCC Name: Branch #2-BB-ESB4-MCC IN-SVC TCC.tcc Bus Voltage: 12470.0V

Device Name: SUB2 Fdr Relay (50/51P)
Bus Name: SUB2 Xmer Prim Side
Function Name: Phase

Manufacturer: GE MULTILIN Description: 50/51P

Type: 850 Class Desc: GE-850 Fault Duty: 2474.1A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) Setting: 1) 51P Test Points: @2.0X, 4.518s @5.0x, 0.787s 2) IEEE, Ext. Inverse 0.63

@10.0x, 0.254s

TCC Name: Branch #2-BB-ESBBus Voltage: 12470.0V / 4160V Branch #2-BB-ESB4-MCC IN-SVC TCC.tcc Device Name: SUB2 Xmer

Bus Name: SUB2 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/4160 LL

Pri Connection: Delta Nominal kVA: 1500.0kvA Full Load kVA: 1500.0kVA Sec Connection: Wye-Ground Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Branch #2-BB-ESB4-MCC IN-SVC TCC-rpt.txt

Device Name: SUB2 Xmer Prim Relay (50/51P) TCC Name: Branch #2-BB-ESB4-MCC IN-SVC TCC.tcc Bus Voltage: 12470.0V

Function Name: Phase

Manufacturer: GE MULTILIN Description: 50/51P

845 Class Desc: 845 Type: AIC Rating: N/A Fault Duty: 2474.1A TCC Time Multiplier: 1
Setting: 1) Phase TOC1
2) IEEE Mod Inv

TCC Time Adder: 0
Test Points: @2.0X, 0.456s
0.12

@10.0x, 0.145s

Device Name: BB-ESB4-TXR1 TCC Name: Branch #2-BB-ESB4-MCC IN-SVC TCC.tcc
Bus Name: BB-ESB4-TXR1 Prim Side Bus Voltage: 4160.0V / 600V
Tcc Current Multiplier: 1
Tcc Time Multiplier: 1
Tcc Time Adder: 0
Description: 2-Winding Transformer Damage Curve
Nominal ky4: 100 Oky4

Pri Connection: Delta
Sec Connection: Wye-Ground
Inrush Factor: 12.0x Nominal kVA: 100.0kVA Full Load kVA: 100.0kVA

Impedance (%z): 5.0000

Device Name: BB-ESB4-MCC LINE (50/51P) TCC Name: Branch #2-BB-ESB4-MCC IN-SVC TCC.tcc Bus Name: SUB2-PDC1 Bus Voltage: 4160.0V

Manufacturer: GE MULTILIN Description: 50/51P

Class Desc: GE-850 Fault Duty: 2337.7A 850 Type: AIC Rating: N/A Current Rating: 100A / 1A Tcc Current Multiplier: 1 Current Rating: 100A / 1A

Tcc Time Multiplier: 1

Setting: 1) 51P
2) IEEE, Ext. Inverse

Tcc Current Multiplier: 1

Tcc Time Adder: 0

Test Points: @2.0X, 1.147s

@5.0X, 0.200s

@10.0x, 0.065s

TCC Name: Branch #2-BB-ESB4-MCC IN-SVC TCC.tcc Bus Voltage: 600.0V Device Name: ESB4-MCC MAIN Bkr

Bus Name: BB-ESB4-MCC

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 100-400A


Type: HKD AIC Rating: 35kA

Fault Duty: 1879.2A

Frame: HKD 600V 225A
Tcc Time Multiplier: 1
Trip: 225A


Trip: 225A
Setting: 1) Thermal Curve (Fixed
2) INST (5-10 x Trip)

5 (1125A)



Branch #3-BB-ESB5C-MCC IN-SVC TCC Current Scale: x 1

Reference Voltage: 600



# Branch #3-BB-ESB5C-MCC IN-SVC TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF In Service Mode-1 jet fuel)

Branch #3-BB-ESB5C-MCC IN-SVC TCC.tcc TCC Name:

Reference Voltage: 600 V x 10^0 Current Scale:

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION.

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 201 112011 2101 21012 2101 2101 2020

Device Name: SUB2 Fdr Relay (50/51P) TCC Name: Branch #3-BB-ESB5C-MCC IN-SVC

TCC.tcc

Bus Name: SUB2 Xmer Prim Side Bus Voltage: 12470.0V

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

Class Desc: GE-850 Fault Duty: 2474.1A 850 Type: N/A AIC Rating: Current Rating: 300A / 5A
TCC Time Multiplier: 1
Setting: 1) 51P Tcc Current Multiplier: 1 Tcc Time Adder:

Setting: 1) 51P 1 (300 2) IEEE, Ext. Inverse 0.63 Test Points: @2.0x, 4.518s 1 (300A) @5.0x, 0.787s

@10.0x. 0.254s

Device Name: SUB2 Xmer TCC Name: Branch #3-BB-ESB5C-MCC IN-SVC

TCC.tcc

Bus Name: SUB2 Xmer Prim Side Bus Voltage: 12470.0V / 4160V

Tcc Current Multiplier: 1 Tcc Time Adder:

Tcc Time Multiplier: 1

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/4160 LL

Nominal kva: 1500.0kvA Pri Connection: Delta Full Load kVA: 1500.0kVA Sec Connection: Wye-Ground Branch #3-BB-ESB5C-MCC IN-SVC TCC-rpt.txt

Device Name: SUB2 Xmer Prim Relay (50/51P) TCC Name: Branch #3-BB-ESB5C-MCC IN-SVC

TCC.tcc

Bus Name: SUB2 Xmer Prim Side Function Name: Phase Bus Voltage: 12470.0V

Manufacturer: GE MULTILIN Description: 50/51P

Class Desc: 845 Fault Duty: 2474.1A 845 Type: AIC Rating: N/A Tcc Current Multiplier: 1 Current Rating: 300A / 5A Tcc Time Multiplier: 1 Tcc Time Adder: 0

Tcc Time Multiplier: 1
Setting: 1) Phase ToC1 1 (300A)
2) IEEE Mod Inv 0.12 Test Points: @2.0X, 0.456s

@5.0x, 0.203s @10.0x, 0.145s

Device Name: BB-ESB5-TXR1 TCC Name: Branch #3-BB-ESB5C-MCC IN-SVC

TCC.tcc

Bus Voltage: 4160.0V / 600V Bus Name: BB-ESB5-TXR1 Prim Side

Tcc Current Multiplier: 1

Tcc Time Multiplier: 1 Tcc Time Adder: 0

Description: 2-Winding Transformer Damage Curve Rated Volts: 4160 L Nominal kVA: 500.0kVA Pri Connection: Delta 4160 LL/600 LL

Full Load kVA: 500.0kVA Sec Connection: Wye-Ground Impedance (%Z): 5.0000 Inrush Factor: 12.0x

Device Name: BB-ESB5-MCC LINE (50/51P) TCC Name: Branch #3-BB-ESB5C-MCC IN-SVC

TCC.tcc

Bus Name: SUB2-PDC1 Bus Voltage: 4160.0V

Function Name: Phase

Manufacturer: Description: GE MULTILIN

50/51P

Class Desc: GE-850 Fault Duty: 2337.7A Type: 850 AIC Rating: N/A Tcc Current Multiplier: 1 Current Rating: 100A / 1A 

@10.0x, 0.202s

TCC Name: Branch #3-BB-ESB5C-MCC IN-SVC Device Name: ESB5-MCC MAIN Bkr

TCC.tcc

Branch #3-BB-ESB5C-MCC IN-SVC TCC-rpt.txt Bus Voltage: 600.0V Bus Name: BB-ESB5-MCC Function Name: Phase Manufacturer: CUTLER-HAMMER Description: 70-600A Type: HLA AIC Rating: 25kA Frame: HLA 600V 600A Fault Duty: 6030.5A Tcc Current Multiplier: 1 Frame: HLA 60 Tcc Time Multiplier: 1 Tcc Time Adder: 0 Trip: 500A Setting: 1) Thermal Curve (Fixed 2) INST (5-10 x Trip) 5 (2500A) Device Name: ESB5C-MCC LINE Bkr TCC Name: Branch #3-BB-ESB5C-MCC IN-SVC TCC.tcc Bus Name: BB-ESB5-MCC Bus Voltage: 600.0V Function Name: Phase Manufacturer: Description: CUTLER-HAMMER 100-400A Type: HKD AIC Rating: 35kA Frame: HKD 600V 225A Fault Duty: 6030.5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0 Trip: 225A Setting: 1) Thermal Curve (Fixed 2) INST (5-10 x Trip) 6.78 (1525.5A) TCC Name: Branch #3-BB-ESB5C-MCC IN-SVC Device Name: BM-74 Bkr TCC.tcc Bus Voltage: Bus Name: BB-ESB5C-MCC 600.0V Function Name: Phase Manufacturer: CUTLER-HAMMER Description: 15-225A Type: FDC AIC Rating: 35kA Frame: FDC 600V 30A Fault Duty: 5536.8A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0 Trip: Setting: 1) Fixed

TCC Name: Branch #3-BB-ESB5C-MCC IN-SVC

Device Name: ESB5C-MCC MAIN Bkr

TCC.tcc

Branch #3-BB-ESB5C-MCC IN-SVC TCC-rpt.txt

Bus Name: BB-ESB5C-MCC Bus Voltage: 600.0V

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 100-400A

Type: HKD

AIC Rating: 35kA
Frame: HKD 600V 225A
Tcc Time Multiplier: 1
Tcc Time Adder: 0

Trip: 225A

Setting: 1) Thermal Curve (Fixed

2) INST (5-10 x Trip) 5 (1125A)

\_\_\_\_\_\_

Device Name: BM-74 TCC Name: Branch #3-BB-ESB5C-MCC IN-SVC


TCC.tcc

Bus Name: BUS-0133 Bus Voltage: 600.0V
Tcc Current Multiplier: 1

Description: Motor Starting Curve Inrush: 6.5 (125.4A)
Rated Size: 20HP (1 of 1 Plotted) FLA+Load Adder: 19.3A + 0.0A


Power Factor: 0.8 Starting Time: 5.00s

Efficiency: 0.93 Full Voltage (Square Transient)



Branch #4-BB-LC3A-MCC IN-SVC TCC

Current Scale: x 1
Reference Voltage: 480



## Branch #4-BB-LC3A-MCC IN-SVC TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF In Service Mode-1 jet fuel) Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc TCC Name: Reference Voltage: 480 V x 10^0 Current Scale: TCC Notes: TCC Comment: Fault Duty Option: Study Result - Bus Fault Current ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION, AND APPLICATION BY A REGISTERED ENGINEER ONLY. SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

Device Name: SUB2 Fdr Relay (50/51P)
Bus Name: SUB2 Xmer Prim Side
Function Name: Phase TCC Name: Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc Bus Voltage: 12470.0V

Manufacturer: GE MULTILIN Description: 50/51P

Tcc Time Multiplier: 1

Type: 850 Class Desc: GE-850 Fault Duty: 2474.1A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) Setting: 1) 51P Test Points: @2.0x, 4.518s @5.0x, 0.787s 2) IEEE, Ext. Inverse 0.63

@10.0x, 0.254s

Device Name: TCC Name: Branch #4-BB-LC3/Bus Voltage: 12470.0V / 4160V Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc SUB2 Xmer

Bus Name: SUB2 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/4160 LL

Pri Connection: Delta Nominal kVA: 1500.0kvA Full Load kVA: 1500.0kVA Sec Connection: Wye-Ground Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Branch #4-BB-LC3A-MCC IN-SVC TCC-rpt.txt

TCC Name: Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc
Bus Voltage: 12470.0V Device Name: SUB2 Xmer Prim Relay (50/51P)

Bus Name: SUB2 Xmer Prim Side

Function Name: Phase

GE MULTILIN Manufacturer:

Description: 50/51P

Type: 845 Class Desc: 845 AIC Rating: N/A Fault Duty: 2474.1A Tcc Current Multiplier: 1 Current Rating: 300A / 5A Tcc Time Multiplier: 1 Tcc Time Adder: 0
Test Points: @2.0X, 0.456s

1 (300A) 0.12 Setting: 1) Phase TOC1 2) IEEE Mod Inv

@5.0x, 0.203s @10.0x, 0.145s

Device Name: LC3-MCC LINE Relay (50/51P) TCC Name: Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc Bus Voltage: 4160.0V

Bus Name: SUB2-PDC1

Function Name: Phase

Manufacturer: GE MULTILIN Description: 50/51P

850 Type: Class Desc: GE-850 AIC Rating: N/A

Fault Duty: 2337.7A Current Rating: 100A / 1A Tcc Current Multiplier: 1

@5.0x, 0.612s

@10.0x, 0.198s

Device Name: T-3
Bus Name: T-3 Prim Side TCC Name: Branch #4-BB-LC Bus Voltage: 4160.0V / 480V Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc

Tcc Current Multiplier: 1 Tcc Time Adder: 0 Tcc Time Multiplier: 1

Description: 2-Winding Transformer Damage Curve Nominal kVA: 500.0kVA Rated Volts: 4160 LL/480 LL

Pri Connection: Delta Full Load kVA: 500.0kVA Sec Connection: Wye-Ground Impedance (%z): 4.8000 Inrush Factor: 12.0x

TCC Name: Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc Bus Voltage: 480.0V Device Name: BM-80 Bkr

Bus Name: BB-LC3A-MCC

Function Name: Phase

CUTLER-HAMMER Manufacturer:

Description: 15-225A

Type: FD AIC Rating: 35kA

Fault Duty: 6858.8A

Branch #4-BB-LC3A-MCC IN-SVC TCC-rpt.txt

Frame: FD 480V 50A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 50A Setting: 1) Fixed

TCC Name: Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc 8us Voltage: 480.0V Device Name: LC3A-MCC MAIN Bkr Bus Name: BB-LC3A-MCC

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 100-400A Type: HKD

AIC Rating: 65kA Frame: HKD 480V 225A Fault Duty: 6858.8A Tcc Current Multiplier: 1 Tcc Time Adder: 0 Tcc Time Multiplier: 1

Trip: 225A

Setting: 1) Thermal Curve (Fixed

2) INST (5-10 x Trip) 6.64 (1494A)

TCC Name: Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc 480.0V Device Name: BM-80 Bus Name: BUS-0076

Tcc Current Multiplier: 1

Tcc Time Multiplier: 1 Tcc Time Adder: 0

Description: Motor Starting Curve
Rated Size: 20HP (1 of 1 Plotted)
Power Factor: 0.8 6.5 (156.8A) Inrush: FLA+Load Adder: 24.1A + 0.0A

Starting Time: 5.00s Efficiency: 0.93 Full Voltage (Square Transient) Full Voltage (Square Transient)

Device Name: LC3A-MCC LINE Bkr Bus Name: MCC LC-3 TCC Name: Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc

Bus Voltage: 480.0V

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 100-400A

Type: HKD

AIC Rating: 65kA Frame: HKD 480V 225A Fault Duty: 7860.0A Tcc Current Multiplier: 1 Tcc Time Adder: 0

Tcc Time Multiplier: 1 Trip: 225A

Setting: 1) Thermal Curve (Fixed 2) INST (5-10 x Trip) 8.93 (2009.3A)

TCC Name: Branch #4-BB-LC3A-MCC IN-SVC TCC.tcc Device Name: MCC-LC-3 MAIN BK

Branch #4-BB-LC3A-MCC IN-SVC TCC-rpt.txt ine Side Bus Voltage: MCC-LC-3 MAIN BK Line Side 480.0V Bus Name:

Function Name: Phase

Manufacturer: CUTLER-HAMMER 125-800A Description:


Type: MΑ

AIC Rating: 30kA Fault Duty: 7938.7A Frame: MA 480V 800A Tcc Time Multiplier: 1 Tcc Current Multiplier: 1
Tcc Time Adder: 0

Trip: 800a


Setting: 1) Thermal Curve (Fixed 2) INST (3000-6000A)

3000 (3000A)



Branch #5-BB-LC4A-MCC IN-SVC TCC

Current Scale: x 1
Reference Voltage: 480



#### Branch #5-BB-LC4A-MCC IN-SVC TCC-rpt.txt

Proiect Name: Burnaby Terminal(AF In Service Mode-1 jet fuel) Branch #5-BB-LC4A-MCC IN-SVC TCC.tcc TCC Name:

Reference Voltage: 480 V x 10^0 Current Scale:

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION,

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

Device Name: SUB2 Fdr Relay (50/51P)
Bus Name: SUB2 Xmer Prim Side
Function Name: Phase TCC Name: Branch #5-BB-LC4A-MCC IN-SVC TCC.tcc Bus Voltage: 12470.0V

Manufacturer: GE MULTILIN Description: 50/51P

Type: 850 Class Desc: GE-850 Fault Duty: 2474.1A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) Setting: 1) 51P Test Points: @2.0x, 4.518s @5.0x, 0.787s 2) IEEE, Ext. Inverse 0.63

@10.0x, 0.254s

Device Name: TCC Name: Branch #5-BB-LC4/Bus Voltage: 12470.0V / 4160V Branch #5-BB-LC4A-MCC IN-SVC TCC.tcc SUB2 Xmer

Bus Name: SUB2 Xmer Prim Side

Tcc Current Multiplier: 1

Tcc Time Multiplier: 1 Tcc Time Adder:

Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/4160 LL

Pri Connection: Delta Nominal kVA: 1500.0kvA Full Load kVA: 1500.0kVA Sec Connection: Wye-Ground Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Branch #5-BB-LC4A-MCC IN-SVC TCC-rpt.txt

TCC Name: Branch #5-BB-LC4A-MCC IN-SVC TCC.tcc
Bus Voltage: 12470.0V Device Name: SUB2 Xmer Prim Relay (50/51P)

SUB2 Xmer Prim Side Bus Name:

Function Name: Phase

GE MULTILIN Manufacturer:

Description: 50/51P

845 Type: Class Desc: 845 AIC Rating: N/A Fault Duty: 2474.1A Tcc Current Multiplier: 1 Current Rating: 300A / 5A Tcc Time Multiplier: 1 Tcc Time Adder: 0
Test Points: @2.0X, 0.456s

1 (300A) 0.12 Setting: 1) Phase TOC1 2) IEEE Mod Inv

@5.0x, 0.203s @10.0x, 0.145s

TCC Name: Branch #5-BB-LC4A-MCC IN-SVC TCC.tcc Bus Voltage: 4160.0V Device Name: LC4-MCC LINE Relay (50/51P)

Bus Name: SUB2-PDC1

Function Name: Phase

Manufacturer: GE MULTILIN Description: 50/51P

850 Type: Class Desc: GE-850 AIC Rating: Fault Duty: 2337.7A N/A Current Rating: 100A / 1A Tcc Current Multiplier: 1

@5.0x, 0.625s @10.0x, 0.202s

Device Name: T-4
Bus Name: T-4 Prim Side TCC Name: Branch #5-BB-LC Bus Voltage: 4160.0V / 480V Branch #5-BB-LC4A-MCC IN-SVC TCC.tcc

Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Description: 2-Winding Transformer Damage Curve Nominal kVA: 500.0kVA Rated Volts: 4160 LL/480 LL

Pri Connection: Delta Full Load kVA: 500.0kVA Sec Connection: Wye-Ground Impedance (%z): 5.0000 Inrush Factor: 12.0x

TCC Name: Branch #5-BB-LC4A-MCC IN-SVC TCC.tcc Bus Voltage: 480.0V Device Name: BPM-89 Bkr

Bus Name: BB-LC4A-MCC

Function Name: Phase

CUTLER-HAMMER Manufacturer:

Description: 15-225A

Type: FD 35kA

AIC Rating: Fault Duty: 5844.4A Branch #5-BB-LC4A-MCC IN-SVC TCC-rpt.txt

Frame: FD 480V 50A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 50A Setting: 1) Fixed

TCC Name: Branch #5-BB-LC4A-MCC IN-SVC TCC.tcc 480.0V Device Name: LC4A-MCC MAIN Bkr Bus Name: BB-LC4A-MCC

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 100-400A Type: HKD

AIC Rating: 65kA Frame: HKD 480V 225A Fault Duty: 5844.4A Tcc Current Multiplier: 1 Tcc Time Adder: 0 Tcc Time Multiplier: 1

Trip: 225A

Setting: 1) Thermal Curve (Fixed

2) INST (5-10 x Trip) 6.57 (1478.3A)

TCC Name: Branch #5-BB-LC4A-MCC IN-SVC TCC.tcc 480.0V Device Name: BM-89 Bus Name: BUS-0111

Tcc Current Multiplier: 1

Tcc Time Multiplier: 1 Tcc Time Adder: 0

Description: Motor Starting Curve
Rated Size: 20HP (1 of 1 Plotted)
Power Factor: 0.8 6.5 (156.8A) Inrush: FLA+Load Adder: 24.1A + 0.0A

Starting Time: 5.00s Efficiency: 0.93 Full Voltage (Square Transient) Full Voltage (Square Transient)

Device Name: LC4A-MCC LINE Bkr Bus Name: MCC LC-4 TCC Name: Branch #5-BB-LC4A-MCC IN-SVC TCC.tcc Bus Voltage: 480.0V

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 100-400A

Type: HKD

AIC Rating: 65kA Frame: HKD 480V 225A Fault Duty: 7630.8A Tcc Current Multiplier: 1 Tcc Time Adder: 0

Tcc Time Multiplier: 1 Trip: 225A

Setting: 1) Thermal Curve (Fixed 2) INST (5-10 x Trip) 8.75 (1968.8A)

Branch #5-BB-LC4A-MCC IN-SVC TCC-rpt.txt

Bus Name: MCC-LC-4 MAIN BK Line Side Bus Voltage: 480.0V

Function Name: Phase

MERLIN GERIN Manufacturer:

Description: LSI, 250-800A Sensors Type: Masterpact, STR 58U AÍC Rating: 65kA ShortTime:50

Fault Duty: 7704.9A Tcc Current Multiplier: 1
Tcc Time Adder: 0 Frame: MC08H1 Tcc Time Multiplier: 1 MC08H1 480V 800A

800a Sensor: 800A Plug:


Setting: 1) LTPU (lo x lr x S) 2) LTD (15-480 Sec.) 3) STPU (1.5-10 x LTPU) 4) STD (INST-0.4) 5) INST (2-28 x S) 0.5; 0.8 (320A)

15

1.5 (480A)


0.1 I^2 t Out

2 (1600A)



Branch #6-BB-ESB3A-MCC MAINT TCC

Current Scale: x 1
Reference Voltage: 600



Proiect Name: Burnaby Terminal(AF Maintenance Mode -1 jet fue)

Branch #6-BB-ESB3A-MCC MAINT TCC.tcc TCC Name:

Reference Voltage: 600 V Current Scale: x 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION,

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 

Device Name: SUB2 Fdr Relay (50/51P)
Bus Name: SUB2 Xmer Prim Side
Function Name: Phase TCC Name: Branch #6-BB-ESB3A-MCC MAINT TCC.tcc Bus Voltage: 12470.0V

Manufacturer: GE MULTILIN Description: 50/51P

Type: 850 Class Desc: GE-850 Fault Duty: 2474.1A AIC Rating: N/A Current Rating: 300A / 5A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

1 (300A) Setting: 1) 51P Test Points: @2.0x, 4.518s 2) IEEE, Ext. Inverse 0.63

@5.0x, 0.787s @10.0x, 0.254s

TCC Name: Branch #6-BB-ESB Bus Voltage: 12470.0V / 4160V Branch #6-BB-ESB3A-MCC MAINT TCC.tcc Device Name: SUB2 Xmer

Bus Name: SUB2 Xmer Prim Side

Tcc Current Multiplier: 1 Tcc Time Adder:

Tcc Time Multiplier: 1 Description: 2-Winding Transformer Damage Curve Rated Volts: 12470 LL/4160 LL

Pri Connection: Delta Nominal kva: 1500.0kvA Full Load kVA: 1500.0kVA Sec Connection: Wye-Ground Impedance (%Z): 8.0000 Inrush Factor: 12.0x

Device Name: SUB2 Xmer Prim Relay (50/51P) TCC Name: Branch #6-BB-ESB3A-MCC MAINT TCC.tcc Bus Voltage: 12470.0V

Function Name: Phase

Manufacturer: GE MULTILIN

Description: 50/51P

845 Type: Class Desc: 845 Fault Duty: 2474.1A
TCC Current Multiplier: 1
TCC Time Adder: 0
Test Points: @2.0x, 0.456s
2) IEEE Mod Inv
3) Mod Inverse 1; 1 AIC Rating: Current Rating: 300A / 5A Tcc Time Multiplier: 1

Setting: 1) Phase TOC1

@10.0x, 0.145s

TCC Name: Branch #6-BB-ESB3A-MCC MAINT TCC.tcc Bus Voltage: 4160.0V / 600V Device Name: BB-ESB3-TXR1

Device Name: BB-ESB3-TXR1

Bus Name: BB-ESB3-TXR1 Prim Side

Bus Voltage: 4160.0V / 600V

Tcc Time Multiplier: 1

Tcc Time Adder: 0

Description: 2-Winding Transformer Damage Curve

Nominal ky/A: 500.0ky/A

Pri Connection: Delta Nominal kva: 500.0kva

Sec Connection: Wye-Ground Inrush Factor: 12.0x Full Load kVA: 500.0kVA Impedance (%z): 5.0000

Device Name: BB-ESB3-MCC LINE (50/51P) TCC Name: Branch #6-BB-ESB3A-MCC MAINT TCC.tcc Bus Name: SUB2-PDC1 Bus Voltage: 4160.0V

Manufacturer: GE MULTILIN Description: 50/51P

Class Desc: GE-850 850 Type: AIC Rating: N/A Fault Duty: 2337.7A Current Rating: 100A / 1A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1

 Rating:
 100A / 1A
 Tcc Current Multiplier:
 1

 Multiplier:
 1
 Tcc Time Adder:
 0

 1) 51P
 1 (100A)
 Test Points:
 @2.0X, 7.243s

 2) IEEE, Ext. Inverse
 1.01
 @5.0X, 1.262s

 3) 50P
 5 (500A)
 @10.0X, 0.408s

 Setting: 1) 51P @10.0x, 0.408s

Device Name: BB-ESB3A-MCC LINE Bkr TCC Name: Branch #6-BB-ESB3A-MCC MAINT TCC.tcc Bus Name: BB-ESB3-MCC Bus Voltage: 600.0V

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 100-400A

Type: HKD AIC Rating: 35kA

Fault Duty: 6778.6A

HKD 600V 400A Tcc Current Multiplier: 1 Frame: Tcc Time Multiplier: 1 Tcc Time Adder:

Trip: 400A

Setting: 1) Thermal Curve (Fixed

2) INST (5-10 x Trip) 7.31 (2924A)

\_\_\_\_\_\_

TCC Name: Branch #6-BB-ESB3A-MCC MAINT TCC.tcc Bus Voltage: 600.0V ESB3-MCC MAIN Bkr Device Name:

Bus Name: BB-ESB3-MCC

Function Name: Phase

Manufacturer: CUTLER-HAMMER

Description: 70-600A

Type: HLA

AIC Rating: 25kA Frame: HLA 600V 600A

Fault Duty: 6778.6A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

500A Trip:

Setting: 1) Thermal Curve (Fixed

2) INST (5-10 x Trip) 5 (2500A)

TCC Name: Branch #6-BB-ESB3A-MCC MAINT TCC.tcc Bus Voltage: 600.0V

Device Name: BB-ESB3A-MCC Main Bkr Bus Name: BB-ESB3A-MCC

Function Name: Phase

Manufacturer: CUTLER-HAMMER Description: 100-400A

Type: HKD

AIC Rating: 35kA Frame: HKD 600V 400A Fault Duty: 6187.3A Tcc Current Multiplier: 1 Tcc Time Multiplier: 1 Tcc Time Adder: 0

400A Trip:

Setting: 1) Thermal Curve (Fixed 2) INST (5-10 x Trip) 5 (2000A)

TCC Name: Branch #6-BB-ESB3A-MCC MAINT TCC.tcc Bus Voltage: 600.0V Device Name: BM-98 Bkr

Bus Name: BB-ESB3A-MCC

Function Name: Phase

Manufacturer: CUTLER-HAMMER

Description: 15-225A Type: FDC

AIC Rating: 35kA Frame: FDC 600V 30A Fault Duty: 6187.3A Tcc Current Multiplier: 1

Tcc Time Multiplier: 1 Tcc Time Adder: 0

Trip: 30A Setting: 1) Fixed

------

Device Name: BM-98 TCC Name: Branch #6-BB-ESB3A-MCC MAINT TCC.tcc

Bus Name: BUS-0119

Bus Voltage: 600.0V

Tcc Current Multiplier: 1


Tcc Time Multiplier: 1

Tcc Time Adder: 0

Tcc Time Multiplier: 1 Tcc Time Adder: 0
Description: Motor Starting Curve Inrush: 6.5 (125.4A)
Rated Size: 20HP (1 of 1 Plotted) FLA+Load Adder: 19.3A + 0.0A


Power Factor: 0.8 Starting Time: 5.00s

Efficiency: 0.93 Full Voltage (Square Transient)



Branch #7-AUBREY GROUND FAULT TCC Current Scale: x 1

Reference Voltage: 4160



#### Branch #7-AUBREY GROUND FAULT TCC-rpt.txt

Project Name: Burnaby Terminal(AF In Service Mode-1 jet fuel)

Branch #7-AUBREY GROUND FAULT TCC.tcc TCC Name:

Reference Voltage: 4160 V Current Scale: X 10^0

TCC Notes: TCC Comment:

Fault Duty Option: Study Result - Bus Fault Current

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL, INTERPRETATION.

AND APPLICATION BY A REGISTERED ENGINEER ONLY.

SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING

FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.

CAPTOR (Computer Aided Plotting for Time Overcurrent Reporting)

COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983-2016 COLINIAN SIGNATURE AMELIES, INC. 1909 2010

TCC Name: Device Name: BB-ESB3-MCC LINE (50/51G) Branch #7-AUBREY GROUND FAULT

TCC.tcc

Bus Name: SUB2-PDC1 Function Name: Neutral

Manufacturer: GE MULTILIN Description: 50/51G

850 Type:

AIC Rating: N/A Current Rating: 50A / 5A Tcc Time Multiplier: 1

Setting: 1) 50G
2) Definite Time 0.05 (2.5A) 0.2 (seconds)

Bus Voltage: 4160.0V

Class Desc: GE-850 Fault Duty: 15.0A

Tcc Current Multiplier: 1 Tcc Time Adder: 0

Test Points: @2.0X, 0.200s @5.0x, 0.200s

@10.0x. 0.200s

Device Name: BB-ESB4-MCC LINE (50/51G) TCC Name: Branch #7-AUBREY GROUND FAULT

TCC.tcc

SUB2-PDC1 Bus Voltage: Bus Name: 4160.0V

Function Name: Neutral Manufacturer: GE MULTILIN

Description: 50/51G

Class Desc: GE-850 Fault Duty: 15.0A 850 Type: AIC Rating: N/A

Branch #7-AUBREY GROUND FAULT TCC-rpt.txt
Tcc Current Multiplier: 1 Current Rating: 50A / 5A Tcc Time Multiplier: 1 Setting: 1) 50G

Multiplier: 1 ICC IIME Addel.

1) 50G 0.05 (2.5A) Test Points: @2.0X, 0.200s
2) Definite Time 0.2 (seconds) @5.0X, 0.200s
@10.0X, 0.200s Setting: 1) 50G

\_\_\_\_\_\_

Device Name: BB-ESB5-MCC LINE (50/51G) TCC Name: Branch #7-AUBREY GROUND FAULT

TCC.tcc

Bus Voltage: 4160.0V

Bus Name: SUB2-PDC1
Function Name: Neutral
Manufacturer: GE MULTILIN
Description: 50/51G

Type: 850
AIC Rating: N/A
Current Rating: 50A / 5A
Tcc Time Multiplier: 1 Class Desc: GE-850
Fault Duty: 15.0A
Tcc Current Multiplier: 1
Tcc Time Adder: 0

Tcc Time Multiplier: 1

Setting: 1) 50G

2) Definite Time

0.05 (2.5A)

0.05 (2.5A)

0.05 (2.5A)

Test Points: @2.0X, 0.200s

@5.0X, 0.200s

@10.0X. 0.200s

@10.0x, 0.200s

Device Name: LC3-MCC LINE Relay (50/51G) TCC Name: Branch #7-AUBREY GROUND FAULT

TCC.tcc

Bus Name: SUB2-PDC1 Function Name: Neutral Bus Voltage: 4160.0V

Manufacturer: GE MULTILIN 50/51G

Class Desc: GE-850 Fault Duty: 15.0A Tcc Current Multiplier: 1 850 Type: AIC Rating: N/A Current Rating: 50A / 5A Tcc Time Multiplier: 1 

Setting: 1) 50G

@5.0x, 0.200s @10.0x, 0.200s

Device Name: LC4-MCC LINE Relay (50/51G) TCC Name: Branch #7-AUBREY GROUND FAULT

TCC.tcc

Bus Name: SUB2-PDC1 Function Name: Neutral Bus Voltage: 4160.0V

Manufacturer: GE MULTILIN

Description: 50/51G Type: 850 Class Desc: GE-850 Type:

Branch #7-AUBREY GROUND FAULT TCC-rpt.txt

AIC Rating: N/A
Current Rating: 50A / 5A
Tcc Time Multiplier: 1 Fault Duty: 15.0A Tcc Current Multiplier: 1 Tcc Time Adder: 0

Test Points: @2.0X, 0.200s Setting: 1) 50G 0.05 (2.5A) 0.2 (seconds) @5.0X, 0.200s @10.0X, 0.200s 2) Definite Time

Device Name: SUB2 Xmer Relay (51G) TCC Name: Branch #7-AUBREY GROUND FAULT

TCC.tcc

Bus Voltage: 4160.0V Bus Name: SUB2-PDC1

Function Name: Neutral Manufacturer: STARTCO

50/ 51G/ 51N, CT200 Description:

Class Desc: Type: SE-325 SE-325 AÍC Rating: Fault Duty: 15.0A Tcc Current Multiplier: 1 N/A Current Rating: 200A / 5A Tcc Time Multiplier: 1 Tcc Time Adder: 0
Test Points: @2.0X, 0.400s

Setting: 1) GF Trip Level 4 (4A)
2) GF Trip Time 0.4 (seconds) @5.0x, 0.401s

@10.0x, 0.401s






Table 1E - Low Voltage MCC Bus Rati				
	Lineup Bus Bracing	Fault Duty	% Capacity Utilized	
Bus	(kA)	(kA)	[%]	Notes
BB-ESB1-MCC	42	2.6	6	
BB-ESB2-MCC	42	1.7	4	
BB-ESB2A-MCC	42	1.7	4	
MCC-EX	42	1.2	3	
MCC-AX	42	2.2	5	
DIV. OFFICE BASMENT	42	1.2	3	
LEVEE BUILDING	42	0.8	2	1
CDP PANEL AX (CTRL RM BLDG)	42	1.9	5	1
CDP PANEL BX	42	2.1	5	
PDP#1	42	2.1	5	
PDP#3	42	2.1	5	
PDP#4	42	2.1	5	
PDP#5	42	2.1	5	1
PDP#6	42	2.1	5	1
MCC-DX	42	2.1	5	
MCC LC-3	42	1.6	4	1
BB-LC3A-MCC	42	1.6	4	
TK90/88 MCC	42	1.5	4	
TK82 MCC	42	1.3	3	1
TK86 MCC	42	1.4	3	7
TK72 MCC	42	1.3	3	7
TK74 MCC	42	1.2	3	
MCC LC-4	42	1.6	4	
BB-LC4A-MCC	42	1.6	4	
TK71 MCC	42	1.3	3	
TK73 MCC	42	1.2	3	7
TK81 MCC	42	1.3	3	7
TK83 MCC	42	1.4	3	7
TK85 MCC	42	1.6	4	7
TK87 MCC	42	1.3	3	
BB-ESB3-MCC	42	0.9	2	
BB-ESB3A-MCC	42	0.9	2	7
BB-ESB3B-MCC	42	0.9	2	7
BB-ESB4-MCC	42	0.4	1	7
BB-ESB5-MCC	42	0.9	2	1
BB-ESB5A-MCC	42	0.9	2	1
BB-ESB5B-MCC	42	0.9	2	]
BB-ESB5C-MCC	42	0.9	2	7



Table 1F - Low Voltage Breaker & Fuse Rating

	Interrupting Rating	Low Voltage Fault Duty	% Capacity Utilized
Device	(kA)	(kA)	[%]
BB-ESB1-GEN Bkr	25	3	12
BB-ESB2-GEN Bkr	25	2	8
BB-ESB3-GEN Bkr	25	1	4
BB-ESB3A-MCC LINE Bkr	35	1	3
BB-ESB3A-MCC Main Bkr	35	1	3
BB-ESB3B-MCC LINE Bkr	35	1	3
BB-ESB3B-MCC Main Bkr	35	1	3
BB-ESB4-GEN Bkr	25	0.5	2
BB-ESB5-GEN Bkr	25	1.1	4
BM-74 Bkr	35	1.1	3
BM-75 Bkr	35	1.1	3
BM-76 Bkr	35	1.1	3
BM-77 Bkr	35	1.1	3
BM-78 Bkr	35	1.1	3
BM-79 Bkr	35	1.1	3
BM-80 Bkr	35	2.2	6
BM-91 Bkr	35	1	3
BM-93 Bkr	35	1	3
BM-96 Bkr	35	1	3
BM-97 Bkr	35	1	3
BM-98 Bkr	35	1	3
BPM-11 Bkr	35	2.9	8
BPM-12 Bkr	35	1.9	5
BPM-21 Bkr	35	2.9	8
BPM-22 Bkr	35	1.9	5
BPM-31 Bkr	35	2.9	8
BPM-31 Bkr1	35	2.2	6
BPM-32 Bkr	35	1.9	5
CDP-AX FDR BK	65	2.5	4
CDP-BX FDR BK	65	2.5	4
DIV OFFICE FDR BK	65	2.5	4
ESB1-AHU Bkr	25	2.9	12
ESB1-LP1 Bkr	25	2.9	12
ESB1-MCC MAIN Bkr	65	2.8	4
ESB2-AHU Bkr	25	1.9	8
ESB2-LP1 Bkr	25	1.9	8
ESB2-MCC MAIN Bkr	65	1.8	3
ESB2A-LP1 Bkr	25	1.8	7
ESB2A-MCC LINE Bkr	25	1.9	8
ESB2A-MCC MAIN Bkr	25	1.8	7



Table 1F -	Low Voltage	Breaker &	Fuse Rating	(Cont.)

	Interrupting Rating	Low Voltage Fault Duty	% Capacity Utilized			
Device	(kA)	(kA)	[%]			
ESB3-LP1 Bkr	25	1	4			
ESB3-MCC MAIN Bkr	25	1	4			
ESB3A-LP1 Bkr	25	1	4			
ESB3B Bkr	35	1	3			
ESB3B-LP1 Bkr	25	1	4			
ESB4-LP1 Bkr	25	0.5	2			
ESB4-MCC MAIN Bkr	35	0.5	1			
ESB5-LP1 Bkr	25	1.1	4			
ESB5-MCC MAIN Bkr	25	1.1	4			
ESB5A-LP1 Bkr	25	1.1	4			
ESB5A-MCC LINE Bkr	35	1.1	3			
ESB5A-MCC MAIN Bkr	35	1.1	3			
ESB5B-LP1 Bkr	25	1.1	4			
ESB5B-MCC LINE Bkr	35	1.1	3			
ESB5B-MCC MAIN Bkr	35	1.1	3			
ESB5C-LP1 Bkr	25	1.1	4			
ESB5C-MCC LINE Bkr	35	1.1	3			
ESB5C-MCC MAIN Bkr	35	1.1	3			
G-LC-3 BK	14	2.9	21			
G-LC-4 BK	14	2.9	21			
GEN BK	65	2.6	4			
LC 71 FDR BK	14	2.8	20			
LC 72 FDR BK	14	2.8	20			
LC 73 FDR BK	65	2.5	4			
LC 74 FDR BK	35	2.5	7			
LC 81 FDR BK	14	2.8	20			
LC 82 FDR BK	14	2.8	20			
LC 83 FDR BK	14	2.8	20			
LC 84 FDR BK	14	2.8	20			
LC 85 FDR BK	14	2.8	20			
LC 86 FDR BK	14	2.8	20			
LC 87 FDR BK	14	2.8	20			
LC 90/88 FDR BK	35	2.5	7			
LC3A-LP1 Bkr	25	2.2	9			
LC3A-MCC LINE Bkr	65	2.5	4			
LC3A-MCC MAIN Bkr	65	2.2	3			
LC4A-LP1 Bkr	25	2.2	9			
LC4A-MCC LINE Bkr	65	2.5	4			
LC4A-MCC MAIN Bkr	65	2.2	3			
MCC-DX FDR BK	25	2.3	9			
MCC-EX FDR BK	65	2.5	4			
MCC-EX MAIN	65	0.6	1			



Table 1F - Low Voltage Breaker & Fuse Rating (Cont.)

·	Interrupting Rating	Low Voltage Fault Duty	% Capacity Utilized		
Device	(kA)	(kA)	[%]		
PDP1 FDR BK	25	2.3	9		
PDP3/4 FDR BK	25	2.3	9		
PDP5 FDR BK	25	2.3	9		
PDP6 FDR BK	25	2.3	9		
PFC FD BK	14	2.8	20		
PFC-LC4 FD BK	14	2.8	20		
TK71 MAIN BK	14	1.5	11		
TK72 MAIN BK	14	1.5	11		
TK73 MAIN BK	65	1.4	2		
TK74 MAIN BK	14	1.4	10		
TK81 MAIN BK	14	1.5	11		
TK82 MAIN BK	14	1.6	11		
TK83 MAIN BK	14	1.8	13		
TK84 MAIN BK	14	2	14		
TK85 MAIN BK	14	2.3	16		
TK86 MAIN BK	14	1.8	13		
TK87 MAIN BK	65	1.5	2		
TK90/88 MAIN BK	65	1.9	3		

Table 1F - Load Interrupt/			
Switch	Interrupt Rating (kA)	Duty (kA)	% Capacity Utilized {Interrupting} [%]
ATS-NORM	30	2.2	7
BB-ESB1-TRS	30	2.6	9
BB-ESB2-TRS	30	1.7	6
ATS-LC3	30	1.6	5
ATS-LC4	30	1.6	5
BB-ESB3-TRS	30	0.6	2
BB-ESB4-TRS	30	0.6	2
BB-ESB5-TRS	30	0.6	2



### Arc Flash Results Emergency Generator Mode

Bus Name	Protective Device Name	Bus kV	Bus Bolted Fault (kA)	Prot Dev Bolted Fault (kA)	Prot Dev Arcing Fault (kA)	Trip/ Delay Time (sec.)	Breaker Opening Time (sec.)	Ground (Y/N)	Equip Type	Gap (mm)	Arc Flash Boundary (m)	Working Distance (m)	Incident Energy (cal/cm2)	Notes
BB-ESB1-MCC	BB-ESB1-GEN Bkr	0.60	2.61	1.05	0.91	2	0.0000	Yes	PNL	25	1.19	0.45	5.8	(*N5) (*N9)
BB-ESB1-VFD11 Line Side	BPM-11 Bkr	0.60	2.59	2.59	2.27	2	0.0000	Yes	PNL	25	1.19	0.45	5.8	(*N9)
BB-ESB1-VFD12 Line Side	BPM-12 Bkr	0.60	1.66	1.66	1.51	2	0.0000	Yes	PNL	25	1.16	0.45	5.6	(*N9)
BB-ESB1-VFD21 Line Side	BPM-21 Bkr	0.60	2.59	2.59	2.27	2	0.0000	Yes	PNL	25	1.19	0.45	5.8	(*N9)
BB-ESB1-VFD22 Line Side	BPM-22 Bkr	0.60	1.66	1.66	1.51	2	0.0000	Yes	PNL	25	1.16	0.45	5.6	(*N9)
BB-ESB1-VFD31 Line Side	BPM-31 Bkr	0.60	2.59	2.59	2.27	2	0.0000	Yes	PNL	25	1.19	0.45	5.8	(*N9)
BB-ESB1-VFD32 Line Side	BPM-32 Bkr	0.60	1.66	1.66	1.51	2	0.0000	Yes	PNL	25	1.16	0.45	5.6	(*N9)
BB-ESB2A	ESB2A-MCC MAIN Bkr	0.60	1.66	1.66	1.50	2	0.0000	Yes	PNL	25	1.16	0.45	5.6	(*N9)
BB-ESB2-MCC	BB-ESB2-GEN Bkr	0.60	1.67	1.05	0.95	2	0.0000	Yes	PNL	25	1.16	0.45	5.6	(*N5) (*N9)
BB-ESB3A-MCC	BB-ESB3A-MCC Main Bkr	0.60	0.56	0.56	0.56	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
BB-ESB3A-MCC Main Bkr LineSide	BB-ESB3A-MCC LINE Bkr	0.60	0.56	0.56	0.56	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
	BB-ESB3B-MCC Main Bkr	0.60	0.56	0.56	0.56	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
BB-ESB3B-MCC Main Bkr LineSide	BB-ESB3B-MCC LINE Bkr	0.60	0.56	0.56	0.56	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
	BB-ESB3-GEN Bkr	0.60	0.56	0.35	0.35	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N5) (*N9) (*N1)
BB-ESB4-MCC	BB-ESB4-GEN Bkr	0.60	0.58	0.35	0.35	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N5) (*N9) (*N1)
BB-ESB5A-MCC	ESB5A-MCC MAIN Bkr	0.60	0.59	0.59	0.59	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
BB-ESB5B-MCC	ESB5B-MCC MAIN Bkr	0.60	0.59	0.35	0.35	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
BB-ESB5C-MCC	ESB5C-MCC MAIN Bkr	0.60	0.59	0.59	0.59	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
BB-ESB5-MCC	BB-ESB5-GEN Bkr	0.60	0.59	0.35	0.35	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N5) (*N9) (*N1)
ESB1-MCC MAIN Bkr Line side	BB-ESB1-GEN Bkr	0.60	2.61	1.05	0.91	2	0.0000	Yes	PNL	25	1.19	0.45	5.8	(*N9)
ESB2A-MCC MAIN Bkr Line Side	ESB2A-MCC LINE Bkr	0.60	1.66	1.66	1.50	2	0.0000	Yes	PNL	25	1.16	0.45	5.6	(*N9)
	BB-ESB2-GEN Bkr	0.60	1.67	1.05	0.95	2	0.0000	Yes	PNL	25	1.16	0.45	5.6	(*N9)
ESB3-MCC MAIN Bkr Line Side	BB-ESB3-GEN Bkr	0.60	0.56	0.35	0.35	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
ESB4-MCC MAIN Bkr Line Side	BB-ESB4-GEN Bkr	0.60	0.58	0.35	0.35	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
ESB5A-MCC MAIN Bkr Line Side	ESB5A-MCC LINE Bkr	0.60	0.59	0.59	0.59	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)



### Arc Flash Results Emergency Generator Mode

Bus Name  ESB5B-MCC MAIN Bkr Line	Protective Device Name ESB5B-MCC LINE Bkr	Bus kV	Bus Bolted Fault (kA)	Prot Dev Bolted Fault (kA)	Prot Dev Arcing Fault (kA)	Trip/ Delay Time (sec.)	Breaker Opening Time (sec.)	Ground (Y/N)	Equip Type PNL	Gap (mm)	Arc Flash Boundary (m)	Working Distance (m)	Incident Energy (cal/cm2)	Notes
Side	E2R2R-WCC TIME RKL	0.60	0.59	0.35	0.35	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
ESB5C-MCC MAIN Bkr Line Side	ESB5C-MCC LINE Bkr	0.60	0.59	0.59	0.59	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
ESB5-MCC MAIN Bkr Line Side	BB-ESB5-GEN Bkr	0.60	0.59	0.35	0.35	2	0.0000	Yes	PNL	25	0.43	0.45	1.1	(*N9) (*N1)
ATS-LC3 (EMERG)	G-LC-3 BK	0.48	1.61	1.43	1.04	2	0.0000	Yes	PNL	25	1.21	0.45	5.9	(*N3) (*N9)
ATS-LC4 (EMERG)	G-LC-4 BK	0.48	1.60	1.43	1.04	2	0.0000	Yes	PNL	25	1.21	0.45	5.9	(*N3) (*N9)
BB-LC3A-MCC	G-LC-3 BK	0.48	1.57	1.40	1.02	2	0.0000	Yes	PNL	25	1.19	0.45	5.8	(*N3) (*N5) (*N9)
BB-LC4A-MCC	G-LC-4 BK	0.48	1.54	1.37	1.18	1.754	0.0000	Yes	PNL	25	1.21	0.45	6.0	(*N5)
CDP PANEL BX	CDP-BX FDR BK	0.48	2.18	1.36	1.12	2	0.0000	Yes	PNL	25	1.22	0.45	6.1	(*N9)
C3A-MCC MAIN Bkr Line Side	G-LC-3 BK	0.48	1.57	1.40	1.02	2	0.0000	Yes	PNL	25	1.19	0.45	5.8	(*N3) (*N5) (*N9)
C4A-MCC MAIN Bkr Line Side	G-LC-4 BK	0.48	1.57	1.40	1.02	2	0.0000	Yes	PNL	25	1.19	0.45	5.8	(*N3) (*N5) (*N9)
MCC LC-3	G-LC-3 BK	0.48	1.61	1.43	1.04	2	0.0000	Yes	PNL	25	1.21	0.45	5.9	(*N3) (*N9)
MCC LC-4	G-LC-4 BK	0.48	1.60	1.43	1.04	2	0.0000	Yes	PNL	25	1.21	0.45	5.9	(*N3) (*N9)
MCC-AX	GEN BK	0.48	2.24	1.25	1.02	2	0.0000	Yes	PNL	25	1.26	0.45	6.4	(*N9)
MCC-DX	MCC-DX FDR BK	0.48	2.16	1.35	0.94	0.4635	0.0000	Yes	PNL	25	0.48	0.45	1.3	(*N3)
MCC-EX	MCC-EX FDR BK	0.48	0.56	0.56	0.56	1.87	0.0000	Yes	PNL	25	0.44	0.45	1.1	(*N5) (*N1)
MCC-EX Line Side	MCC-EX FDR BK	0.48	0.96	0.96	0.75	0.9187	0.0000	Yes	PNL	25	0.53	0.45	1.5	(*N3)
K71 MAIN BK Line Side	LC 71 FDR BK	0.48	1.27	1.26	0.95	1.91	0.0000	Yes	PNL	25	1.04	0.45	4.7	(*N3)
TK71 MCC	TK71 MAIN BK	0.48	1.27	1.26	0.95	1.91	0.0000	Yes	PNL	25	1.04	0.45	4.7	(*N3)
K72 MAIN BK Line Side	LC 72 FDR BK	0.48	1.28	1.26	0.95	1.905	0.0000	Yes	PNL	25	1.04	0.45	4.7	(*N3)
TK72 MCC	TK72 MAIN BK	0.48	1.28	1.26	0.95	1.905	0.0000	Yes	PNL	25	1.04	0.45	4.7	(*N3)
K73 MAIN BK Line Side	G-LC-4 BK	0.48	1.23	1.09	0.97	2	0.0000	Yes	PNL	25	1.17	0.45	5.6	(*N5) (*N9)
K73 MCC	G-LC-4 BK	0.48	1.23	1.09	0.97	2	0.0000	Yes	PNL	25	1.17	0.45	5.6	(*N5) (*N9)
K74 MAIN BK Line Side	G-LC-3 BK	0.48	1.16	1.04	0.93	2	0.0000	Yes	PNL	25	1.14	0.45	5.4	(*N5) (*N9)
K74 MCC	TK74 MAIN BK	0.48	1.16	1.16	0.88	2	0.0000	Yes	PNL	25	1.03	0.45	4.5	(*N3) (*N9)



### Arc Flash Results Emergency Generator Mode


**Burnaby Terminal** 216239 Rev B - Issued For Review


Bus Name	Protective	Bus	Bus	Prot Dev	Prot Dev	Trip/	Breaker	Ground	Equip	Gap	Arc Flash	Working	Incident	Notes
Device Name	Device	kV	Bolted	Bolted	Arcing	Delay	Opening	(Y/N)	Type		Boundary	Distance	Energy	
		Fault	Fault	Fault	Time	Time			(mm)	(m)	(m)	(cal/cm2)		
			(kA)	(kA)	(kA)	(sec.)	(sec.)							
K81 MAIN BK Line Side	LC 81 FDR BK	0.48	1.30	1.29	0.97	1.759	0.0000	Yes	PNL	25	1.00	0.45	4.4	(*N3)
TK81 MCC	TK81 MAIN BK	0.48	1.30	1.29	0.97	1.759	0.0000	Yes	PNL	25	1.00	0.45	4.4	(*N3)
K82 MAIN BK Line Side	LC 82 FDR BK	0.48	1.33	1.32	0.99	1.659	0.0000	Yes	PNL	25	0.98	0.45	4.2	(*N3)
K82 MCC	TK82 MAIN BK	0.48	1.33	1.32	0.99	1.659	0.0000	Yes	PNL	25	0.98	0.45	4.2	(*N3)
TK83 MAIN BK Line side	LC 83 FDR BK	0.48	1.44	1.43	1.06	1.281	0.0000	Yes	PNL	25	0.87	0.45	3.5	(*N3)
FK83 MCC	TK83 MAIN BK	0.48	1.44	1.43	1.06	1.281	0.0000	Yes	PNL	25	0.87	0.45	3.5	(*N3)
K84 MAIN BK Line Side	LC 84 FDR BK	0.48	1.49	1.49	1.09	1.139	0.0000	Yes	PNL	25	0.83	0.45	3.2	(*N3)
K84 MCC	TK84 MAIN BK	0.48	1.49	1.49	1.09	1.139	0.0000	Yes	PNL	25	0.83	0.45	3.2	(*N3)
TK85 MAIN BK Line Side	LC 85 FDR BK	0.48	1.56	1.55	1.13	1.009	0.0000	Yes	PNL	25	0.79	0.45	2.9	(*N3)
K85 MCC	TK85 MAIN BK	0.48	1.56	1.55	1.13	1.009	0.0000	Yes	PNL	25	0.79	0.45	2.9	(*N3)
TK86 MAIN BK Line Side	LC 86 FDR BK	0.48	1.42	1.40	1.04	1.401	0.0000	Yes	PNL	25	0.92	0.45	3.8	(*N3)
K86 MCC	TK86 MAIN BK	0.48	1.42	1.40	1.04	1.401	0.0000	Yes	PNL	25	0.92	0.45	3.8	(*N3)
K87 MAIN BK Line Side	G-LC-4 BK	0.48	1.26	1.12	1.00	2	0.0000	Yes	PNL	25	1.19	0.45	5.8	(*N5) (*N9)
K87 MCC	G-LC-4 BK	0.48	1.26	1.12	1.00	2	0.0000	Yes	PNL	25	1.19	0.45	5.8	(*N5) (*N9)
K90/88 MAIN BK Line Side	G-LC-3 BK	0.48	1.47	1.31	1.14	1.981	0.0000	Yes	PNL	25	1.28	0.45	6.5	(*N5)
K90/88 MCC	G-LC-3 BK	0.48	1.47	1.31	1.14	1.981	0.0000	Yes	PNL	25	1.28	0.45	6.5	(*N5)


(\*N1) - Out of IEEE 1584 Range; Lee Equation Used (\*N2) < 80% Cleared Fault Threshold


(\*N3) - Arcing Current Low Tolerances Used (\*N5) - Miscoordinated, Upstream Device Tripped


(\*N9) - Max Arcing Duration Reached




















Append	lix 4
Reference Draw	ings


Number	Rev	Title
BB00-EE1023	0	480V SINGLE LINE DIAGRAM MCC F JET FUEL AREA
BB00-EE1025	1	480V SINGLE LINE DIAGRAM MCC B LOWER TANK FARM AREA
BB00-EE1027	1	480V SINGLE LINE DIAGRAM CDP PANEL BX LOWER TANK FARM AREA
BB00-EE1029	4	480V SINGLE LINE DIAGRAM P.L.M. SHOP AND MECHANICAL BLDG.
BB00-EE1041	2	480V SINGLE LINE DIAGRAM POWER DISTRIBUTION MCC B PANEL 1 LOWER TANK FARM AREA
BB00-EE1042	2	480V SINGLE LINE DIAGRAM POWER DISTRIBUTION MCC B PANEL 3 LOWER TANK FARM
BB00-EE1043	2	480V SINGLE LINE DIAGRAM POWER DISTRIBUTION MCC B PANEL 4 LOWER TANK FARM AREA
BB00-EE1044	1	480V SINGLE LINE DIAGRAM POWER DISTRIBUTION MCC B PANEL 5 LOWER TANK FARM AREA
BB00-EE1045	4	SINGLE LINE DIAGRAM POWER DISTRIBUTION PANEL 6 (480 V) IN MCC-B BLDG
BB00-EE1046	1	480V SINGLE LINE DIAGRAM CDP PANEL BOARD SB-A1 E/I BUILDING
BB00-EE1047	1	480V SINGLE LINE DIAGRAM MCC E & MCC EX
BB00-EE1311	0	SINGLE LINE DIAGRAM CDP PANEL A CONTROL ROOM BUILDING
BB00-EE1312	0	SINGLE LINE DIAGRAM CDP PANEL AX GENERATOR POWER CONTROL ROOM
BB00-EE1024 SHT 1	8	480V MCC A SINGLE LINE DIAGRAM LOWER TANK FARM AREA
BB00-EE1026 SHT 1	5	480V- MCC AX SINGLE LINE DIAGRAM LOWER TANK FARM AREA
01-13279-C1A01-BB00-EE1031	2	SINGLE LINE DIAGRAM TK81 MCC TANK 81
01-13343-C1A01-BB00-EE1032 SHT 2	4	SINGLE LINE DIAGRAM 480V TK83 MCC TK83 LC BUILDING
01-13343-C1A01-BB00-EE1036 SHT 2	2	SINGLE LINE DIAGRAM TK82 MCC TANK 82
01-13343-C1A01-BB00-EE1037 SHT 2	4	SINGLE LINE DIAGRAM TK84 MCC TANK 84
01-13343-C1A01-BB00-EE1040 SHT 2	3	SINGLE LINE DIAGRAM TK74 MCC TANK 74
BB00-EE1322 SHT2	2	SINGLE LINE DIAGRAM TANK 90/88
BB00-EE1323	4	SINGLE LINE DIAGRAM TANK 87 MCC PANEL NLP-87A
01-13104-C1A01-BB00-EE1466 SHT 1	1	SINGLE LINE DIAGRAM NAEMS UPPER ROAD TANK 88

Number	Rev	Title
BB00-EE1020	4C	12.47 AND 4.16KV SLD LOWER TANK FARM AREA
BB00-EE1020D	А	DEMOLITION - 12.47 AND 4.16KV SLD LOWER TANK FARM AREA
01-13283-BB00-EE1028 SHT 1	8C	SINGLE LINE DIAGRAM MCC-DX IN MCC-D BLDGREFINED PRODUCTS
01-13283-BB00-EE01028 SHT 02	С	SINGLE LINE DIAGRAM 480 VOLT DISTRIBUTION MCC-DX (480V) TMEP
01-13283-BB00-EE01028 SHT 03	С	SINGLE LINE DIAGRAM 480 VOLT DISTRIBUTION MCC-DX (480V) TMEP
01-13343-C1A01-BB00-EE1033 SHT 2	2C	SINGLE LINE DIAGRAM TK85 MCC TANK 85
01-13277-C1A01-BB00-EE1034 SHT 2	1C	SINGLE LINE DIAGRAM TK71 MCC TANK 71
01-13283-BB00-EE1035 SHT 2	0C	SINGLE LINE DIAGRAM TK73
12887-C1A01-BB00-EE1038 SHT 2	1C	SINGLE LINE DIAGRAM TANK76
01-13343-C1A01-BB00-EE1039 SHT 2	4C	SINGLE LINE DIAGRAM TK72 MCC TANK 72
BB00-EE1319 SHT 1	0C	480V SINGLE LINE DIAGRAM LC-3 UPPER TANK FARM AREA
BB00-EE1320 SHT 1	0C	480V SINGLE LINE DIAGRAM LC-4 LOWER TANK FARM AREA
01-13283-BB00-EE01660 SHT 1	С	SINGLE LINE DIAGRAM TERMINAL WIDE OVERVIEW POWER DISTRIBUTION TANK FARM
01-13283-BB00-EE01660 SHT 2	С	SINGLE LINE DIAGRAM TERMINAL WIDE OVERVIEW POWER DISTRIBUTION TANK FARM
01-13283-BB00-EE01660 SHT 3	В	SINGLE LINE DIAGRAM TERMINAL WIDE OVERVIEW POWER DISTRIBUTION TANK FARM
01-13283-BB00-EE01660 SHT 4	В	SINGLE LINE DIAGRAM TERMINAL WIDE OVERVIEW POWER DISTRIBUTION TANK FARM
01-13283-BB00-EE01660 SHT 5	В	SINGLE LINE DIAGRAM TERMINAL WIDE OVERVIEW POWER DISTRIBUTION TANK FARM
01-13283-BB00-EE01661 SHT 1	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB1-MCC TMEP
01-13283-BB00-EE01661 SHT 2	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB1-MCC TMEP
01-13283-BB00-EE01661 SHT 3	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB1-MCC TMEP
01-13283-BB00-EE01661 SHT 4	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB1-MCC TMEP
01-13283-BB00-EE01661 SHT 5	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB1-MCC TMEP

Number	Rev	Title
01-13283-BB00-EE01661 SHT 6	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB1-MCC TMEP
01-13283-BB00-EE01662 SHT 1	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB2-MCC TMEP
01-13283-BB00-EE01662 SHT 2	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB2-MCC TMEP
01-13283-BB00-EE01662 SHT 3	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB2-MCC TMEP
01-13283-BB00-EE01663 SHT 1	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB2A-MCC TMEP
01-13283-BB00-EE01663 SHT 2	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB2A-MCC TMEP
01-13283-BB00-EE01663 SHT 3	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB2A-MCC TMEP
01-13283-BB00-EE01663 SHT 4	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB2A-MCC TMEP
01-13283-BB00-EE01663 SHT 5	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB2A-MCC TMEP
01-13283-BB00-EE01663 SHT 6	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB2A-MCC TMEP
01-13283-BB00-EE01663 SHT 7	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB2A-MCC TMEP
01-13283-BB00-EE01664 SHT 1	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-LC3A-MCC TMEP
01-13283-BB00-EE01665 SHT 1	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-LC4A-MCC TMEP
01-13283-BB00-EE01666 SHT 1	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB3-MCC TMEP
01-13283-BB00-EE01666 SHT 2	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB3-MCC TMEP
01-13283-BB00-EE01666 SHT 3	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB3A-MCC TMEP
01-13283-BB00-EE01666 SHT 4	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB3A-MCC TMEP
01-13283-BB00-EE01666 SHT 5	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB3B-MCC TMEP
01-13283-BB00-EE01666 SHT 6	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB3B-MCC TMEP
01-13283-BB00-EE01667 SHT 1	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB4-MCC TMEP

# **APPENDIX 4 - REFERENCE DRAWINGS**


Number	Rev	Title
01-13283-BB00-EE01667 SHT 2	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB4-MCC TMEP
01-13283-BB00-EE01668 SHT 1	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB5-MCC TMEP
01-13283-BB00-EE01668 SHT 2	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB5-MCC TMEP
01-13283-BB00-EE01668 SHT 3	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB5A-MCC TMEP
01-13283-BB00-EE01668 SHT 4	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB5A-MCC TMEP
01-13283-BB00-EE01668 SHT 5	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB5B-MCC TMEP
01-13283-BB00-EE01668 SHT 6	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB5B-MCC TMEP
01-13283-BB00-EE01668 SHT 7	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB5C-MCC TMEP
01-13283-BB00-EE01668 SHT 8	С	SINGLE LINE DIAGRAM 600 VOLT DISTRIBUTION BB-ESB5C-MCC TMEP



CRANE	SPARE	SPACE	
15A BKR	15A BKR		
(120V	CONT. COIL,		
BOOSTER SUCTION MOV S-11	MOV S-12	LTG. PNL. 'NLP-F' 42 CCT.'S	
15A BKR	15A BKR		
15A BKR	15A BKR		
CHEVRON/ WESTRIDGE SUCTION MOV J7.29	PETROCAN SUCTION MOV JP4.8	30kVA	
15A BKR	15A BKR	TRANSFORME	
SHELL/ IMPERIAL SUCTION MOV JS1.2	LTG. PNL. `NLP-F' TRANSF.	480-120/208	3V
15A BKR	50A BKR		

## M.C.C. 'F' NORTH ELEVATION


ELEVATION											TF	023 02-JU					
			_		I	_					_		DRAWN D.W.M.	480V SINGLE LINE DIAGRAM	SHEET SIZE		
													CHECKED E.Z.	M.C.C. 'F' JET FUEL AREA	SCALE NONE		
													APPROVED		DATE		
3	ELECTRICAL KEY PLAN - AREA #6	EE1006												BURNABY TERMINAL	97/02/14		
2	SINGLE LINE DIAG M.C.C. 'A'	EE1024											DRAWING NUMBER				
1	LIGHTING PANEL SCHEDULES (4 SHT.'s)	EE1051				+		0	98/10/30	AS BUILT JOB 7224 - JET FUEL PUMP M."	T JN		AFE	WBS FACILITY ID. DOCUMENT No.	SHT.No. REV.		
NO.	REFERENCE DRAWINGS	DRAWING NO.	NO.	DATE	REVISION	DR	. CHK. APP	R. NO.			R. CHK.	APPR.	-	— ввоо — ее1023	O SAVE		




SPARE BREAKER	UNIT HEATER	SPACE	SPARE	SPACE
SPACE	MCC B METERS	SPACE	POWER DISTRIBUTION PANEL #2 60A BKR	SPACE
	GFA	SPACE	SPACE	SPACE
PUMP 4 ESSD	PUMP 3 SHELL	INCOMING BREAKER	PUMP 2 PETRO CAN	PUMP 1 CHEVRON
5 FVNR	4 FVNR	800A BKR	4 FVNR	4 FVNR
		1		

	MCC	В	ELEVATION
--	-----	---	-----------

MCC B ELEVATION												<b>6</b>		
				1							_	DRAWN SM	4000	SHEET SIZE A1
												CHECKED	SINGLE LINE DIAGRAM  MCC B	SCALE NONE
7	KEY PLAN DISTRIBUTION BLOCK DIAGRAM	EE1015										APPROVED	LOWER TANK FARM AREA BURNABY TERMINAL	DATE
3	KEY PLAN DISTRIBUTION BLOCK DIAGRAM	EE1015											1	94/05/17
2	LIGHTING PANEL SCHEDULES	EE1051 SHT.1/4				1	95/07/17	AS BUILT		BP			DRAWING NUMBER	
1	12.4kV & 4.16kV SINGLE LINE DIAGRAM	EE1020				0	94/05/17	REDRAWN FROM EE2004, REV.2		SM		AFE	WBS FACILITY ID. DOCUMENT No.	SHI.No. REV.
NO.	REFERENCE DRAWINGS	DRAWING NO.	NO.	DATE	REVISION	DR. CHK. APPR. NO.	DATE	REVISION		DR. CHK.	APPR.	-	— BB00 — EE1025	1








# CDP PANEL BX ELEVATION


(LOCATED IN MCC 'B' BUILDING)


8	DISTRIBUTION BLOCK DIAGRAM	EE1015	1									<b>6</b>	TRANS	MOUNTAIN		
7	SINGLE LINE DIAGRAM MCC DX	EE1028	1									DRAWN		480V	SHEET SIZ	ZE
6	480V SINGLE LINE DIAGRAM P.D.P. 6	EE1045										SM	_	SINGLE LINE DIAGRAM	A1	
5	480V SINGLE LINE DIAGRAM P.D.P. 5	EE1044										CHECKED		CDP PANEL BX	SCALE NON	NE
4	480V SINGLE LINE DIAGRAM P.D.P. 4	EE1043										APPROVED	⊣ լ	OWER TANK FARM AREA	DATE	
3	480V SINGLE LINE DIAGRAM P.D.P. 3	EE1042										1		BURNABY TERMINAL	94/05	i/18
2	480V SINGLE LINE DIAGRAM P.D.P. 1	EE1041						1	95/07/17	AS BUILT	BP			DRAWING NUMBER		
1	480V SINGLE LINE DIAGRAM MCC AX	EE1026						0	94/05/18	REDRAWN FROM EE2006 REV.1	SM	AFE	WBS	FACILITY ID. DOCUMENT No.	SHT.No.	REV.
NO	REFERENCE DRAWINGS	DRAWING NO.	NO.	DATE	REVISION	DR.	CHK. APPE	R. NO.	DATE	REVISION	DR. CHK. APPR.	_	•	— BB00 — EE1027		1













MOV 106			
MOV 202			
MOV 212         —         —         MOV 213           MOV 222         —         —         MOV 223           MOV 232         —         —         MOV 233           MOV 242         —         —         MOV 243           MOV 252         —         —         MOV 253           MOV 125         —         —         SPARE           MOV 127         —         —         SPARE           SPARE         —         —         SPARE           SPARE         —         —         SPARE	MOV 106		MOV 123
MOV 222	MOV 202		MOV 203
MOV 232	MOV 212		MOV 213
MOV 242	MOV 222		MOV 223
MOV 252	MOV 232		MOV 233
MOV 125	MOV 242		MOV 243
MOV 127	MOV 252		MOV 253
SPARE SPARE SPARE	MOV 125		SPARE
SPARE SPARE	MOV 127		SPARE
	SPARE		SPARE
SPARE -	SPARE		SPARE
	SPARE		

#### POWER DISTRIBUTION PANEL 5 ELEVATION

							VEC 6 ELEWITION										KIND	ER <b>Z</b> M	organ	TRANS	MOUNT	AIN
F	1				Н												DRAWN SM CHECKED		V SINGLE I POWER DIS MCC B P		SHEET S A/ SCALE NO	.1
	Ŧ										+						APPROVED	LC		FARM AREA	DATE 94/0	
2	К	KEY PLAN DISTRIBUTION BLOCK DIAGRAM	EE1015							1	06,	/11/14	AS BUILT - FIELD REVIEW	LDP			AFF	WBS	DRAWING NUM	BER D. DOCUMENT No.	SHT No	REV.
1	4	480V SINGLE LINE DIAG. CDP PANEL BX	EE1027							0	94,	/05/24	REDRAWN FROM EE2007, SHT. 4 OF 5 REV.1	SM			7.			•	3	4
NO.	).	REFERENCE DRAWINGS		DRAWING NO.	NO.	DATE	REVISION	DR.	CHK. AP	PR. NO	.   1	DATE	REVISION	DR.	CHK.	APPR.			_ BB00	— EE1044		1 !





 MOV NUMBERS IN THE MANIFOLD AREA ARE THE SAME AS THE NUMBERS AT THE BREAKER PANELS BUT ARE PRECEDED BY THE NUMBER '3' EG. THE BREAKER NUMBER 872 BECOMES 3872 AT THE MOV AND 882 BECOMES 3882 ETC.



#### POWER DISTRIBUTION PANEL 6 FRONT ELEVATION

													KIND	ER MORGAN TRANS	MOUNTAIN
_													DRAWN BY MHM	SINGLE LINE DIAGRAM	SHEET SIZE A1
							4	12/03	09 AS BUILT, AFE 01–12912 (FE 211021.01)	MR	BR		CHECKED BY	POWER DISTRIBUTION PANEL 6 (480V)	SCALE N.T.S.
							3	11/09	26 ISSUED FOR CONSTRUCTION, AFE 01-12912 (FE 211021.01)	кс	n PR		APPROVED BY	J l	DATE
							2	11/05	AS BUILT PER FMR #10360 (C/W FIELD VERIFICATION)	LDF	BDC			BURNABY TERMINAL	94/05/24
2	KEY PLAN DISTRIBUTION BLOCK DIAGRAM	EE1015					1	06/11	14 AS BUILT - FIELD REVIEW	LDI	•		.==	DRAWING NUMBER WBS FACILITY ID DOCUMENT NO :	017 NO DD/
1	480V SINGLE LINE DIAG. CDP PANEL BX	EE1027					0	94/05	24 REDRAWN FROM EE2007 SHT. 5 OF 5 REV. 2	N	м		AFE		STI NU KEV
NO	REFERENCE DRAWINGS	DRAWING NO	NO	DATE	REVISION	DRN CHK AF	PR NO	DAT	REVISION	DRI	N CHK	APPR		— BB00 — EE1045	4






### MCC E MCC EX NAMEPLATE (NOTE 1)-MAIN BREAKER INCOMING P.L.M. SHOP FEEDER 200A BKR SPACE SPACE MECHANICAL MAINTENANCE SHOP FEEDER 12 CCT. 120/208V LIGHTING PANEL ELP-EX 200A BKR EAST INTRFCE 9kVA MONITOR TFMR. BUILDING I 5A BKR\_A BKR MAIN BREAKER 30A BKR\_A BKR 9kVA 480-120/208V TRANSFORMER SPACE 600A


#### MCC E & MCC EX ELEVATION


				<u>.M</u>	MCC E & MCC EX ELEVATION							TRANS MOUNTAIN		JC 25-740
			_								DRAWN D.W.M.	480V SINGLE LINE DIAGR		SHEET SIZE
5	ELECTRICAL KEY PLAN	EE1000									CHECKED M.L.	MCC 'E' & MCC 'E		SCALE SCALE NONE
4	480V SINGLE LINE DIAGRAM - P.L.M.	EE1029									APPROVED			DATE
3	LIGHTING PANEL SCHEDULES	EE1051 ( 4 SHT'S )										BURNABY TERMINAL		94-05-20
2	480V SINGLE LINE DIAGRAM - MCC AX	EE1026				1	95-07-20	AS BUILT	B.P.			DRAWING NUMBER		
1	12.47kV & 4.16kV SINGLE LINE DIAGRAM	EE1020				0	94-11-09	AS-BUILT - AFE 4126	T.L.	M.L.	AFE			SHT.No. REV.
NO.	REFERENCE DRAWINGS	DRAWING NO.	NO.	DATE	REVISION	DR. CHK. APPR. NO.	DATE	REVISION	DR.	CHK. APP	R.	— — ВВОО — ЕЕ	1047	1   🖁


#### WARNING


THIS MCC LINE-UP IS SUPPLIED BY TWO SEPARATE SOURCES OF POWER. DISCONNECT BOTH POWER SOURCES BEFORE WORKING ON MCC.












TK81 MCC POWER DISTRIBUTION

MCC UNIT INCLUDES EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.


kinder#morgan

												RIND	erymo	TRANS	з моим	ITAIN
Г												DRAWN BY DWM	SINGL	E LINE DIAGRAM TK81 MCC	SHEET SI	iZE .1
:	5	NLP-81A LIGHTING PANEL SCHEDULE	EE1472									CHECKED BY FA		TANK 81	SCALE NT:	is
- 4	4	MOV-DD81 SCHEMATIC & WIRING	EE1463									APPROVED BY			DATE	-
	3	TANK 81 EXTERIOR LIGHTING SCHEMATIC & WIRING	EE1154										BU	RNABY TERMINAL	13/03	3/14
	2	MOV-TK81 SCHEMATIC & WIRING	EE1153					1	14/02/28 AS BUILT, AFE 01-13279	DWM	FA			WING NUMBER		
	1	PUMPHOUSE & TANK AREA SINGLE LINE DIAGRAM	EE1021					0	13/03/25 ISSUED FOR CONSTRUCTION, AFE 01-13279 (FE 212269.01)	KCh	FA	AFE		FACILITY ID DOCUMENT NO	SHI NO	REV
N	0	REFERENCE DRAWINGS	DRAWING NO	NO	DATE	REVISION	DRN CHK APPR	NO	DATE REVISION	DRN	CHK APPR	01-13279	C1A01 -	BB00 — EE1031	2	1




- MCC UNIT TO INCLUDE EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.
- 2. EXTRACTED FROM DRAWING BB00-EE1032.

									KIND	ER MORGAN TRANS	S MOUNTAIN
7 SCHEMATIC DIAGRAM MOV TK83 TANK 83 BAY	EE115001								DRAWN BY	SINGLE LINE DIAGRAM	SHEET SIZE
6 NLP-83A PANEL BOARD SCHEDULE	EE1032 SHEET 3								МНМ	480V TK83 MCC	AI
5 TK83 MCC ELEVATION	EE1032 SHEET 1			4	16/02/08	AS BUILT, AFE #01-13548	RLY SA	GRL	CHECKED BY	TK83 LC BUILDING	SCALE NTS
4 LIGHTING CONTACTOR WIRING	EE1151			3	15/07/23	ISSUED FOR CONSTRUCTION, AFE #01-13548	LGC SA	GRL	APPROVED BY	-	DATE
3 MOV STARTER WIRING	EE1150			2	14/01/21	AS BUILT, AFE 01-13343	JJK GL			BURNABY TERMINAL	13/08/29
2 MIXER STARTER WIRING	EE1149			1	13/12/18	AS BUILT, AFE 01-13343	KCh LS			DRAWING NUMBER	
1 S.L.D. PUMPHOUSE & TANK AREA	EE1021			0	13/08/29	ISSUED FOR CONSTRUCTION, AFE 01-13343 (FE 213131)	KCh LS		AFE	WBS FACILITY ID DOCUMENT NO FORMERLY FE1032 BB00 EE1032	SHT NO REV
NO REFERENCE DRAWINGS	DRAWING NO NO	DATE REVISION	DRN CHK	APPR N	DATE	REVISION	DRN CH	APPR	01-13343	C1A01 - BB00 - EE1032	2   4



- MCC UNIT TO INCLUDE EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.
- 2. EXTRACTED FROM DRAWING BB00-EE1036.


									KIND	er <b>z</b> morga <u>n</u>		
						1			DRAWN BY MHM	SINGLE LINE DIAGRAM	SHEET S	SIZE A1
6 NLP-82A PANEL BOARD SCHEDULE	EE1036 SHEET 3									TK82 MCC		
5 TK82 MCC ELEVATION	EE1036 SHEET 1								CHECKED BY	TANK 82	SCALE NT	NTS
4 LIGHTING CONTACTOR WIRING	EE1108								APPROVED BY		DATE	
3 MOV STARTER WIRING	EE1107			2	14/01/2	1 AS BUILT, AFE 01-13343	JJK GI			BURNABY TERMINAL	13/0	08/29
2 MIXER STARTER WIRING	EE1106			1	13/12/18	B AS BUILT, AFE 01-13343	KCh LS	3		DRAWING NUMBER		
1 S.L.D. PUMPHOUSE & TANK AREA	EE1021			0	13/08/29	ISSUED FOR CONSTRUCTION, AFE 01-13343 (FE 213131)	KCh LS	3	AFE	WBS FACILITY ID DOCUMENT NO		REV
NO DECEDENCE DRAWINGS	DRAWING NO. N	O DATE PENISION	DBN CHK	ADDD N	DATE	DEVICION	DBN CL	V ADDD	01-13343	C1A01 — BB00 — EE1036	2	2





- MCC UNIT INCLUDES EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.
- 2. EXTRACTED FROM DRAWING BB00-EE1037.

													KIND	er <b>‡</b> mo	organ	TRANS	MOUNTAIN
	NLP-84A PANEL BOARD SCHEDULE	EE1037 SHEET 3	1								$\overline{}$		DRAWN BY MR	SING	SLE LINE D		SHEET SIZE A1
5	TK84 MCC ELEVATION	EE1037 SHEET 1						4 15/04	04/10 AS BUILT	LT, AFE 01-13577 MR	R K	KS .	CHECKED BY LS		TK84 MC TANK 84		SCALE NTS
4	LIGHTING CONTACTOR WIRING	EE1111						3 14/05	05/30 ISSUED	FOR CONSTRUCTION, AFE 01-13577 (TT 214018.00)	R F	FA	APPROVED BY				DATE
3	MOV STARTER WIRING	EE1110						2 14/0	01/21 AS BUILT	LT, AFE 01-13343 JJK	K G	GL		В	urnaby teri	/INAL	13/08/29
2	MIXER STARTER WIRING	EE1109						1 13/12	12/18 AS BUIL	ILT, AFE 01-13343 KCI	h L	LS	.==		RAWING NUMBER	DOO!!!!ENT NO	01/7 NO 05/
1	S.L.D. PUMPHOUSE & TANK AREA	EE1021						0 13/0	08/29 ISSUED	FOR CONSTRUCTION, AFE 01-13343 (FE 213131) KC	h L		AFE	WBS			SHT NO REV
NC	DECEDENCE DRAWINGS	DRAWING NO	NO	DATE PENSIONI	DDN	CHK V	000	NO DA	DATE	DEVISION DE	N C	UV ADDD	01-13343-	C1A01	— BB00 —	EE1037	2   4




- MCC UNIT TO INCLUDE EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.
   EXTRACTED FROM DRAWING EE1040.


KINDER MORGAN


													RINUER	TRANS	MOUNTAIN
Γ	6	NLP-74A PANEL BOARD SCHEDULE	EE1040 SHEET 3	1									MIX	SINGLE LINE DIAGRAM TK74 MCC	SHEET SIZE A1
	5	TK74 MCC ELEVATION	EE1040 SHEET 1										CHECKED BY LS	TANK 74	SCALE NTS
Γ	4	LIGHTING CONTACTOR WIRING	EE1120						3	14/04/04 AS BUILT, AFE 01-12627	TM FA		APPROVED BY		DATE
Γ	3	MOV STARTER WIRING	EE1119						2	14/01/21 AS BUILT, AFE 01-13343	JJK GL		1	BURNABY TERMINAL	13/08/29
Γ	2	MIXER STARTER WIRING	EE1118						1	13/12/18 AS BUILT, AFE 01-13343	KCh LS		AFF W	DRAWING NUMBER BS FACILITY ID DOCUMENT NO	CUT NO DE
Γ	1	S.L.D. PUMPHOUSE & TANK AREA	EE1021						0	13/08/29 ISSUED FOR CONSTRUCTION, AFE 01-13343 (FE 213131)	KCh LS				SHI NU REV
	NO	REFERENCE DRAWINGS	DRAWING NO	NO	DATE	REVISION	DRN CH	K APPR	NO	DATE REVISION	DRN CHK	APPR	01-13343- C1	A01 — BB00 — EE1040	2   3

 MCC UNIT TO INCLUDE EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.



								KIND	er <b>‡</b> morg <u>an</u>	
					_			DRAWN BY JJK	SINGLE LINE DIAGRAM	SHEET SIZE A1
								CHECKED BY GL	TANK 90/88	SCALE N.T.S.
					2 1	13/04/29 AS BUILT, AFE 01-13104	MR MI	APPROVED BY	BURNABY TERMINAL	DATE 13/03/13
2 PANELBOARD NLP-88/90A	EE132203				_	13/03/25 AS-BUILT FMR #10394	LDP PP	AFE	DRAWING NUMBER  WBS FACILITY ID DOCUMENT NO	SHT NO REV
1 MCC ELEVATION TANK 88/90  NO REFERENCE DRAWINGS	DRAWING NO NO	DATE	REVISION DRN CHK	APPR	_	13/03/08 AS-BUILT AFE# 01-13115 - DWG SPLIT TO SHTS 01, 02 & 03  DATE REVISION	JJK GL DRN CHI			2 2






REFERENCE DRAWINGS


DRAWING NO


NO DATE

REVISION

										KIND	ERZMORGAN TRANS	MOUNTAIN
										DRAWN BY KCh	SINGLE LINE DIAGRAM	SHEET SIZE A1
										CHECKED BY MI	NAEMS	SCALE NTS
_										APPROVED BY	UPPER ROAD TANK 88 BURNABY TERMINAL	DATE 13/01/23
				1	13/04/29	AS BUILT, AFE 01-13104	MR	М		AFE	DRAWING NUMBER WBS FACILITY ID DOCUMENT NO	SHT NO REV
				0	13/01/31	ISSUED FOR CONSTRUCTION, AFE 01-13104 (FE 213027.00)	KCh	М				SHI NO REV
	DRN	СНК	APPR	NO	DATE	REVISION	DRN	CHK	APPR	ψ1-13104	C1A01 — BB00 — EE1466	1 1







DRN CHK APPR

NO DATE

DRAWING NO

REVISION


DRN CHK APPR


NO


DATE

REVISION

REFERENCE DRAWINGS










- MCC UNIT TO INCLUDE EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.
- 2. EXTRACTED FROM DRAWING BB00-EE1033.

KINDER MORGAN

TRANS MOUNTAIN

										DRAWN BY	SINGLE LINE DIAGRAM	SHEET SIZE
6	NLP-85A PANEL BOARD SCHEDULE	EE1033 SHEET 3				2C :	2017/01/11 ISSUED FOR DESIGN AFE #01-13283 (CH2M PROJ. #660356)	PB RL	JE	IVIR	TK85 MCC	A1
5	TK85 MCC ELEVATION	EE1033 SHEET 1				2B 2	2016/12/13 RE-ISSUED FOR REVIEW AFE #01-13283 (CH2M PROJ. #660356)	NY RL	JE	CHECKED BY LS	TANK 85	SCALE NTS
4	LIGHTING CONTACTOR WIRING	EE1148				2A 2	2016/09/30 ISSUED FOR APPROVAL AFE #01-13283 (CH2M PROJ. #660356)	NY RL	JE	APPROVED BY		DATE
3	MOV STARTER WIRING	EE1147				2	14/01/21 AS BUILT, AFE 01-13343	JJK GL			BURNABY TERMINAL	13/08/29
2	MIXER STARTER WIRING	EE1146				1	13/12/18 AS BUILT, AFE 01-13343	KCh LS		AFF WI	DRAWING NUMBER  BS FACILITY ID DOCUMENT NO	SHT NO BEV
1	S.L.D. PUMPHOUSE & TANK AREA	EE1021				0	13/08/29 ISSUED FOR CONSTRUCTION, AFE 01-13343 (FE 213131)	KCh LS		AFE WI		
NC	REFERENCE DRAWINGS	DRAWING NO	NO DATE	REVISION DRN	CHK APPR	NO	DATE REVISION	DRN CHK	APPR	01-13283-	— BB00 — EE1033	2 2C



TK71 MCC POWER DISTRIBUTION

INULES:

MCC UNIT INCLUDES EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.


1. MCC UNIT INCLUDES EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.

KINDER MORGAN

									CANADA TRA	NS MOUNTAIN
<u>r</u>		Т			<u> </u>	T		drawn by DWM	SINGLE LINE DIAGRAM	SHEET SIZE A1
5 NLP-71A LIGHTING PANEL SCHEDULE	EE1474				1C 17/01/11	ISSUED FOR DESIGN AFE #01-13283 (CH2M PROJ. #660356)	PB RL JE	CHECKED BY FA	TK71 MCC TANK 71	SCALE NTS
4 MOV-DD71 SCHEMATIC & WIRING	EE1461				1B 16/12/13	RE-ISSUED FOR REVIEW AFE #01-13283 (CH2M PROJ. #660356)	NY RL JE	APPROVED BY		DATE
3 TANK 71 EXTERIOR LIGHTING SCHEMATIC & WIRING	EE1145				1A 16/09/30	ISSUED FOR APPROVAL AFE #01-13283 (CH2M PROJ. #660356)	NY RL JE		BURNABY TERMINAL	13/03/14
2 MOV-TK71 SCHEMATIC & WIRING	EE1144				1 14/02/28	AS BUILT, AFE 01-13277	DWM FA	, FF	DRAWING NUMBER  WBS FACILITY ID DOCUMENT N	NO CHI NO BEV
1 PUMPHOUSE & TANK AREA SINGLE LINE DIAGRAM	EE1021				0 13/03/25	ISSUED FOR CONSTRUCTION, AFE 01-13277 (FE 212269.00)	KCh FA	AFE.		
NO REFERENCE DRAWINGS	DRAWING NO NO	DATE	REVISION	DRN CHK AF	PR NO DATE	REVISION	DRN CHK APPR	01-13283-	— BB00 — EE1034	+   2   1C



3c #350 MCM TECK ----



TK73 MCC POWER DISTRIBUTION

# NOTES:


 MCC UNIT TO INCLUDE EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.



								ISSUED FOR DESIGN		KIND	KINDER MORGAN TRANS MOUNTAIN				
T T			T	<del>                                      </del>					Т	DRAWN BY	I MCC SINGLE LINE DIAGNAM I	SHEET SIZE A1			
										CHECKED BY	TANK 73	SCALE N.T.S.			
					0	OC 2017/01/11	ISSUED FOR DESIGN AFE #01-13283 (CH2M PROJ. #660356)	PB RL	JE	APPROVED BY	-	DATE			
					0	DB 2016/12/13	RE-ISSUED FOR REVIEW AFE #01-13283 (CH2M PROJ, #660356)	NY RL	JE		BURNABY TERMINAL	13/03/13			
2 PANELBOARD NLP-73A TANK 73	EE103503				0	A 2016/09/30	ISSUED FOR APPROVAL AFE #01-13283 (CH2M PROJ. #660356)	NY RL	JE	, F.F.	DRAWING NUMBER  WBS FACILITY ID DOCUMENT NO S	CHT NO DEV			
1 MCC ELEVATION TANK 73	EE103501				(	0 13/03/13	AS-BUILT AFE# 01-13204	JJK AL		AFE	·	SHI NU REV			
NO REFERENCE DRAWINGS	DRAWING NO	NO DATE	REVISION	DRN CHK	APPR N	NO DATE	REVISION	DRN CHK	APPR	01-13283-	- BB00 - EE1035	2 OC			

### FROM LOADCENTRE LC-3 SEE REF. 1

3c #2 TECK ----






# NOTES:

1. MCC UNIT TO INCLUDE EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.

KIND	ERZN	IORGAN CANADA	TRANS	MOUNTAIN
DRAWN BY MH	МСС	SINGLE LINE TANK 86	DIAGRAM	SHEET SIZE A1
CHECKED BY		TAINN 00		SCALE NTS

										MH	MCC SINGLE LINE DIAGRAI	M A1
5 PANEL BOARD NLP-86 TANK 86	EE103803					1C 2017/01/11 ISSUED FOR DESIGN /	AFE #01-13283 (CH2M PROJ. #660356)	PB RL	JE	CHECKED BY	TANK 86	SCALE NTS
4 MCC ELEVATION TANK 86	EE103801					1B 2016/12/13 RE-ISSUED FOR REVIE	EW AFE #01-13283 (CH2M PROJ. #660356)	NY RL	JE	APPROVED BY		DATE
3 LIGHTING CONTACTOR WIRING	EE1114					1A 2016/09/30 ISSUED FOR APPROVA	AL AFE #01-13283 (CH2M PROJ. #660356)	NY RL	JE		BURNABY TERMINAL	13/01/02
2 MOV STARTER	EE111301, EE111302					1 13/01/21 AS-BUILT AFE 01-12	2887	JJK GL	GL		DRAWING NUMBER	
1 LC3, UPPER TANK FARM AREA	EE131901, EE131902					0 13/01/07 ISSUED FOR CONSTRU	JCTION AFE 01-12887	JJK GL	GL	AFE L	WBS FACILITY ID DOCUMENT NO	O SHI NO RE
NO REFERENCE DRAWINGS	DRAWING NO	NO DATE	REVISION	DF	RN CHK APPR	NO DATE	REVISION	DRN CHK	APPR	01-13283-	— BB00 — EE1038	2   10



 MCC UNIT INCLUDES EXTERNAL WARNING LABEL ADVISING OF POWER FROM SEPARATE SOURCES.


TRANS MOUNTAIN

2. EXTRACTED FROM DRAWING BB00-EE1039.

KINDER MORGAN


	ch211
,	11 JAN 2017 11 ISSUED
	FOR DESIGN


											DRAWN BY	SINGLE LINE DIAGRAM	SHEET SIZE
6 NLP-72A PANEL BOARD SCHEDULE	EE103903					4A 2	16/09/30	ISSUED FOR APPROVAL AFE #01-13283 (CH2M PROJ. #660356)	NY RL	JE	MK	TK72 MCC	A I
5 TK72 MCC ELEVATION	EE103901					4	5/04/10	AS BUILT, AFE 01-13576	MR KS		CHECKED BY LS	TANK 72	SCALE NTS
4 LIGHTING CONTACTOR WIRING	EE1117					3	4/05/30	ISSUED FOR CONSTRUCTION, AFE 01-13576 (TT 214018.00)	MR FA		APPROVED BY		DATE
3 MOV STARTER WIRING	EE1116					2	4/01/21	AS BUILT, AFE 01-13343	JJK GL			BURNABY TERMINAL	13/08/29
2 MIXER STARTER WIRING	EE1115	4C	2017/01/11 ISSUED FOR DESIGN AFE #01-13283 (CH2M PROJ. #660356)	PB RL	JE	1	3/12/18	AS BUILT, AFE 01-13343	KCh LS		A.E.E.	DRAWING NUMBER  WBS FACILITY ID DOCUMENT NO	T CLIT NO BEV
1 S.L.D. PUMPHOUSE & TANK AREA	EE1021	4B	2016/12/13 RE-ISSUED FOR REVIEW AFE #01-13283 (CH2M PROJ. #660356)	NY RL	JE	0	3/08/29	ISSUED FOR CONSTRUCTION, AFE 01-13343 (FE 213131)	KCh LS		AFE 1		
NO REFERENCE DRAWINGS	DRAWING NO	NO	DATE REVISION	DRN CHK	APPR	NO	DATE	REVISION	DRN CHK	APPR	01-13283-	— BB00 — EE1039	2 4C





									TR	480V SINGLE LINE DIAGRAM LC-3 UPPER TANK FARM AREA  SHEET SIZE A1 SCALE NONE		
	<u> </u>								DRAWN DA		SHEET SIZE A1	
									CHECKED AAW			
				00	2017/01/11	ISSUED FOR DESIGN AFE #01-13283 (CH2M PROJ. #660356)	PB RL	JE	APPROVED			
3 SINGLE LINE DIAGRAMS & MCC LAYOUTS EE1031 TO EE1040				OB	2016/12/13	RE-ISSUED FOR REVIEW AFE #01-13283 (CH2M PROJ. #660356)	NY RL	JE	1	BURNABY TERMINAL	97/11/15	
2 SINGLE LINE DIAGRAM FIRE PUMPHOUSE EE1021 (2 SHEETS)				0A	2016/09/30	ISSUED FOR APPROVAL AFE #01-13283 (CH2M PROJ. #660356)	NY RL	JE	.55			
1 ELECTRICAL KEY PLAN EE1000				0	99/05/31	AS BUILT JOB 7134 ( GENERATOR FOR LC-3 ADDED), FORMERLY PART OF EE1021 SHEET 1	DA AAW	AAW	AFE	WBS FACILITY ID. DOCUMENT No.		
NO. REFERENCE DRAWINGS DRAWING NO.	NO. DATE	REVISION	DR. CHK. APPF	R. NO.	DATE	REVISION	DR. CHK.	APPR.	01-13283-	— BB00 — EE1319	1/2 OC	






— ввоо — EE1320

1/2 OC

PB RL NY RL OC | 2017/01/11 | ISSUED FOR DESIGN AFE #01-13283 (CH2M PROJ. #660356) SINGLE LINE DIAGRAMS & MCC LAYOUTS | EE1031 TO EE1040 OB 2016/12/13 | RE-ISSUED FOR REVIEW AFE #01-13283 (CH2M PROJ. #660356) NY RL DA AAW SINGLE LINE DIAGRAM FIRE PUMPHOUSE EE1021 (2 SHEETS) OA | 2016/09/30 | ISSUED FOR APPROVAL AFE #01-13283 (CH2M PROJ. #660356) AAW ELECTRICAL KEY PLAN 99/05/31 AS BUILT JOB 7134 (GENERATOR FOR LC-4 ADDED), FORMERLY PART OF EE1021 SHEET 1 DR. CHK. 01-13283-DR. CHK. APPR. NO. DATE APPR. REFERENCE DRAWINGS DRAWING NO. NO. DATE REVISION REVISION



### SINGLE LINE DIAGRAM NOTES:

- DRAWING FORMATS USED ARE BASED ON CHAPPEL STATION DRAWING FORMATS.
- 2. 600V TRANSFORMER SIZES TO BE DETERMINED. NOMINAL
- SIZES SHOWN.
- 3. GENERATOR SIZES TO BE DETERMINED.
- 4. MCC CIRCUIT BREAKER SIZES TO BE DETERMINED.
- NOMINAL SIZES SHOWN. 5. UPS SIZES TO BE DETERMINED.
- 6. ALL PT'S, CT'S AND FUSE SIZES TO BE DETERMINED.



NY RL

NY RL

DRN CHK APPR

ISSUED FOR DESIGN AFE #01-13283 (CH2M PROJ. #660356)

ISSUED FOR APPROVAL AFE #01-13283 (CH2M PROJ. #660356)

REVISION

B | 13DEC2016 | RE-ISSUED FOR REVIEW AFE #01-13283 (CH2M PROJ. #660356)

A 30SEP2016


NO DATE


REFERENCE DRAWING NO.

NO.

REFERENCE DRAWING TITLE

1		(Fig. 1)	TRANSMOUNTAIN											
	DRAWN BY N. YOUNG	_	SINGLE LINE	SHEET S										
	CHECKED BY	T I	ERMINAL WID		SCALE	'								
	R. LEE		POWER DISTRIBUTION  TANK FARM											
JE	APPROVED BY  J. ESTERER		BURNABY 1	DATE 2015/	07/10									
JE	PROJECT			DRAWING NUMBER										
JE	AFE AFE		FACILITY ID	DOCUMENT NO	SHT NO	REV								
APPR	01-13	283	BB00	EE01660	01	С								





Ch2M 11 JAN 20 ISSUED FOR

						AWING PREVIOUSLY				TRANS MOUNTAIN		
		T		1	PART OF	BB00-EE01660,	SHI 02 (RI	EV. A)	DRAWN BY N. YOUNG	SINGLE LINE DIAGRAM	SHEET SIZ	
									CHECKED BY R. LEE	TERMINAL WIDE OVERVIEW POWER DISTRIBUTION	SCALE NTS	
									APPROVED BY	TANK FARM	DATE	
			В	11JAN2017	ISSUED FOR DESIGN AFE #01-13283 (CH2M PROJ. #660356)		PB RL	JE	J. ESTERER PROJECT COL		2016/0	
			А	13DEC2016	ISSUED FOR REVIEW AFE #01-13283 (CH2M PROJ. #660356)		NY RL	JE	01-132	FACILITY ID   DOCUMENT NO	03	REV D
NO.	REFERENCE DRAWING TITLE	REFERENCE DRAWING NO.	NO	DATE	REVISION	[	ORN CHK	APPR	01-132	83   BB00 — EE01660	US	D

